

Question 4

Can we send the copy of LC by email? or need to mail the original copy?

Answer 4

Letter of Credit (LC) can be provided as an email copy, the successful proponent will be required to supply the original.

Question 5

By reviewing the video, some of the Protruded Services are located within the Multiple Fracture FM. We are concerned when the trimming process starts that there may be a pipe collapse situation due to vibration. How should we treat that? Same situation may apply to root cutting as well? Please advise.

Answer 5

- The required coding format for the CCTV sewer inspection is the Water Research centre's 3rd edition Manual of Sewer Condition Classification, 1993 and associated 1996 Addendum as indicated in the specifications;
- Styrenated resins are **not** acceptable as indicated in the associated CIPP and Trenchless Point repair specifications for this project.

Question 6

For the lining material: Will the engineer accept a closed system?

Answer 6

CIPP liner and trenchless point repairs must be installed in accordance with the specifications already supplied and only non-styrenated resins will be accepted.