

Project : Kouchibouguac Park Power Line Upgrade

Solicitation # : 5P131-13-0539

Q1: Is the line construction built as standard construction or compact construction?

A1: Standard Construction.

Q2: Does this tender include installing a neutral wire on the new poles approximately two KM or using the neutral from the existing underground primary.

A2: Install neutral wire on new poles for approximately 2 km.

Q3: How wide will the new route be cleared from trees.

A3: 40 to 50 feet.

Q4: Who will transfer the communication cables?

A4: Bell Aliant

Q5: Will permission be granted to have extended power interruptions to install new facilities and transfer existing equipment.

A5: Yes

Q6: Who is authorized to provide line inspection as to being built to standards on customer owned facilities?

A6: Both NB Public Safety for the project and NB Power for any upgrades to existing power lines leading to distribution interfaces.

Q7: Are CAD drawings acceptable for the engineering and plan drawings.

A7: Yes