



Addendum / Addenda

No./N^o
4

Project Description / Description de projet M-20 Biocomposite Lab Renovation		
Solicitation No./ No de sollicitation 13-22073	Project No./N ^o de projet 3714	W.O. No./N ^o d'ordre de travail
Departmental Representative / représentant ministériel Denis Labelle		Date Oct. 23, 2013
<p>Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p>		<p>Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p>

Mechanical :

From questions submitted by contractors

- 1- on Drwg 3714-G01 – note 2 mentions 32mm piping, on the drawing it indicates 25mm could you please clarify the size required
 - Note 2 should indicated 25mm (nominal- 1” Piping) NOT 32mm (1-1/4”)
- 2- on Drwg 3714-G01 – note 5 mentions DCW piping and ball valves sized and located as indicated. No note 5 on drawing
 - NO DCW piping required (therefore note not required)- delete from work.
- 3- on Drwg 3714-G01 – note 6 mentions “as indicated”. No note 6 on drawing
 - This note no longer valid- delete from work.