

**RETURN BIDS TO:
 RETOURNER LES SOUMISSIONS A:
 Bid Receiving/Réception des
 sousmissions**

RCMP / GRC
 Procurement & Contracting services
 c/o Commissionaires, F Division
 6101 Dewdney Avenue
 Regina, SK S4P 3K7

**Facsimile Number for Amendments:
 (306) 780-3466**

**SOLICITATION AMENDMENT
 MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les memes.

Comments - Commentaries

Vendor/Firm Name and Address
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Title-Sujet Electronic Gate Replacement and Extension of Existing Fence, Innisfail, AB	
Solicitation No. - No. de l=invitation M5000-4-3608/A	Date 24 October 2013
Amendment No. - No modif. 02	
Client Reference No. - No. De Référence du Client 827522	
GETS Reference No. - No. de Référence de SEAG PW-13-00506621	
Solicitation Closes -L' invitation prend fin at - à 2 :00 pm Central Standard Time Zone on - le 31 October 2013	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Bonny Manz, Senior Contracting Officer	
Telephone No. - No de téléphone (306) 780-3352	Fax No. - N° de FAX: (306) 780-3466
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police Police Dog Services Training Centre Highway 2, Exit 365 East Innisfail, AB T4G 1S8	
This document contains a PERSONNEL SECURITY Clearance requirement.	
Delivery Required - Livraison exigée:	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l' entrepreneur	



**Royal Canadian Mounted Police
Gendarmerie royale du Canada**

Government
of Canada

Gouvernement
du Canada

Solicitation No./No de l'invitation: M5000-4-3608/A2

The purpose of this amendment is to add an addendum called "PHYSICAL ACCESS SOLUTIONS", add an item to ANNEX "A" Specifications, and answer the following questions:

Page 18 of 21

Under "9 SCOPE OF WORK", 9.10

INSERT: Wiring for the card reader is to terminate in the telephone/LAN room. Wiring for the camera, intercom and operator to open the gate to terminate at the front office.

Questions and Answers:

Q1. The existing fence is 2.4m high plus barbed wire. The drawings and specifications call for 1.8m high plus barbed wire. Should we bid 2.4m high, which will match existing? Or should we quote 1.8m high, as the details note?

A1. *Contractor to match existing fence height.*

Q2. In the scope, item 9.6 asks for one gate motor. On A2 the gate opening is 8.19m, with bollards in the centre of the opening. The critical dimensions chart on A2 (A) states clear opening of gate is 3.75m.

a) Which figure is correct?

b) If the critical dimensions chart is correct, then are we supplying two gates, and operators?

c) If two gates are to be installed, there will be no room for the gate to open beside the entrance lane.

A2. a) *The critical dimensions chart is correct.*

b) A2 Plainview and elevation x 2. Supply two gates and operators.

c) Contractor to accommodate perimeter security fencing to allow the gate to open on the entrance lane.

Q3. Can we be given the access control hardware details to confirm compatibility with the operator we supply?

A3. *See Addendum entitled "PHYSICAL ACCESS SOLUTIONS".*

Q4. Because of the short time line for supply, can we offer an alternate sliding gate system? The design on A2 may require up to 8-10 weeks for delivery?

A4. *Yes, an alternate system may be offered as long as it is a pre-approved alternate.*

Q5. Is there a specification for the fence framework? Or do we match existing sizes, and suggest a wall thickness (e. SC-40)?

A5. *Contractor to match existing sizes.*