

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions/Travaux
publics et Services gouvernementaux Canada
The Cambridge Building
3 Queen Street/3, rue Queen
Charlottetown
Prince Edward Island
C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
The Cambridge Building
3 Queen Street/3 rue, Queen
PO Box 1268/CP 1268
Charlottetown
Prince Ed
C1A 4A2

Title - Sujet Exhaust Fan Replac,CFIA,Charlotteto	
Solicitation No. - N° de l'invitation 39903-140188/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client 39903-140188	Date 2013-10-24
GETS Reference No. - N° de référence de SEAG PW-\$PWC-010-3310	
File No. - N° de dossier PWC-3-36048 (010)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-10-29	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: MacDonald, Anne (PWC) D.	Buyer Id - Id de l'acheteur pwc010
Telephone No. - N° de téléphone (902) 626-4949 ()	FAX No. - N° de FAX (902) 566-7514
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Addendum One
October 24, 2013**39903-140188/A****Exhaust Fan Replacement, Canadian Food Inspection Agency, 93 Mt Edward Road,
Charlottetown, PE**

The following Addendum to the tender is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Question & Answer

Re: Specification Section 23 24 25 - Packaged Roof Exhausters & Page 3 Part 2 - Products,
2.1 Roof Exhausters (Fume Hood Type Fan), 2.1.7

Question:

1. Alternate Fan: Vari-Plume Laboratory Exhaust by Loren Cook Company

Answer:

2. Shop-drawing submission was incomplete to verify full compliance with specification.

Date

Signature of Contractor