

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des
sousmissions**

RCMP / GRC
Procurement & Contracting services
c/o Commissionaires, F Division
6101 Dewdney Avenue
Regina, SK S4P 3K7

**Facsimile Number for Amendments:
(306) 780-3466**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les memes.

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Title-Sujet Site Preparation and Erection of Pre-engineered Building, Innisfail, AB	
Solicitation No. - No. de l=invitation M5000-4-3609/A	Date 28 October 2013
Amendment No. - No modif. 04	
Client Reference No. - No. De Référence du Client 1003933	
GETS Reference No. - No. de Référence de SEAG PW-13-00506624	
Solicitation Closes -L' invitation prend fin at - à 2 :00 pm Central Standard Time Zone on - le 31 October 2013	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Bonny Manz, Senior Contracting Officer	
Telephone No. - No de téléphone (306) 780-3352	Fax No. - N° de FAX: (306) 780-3466
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police Police Dog Services Training Centre Highway 2, Exit 365 East Innisfail, AB T4G 1S8	
This document contains a PERSONNEL SECURITY Clearance requirement.	
Delivery Required - Livraison exigée:	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



Royal Canadian Mounted Police
Gendarmerie royale du Canada

Government
of Canada

Gouvernement
du Canada

Solicitation No./No de l' invitation: M5000-4-3609/A4

The purpose of this amendment is to answer the following question:

QUESTION AND ANSWER:

- Q8.** Looking at details A and B on S2.0, I noticed the detail " Fill material to be free draining pitrun gravel in 150mm lifts compact to 95% S.P.D.D." Does this mean that the entire foot print of the building must be excavated down to the footing level and bought back up with fill material or does it only represent the areas around the perimeter that were excavated for the installation of the footing?
- A8.** *The entire area under the structure is to be excavated and backfilled with pitrun gravel compacted to 95% S.P.D.D., as well as a minimum of 150 mm of crushed gravel is to be placed under the entire slab and compacted 95% S.P.D.D. These requirements reflect Section C of the geotechnical report by Smith and Dow Associates Ltd. dated March 19th, 2003.*