

---

**Q1 Re; Hoisting requirements**

Are we allowed crane set up on the southwest and northwest corners below the roadway?

Response: We have had cranes set up in both these locations in the past. I have attached a photo of a crane set up on the north west side. I do not have a photo of the crane set up on the south west side. The waterfront trails have been completed since the photo was taken and the contractor should be aware that the trail travels beneath both the north and south underpasses and pedestrian control may be required. Also to consider is the weight of proposed crane the ability of the soil to accept the weight.

**Q2 Re; Hoisting requirements**

If there are any underground water canals in the area please provide a layout drawing.

Response: We are unaware of any underground water canals. There are equalization pockets beneath both towers which connect to the canal.