

PART 1 - GENERAL

1.1 GENERAL

- .1 The purpose of this section is to describe the hangers for the PVC pipe to be installed in the degasser building. The Contractor is responsible to install these hangers.
- .2 The hangers shall be installed in such a way as to be easy to maintain and inspect.
- .3 All hanger material is to be 316 stainless steel, or corrosion-proof rods.

1.2 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
 - .1 ASME B31.1-07, Power Piping.
- .2 ASTM International
 - .1 ASTM A 125-1996(2007), Standard Specification for Steel Springs, Helical, Heat-Treated.
 - .2 ASTM A 307-07b, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .3 ASTM A 563-07a, Standard Specification for Carbon and Alloy Steel Nuts.
- .3 Factory Mutual (FM)
- .4 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS)
 - .1 MSS SP 58-2002, Pipe Hangers and Supports - Materials, Design and Manufacture.
 - .2 MSS SP 69-2003, Pipe Hangers and Supports - Selection and Application.
 - .3 MSS SP 89-2003, Pipe Hangers and Supports - Fabrication and Installation Practices.
- .5 Underwriter's Laboratories of Canada (ULC)

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and data sheets for hangers and supports and include product characteristics, performance criteria,

physical size, finish and limitations.

- .3 Shop Drawings:
 - .1 Submit shop drawings for:
 - .1 Bases, hangers and supports.
 - .2 Connections to equipment and structure.
 - .3 Structural assemblies.
- .4 Certificates:
 - .1 Submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Manufacturers' Instructions:
 - .1 Provide manufacturer's installation instructions.
 - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.

1.4 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .2 Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding, and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 SYSTEM DESCRIPTION

- .1 Design Requirements:
 - .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.
 - .2 Base maximum load ratings on allowable stresses prescribed by ASME B31.1 or MSS SP 58.
 - .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure.
 - .4 Design hangers and supports to support systems under conditions of

operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment.

.5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment in accordance with MSS SP 58.

.2 Performance Requirements:

.1 Design supports, platforms, catwalks, hangers to withstand seismic events as specified.

2.2 GENERAL

.1 Fabricate hangers, supports and sway braces in accordance with MSS SP 58. ANSI B31.1

.2 Use components for intended design purpose only. Do not use for rigging or erection purposes.

2.3 PIPE HANGERS

.1 Upper attachment to concrete:

.1 Ceiling: 316 stainless steel welded eye rod, clevis plate, clevis pin and cotters with weldless forged steel eye nut. Ensure eye 6 mm minimum greater than rod diameter.

.2 Concrete inserts: wedge shaped body with knockout protector plate UL listed FM approved to MSS SP 69.

.2 Hanger rods: threaded rod material to MSS SP 58:

.1 Ensure that hanger rods are subject to tensile loading only.

.2 Provide linkages where lateral or axial movement of pipework is anticipated.

.3 Do not use 22 mm or 28 mm rod.

.3 Pipe attachments: material to MSS SP 58:

.1 Attachments for steel piping: 316 stainless steel.

.2 Use insulation shields for hot pipework.

.3 Oversize pipe hangers and supports.

.4 Adjustable clevis: material to MSS SP 69 UL listed FM approved, clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.

.1 Ensure "U" has hole in bottom for rivetting to insulation shields.

.5 Yoke style pipe roll: 316 stainless steel yoke, rod and nuts with roll, to MSS SP 69.

.6 U-bolts: 316 stainless steel to MSS SP 69 with 2 nuts at each end to ASTM A 563.

- .7 Pipe rollers: 316 stainless steel roll and roll stand with rod to MSS SP 69.

2.4 RISER CLAMPS

- .1 316 stainless steel pipe: 316 stainless steel to MSS SP 58, type 42, UL listed FM approved.
- .2 Bolts: to ASTM A 307.
- .3 Nuts: to ASTM A 563.

2.5 INSULATION PROTECTION SHIELDS

- .1 Insulated cold piping:
 - .1 64 kg/m³ density insulation plus insulation protection shield to: MSS SP 69, 316 stainless steel. Length designed for maximum 3 m span.
- .2 Insulated hot piping:
 - .1 Curved plate 300 mm long, with edges turned up, welded-in centre plate for pipe sizes NPS 12 and over, 316 stainless steel to comply with MSS SP 69.

PART 3 - EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install in accordance with:
 - .1 Manufacturer's instructions and recommendations.
- .2 Clamps on riser piping:
 - .1 Support independent of connected horizontal pipework using riser clamps and riser clamp lugs welded to riser.
 - .2 Bolt-tightening torques to industry standards.
- .3 Clevis plates:
 - .1 Attach to concrete with 4 minimum concrete inserts, one at each corner.

- .4 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.
- .5 Use approved constant support type hangers where:
 - .1 Vertical movement of pipework is 13 mm or more,
 - .2 Transfer of load to adjacent hangers or connected equipment is not permitted.
- .6 Use variable support spring hangers where:
 - .1 Transfer of load to adjacent piping or to connected equipment is not critical.
 - .2 Variation in supporting effect does not exceed 25 % of total load.

3.3 HANGER SPACING

- .1 Plumbing piping: to Canadian Plumbing Code Provincial Code authority having jurisdiction.
- .2 Fire protection: to applicable fire code.
- .3 Flexible joint roll groove pipe: in accordance with table below for stainless steel, but not less than one hanger at joints. Table listings for straight runs without concentrated loads and where full linear movement is not required.
- .4 Within 300 mm of each elbow, maximum spacing of stainless steel supports to be 4.9 m.
- .5 Pipework greater than NPS 12: to MSS SP 69.

3.4 HANGER INSTALLATION

- .1 Install hanger so that rod is vertical under operating conditions.
- .2 Adjust hangers to equalize load.
- .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural stainless steel members.

3.5 HORIZONTAL MOVEMENT

- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4 degrees from vertical.
- .2 Where horizontal pipe movement is less than 13 mm, offset pipe hanger and

support so that rod hanger is vertical in the hot position.

3.6 FINAL ADJUSTMENT

- .1 Adjust hangers and supports:
 - .1 Ensure that rod is vertical under operating conditions.
 - .2 Equalize loads.
- .2 Adjustable clevis:
 - .1 Tighten hanger load nut securely to ensure proper hanger performance.
 - .2 Tighten upper nut after adjustment.
- .3 C-clamps:
 - .1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.
- .4 Beam clamps:
 - .1 Hammer jaw firmly against underside of beam.

3.7 FIELD QUALITY CONTROL

- .1 Site Tests: conduct following tests in accordance with Section 01 45 00 - Quality Control and submit report as described in PART 1 - ACTION AND INFORMATIONAL SUBMITTALS.

3.8 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.