




CT01

CW12_R


CW05




CT04

- | | | |
|----|-------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------|
| | 1 CONCRETE | |
| .1 | LEVEL ALIGNMENT - TOP OF SLAB FROM SPECIFIED PLANE AT ANY POINT
SLAB ON GRADE:
SLAB ON FALSEWORK | +20mm
±12mm |
| .2 | VERTICAL ALIGNMENT
GENERAL LOCATION OF LINES, SURFACES, ARISES:
SLOPE OF LINES, SURFACES, ARISES:
EXTERIOR FACE OF COLUMNS
EDGE OF FLOORS | +25mm
3mm IN 1000mm
REFER TO [G/S0.03]
REFER TO [H/S0.03] |
| .3 | SLAB THICKNESS, BEAM DEPTH
THICKNESS LESS THAN 300mm:
THICKNESS GREATER THAN 300mm: | ± 8mm
±12mm |
| .4 | EMBEDDED PLATE LOCATION:
VERTICAL AND HORIZONTAL LOCATION:
SLOPE OF SURFACE: | ±20mm
±1mm IN 50mm
(MAXIMUM 6mm) |
| .5 | OTHER TOLERANCES AS CAN/CSA A23.1-00 AND CAN/CSA S16-01. | |
| | 2 STEEL | |
| .1 | EDGE OF STEEL WALL SUPPORTS - REFER TO H/S0.03. | |
| .2 | MASONRY LINTELS:
VERTICAL AND HORIZONTAL LOCATION: | ±12mm |
| .3 | OTHER TOLERANCES IN ACCORDANCE WITH CAN/CSA-S16-01 AND AS NOTED IN SPECIFICATION FOR ARCHITECTURALLY EXPOSED STEEL. | |


CW16




CW19



CW15




CW10



NOTES:

1. CAST CONCRETE IN SHRINKAGE STRIP NOT SOONER THAN 56 DAYS AFTER ADJOINING PORTIONS OF WALLS HAVE BEEN CONSTRUCTED.
2. HOOK HORIZONTAL REINFORCEMENT IN SHRINKAGE STRIP IF STRIP WIDTH IS NOT SUFFICIENT FOR TENSION LAP SPLICE OF HORIZONTAL REINFORCEMENT PER TABLE ON S.01.

CF32



DIALOG™


stamp



01	ISSUED FOR BID	2013/10/04
----	----------------	------------

revision	date
----------	------

Do not scale drawings
Verify all dimensions and conditions on site and
immediately notify the Departmental Representative of all
discrepancies

	A	detail no. no. du détail
	B	drawing no. - where detail required dessin no. - où détail exigé
	C	drawing no. - where detailed dessin no. - où détaillé

project title	
titre du projet	

GRAND VALLEY INSTITUTION FOR WOMEN
1575 HOMER WATSON BLVD.
KITCHENER, ONTARIO, N2P2C5

PRINCIPAL ENTRANCE BUILDING

drawing title
titre du dessin

TYPICAL DETAILS

drawn by
dessine par

KAZ

designed by
conc par

NM

NM

approved by
approuvé par DK

DK

bid	
offre	RP

RP

project date
date du projet 10/24/2012

project no. DIALOG NO. 09487T.02
no. du projet R.047995.001

drawing no.
dessine no. 01 05

S1.07