




01	ISSUED FOR BID	2013/10/04
revision	description	date

Do not scale drawings  
Verify all dimensions and conditions on site and  
immediately notify the Departmental Representative of all  
discrepancies

	<b>A</b>	detail no. no. du détail
	<b>B</b>	drawing no. - where detail required dessin no. - où détail exigé
	<b>C</b>	drawing no. - where detailed dessin no. - où détaillé

project title  
titre du projet

GRAND VALLEY INSTITUTION FOR WOMEN  
1575 HOMER WATSON BLVD.  
KITCHENER, ONTARIO, N2P 2C5

## PRINCIPAL ENTRANCE BUILDING

drawing title  
titre du dessin

GROUND FLOOR  
HVAC UPGRADE  
PLAN-B

drawn by  
dessine par

designed by  
conc par

approved by  
approuve par

bid		project manager
offre	RP	administrateur de projets

project date  
date du projet 2013-04-19

project no. no. du projet	DIALOG NO. 09487T.02 R.047995.001
------------------------------	--------------------------------------

drawing no.  
dessine no.

**M1.09**



- 1 MECHANICAL CONTRACTOR TO RE-BALANCE EXHAUST SYSTEM FOR EF-1 TO AIR FLOW INDICATED. EF-1 LOCATED IN PENT HOUSE A2.01.
- 2 INCREASE VAV BOX OUTPUT TO LISTED VALVE.
- 3 REPLACE DIFFUSERS IN CEILING ONCE WORK ABOVE IS COMPLETE AND CEILING RESTORED.

1. THIS DRAWING INDICATES GENERAL INTENT OF DESIGN ONLY. CONTRACTOR TO VERIFY EXISTING SITE CONDITION, PRIOR TO ORDERING MATERIALS AND COMMENCING WORK. REPORT TO DEPARTMENTAL REPRESENTATIVE ANY DISCREPANCIES BETWEEN EXISTING AND DESIGN DRAWINGS.
2. PROVIDE NEW EQUIPMENT, INCLUDING FITTINGS AND ACCESSORIES AS INDICATED.
3. UPON COMPLETION OF HVAC AND CONTROLS, THE CONTRACTOR SHALL BALANCE EXHAUST FANS, DAMPERS AND DIFFUSERS FOR SPECIFIED FLOW ON NEW AND RELOCATED DIFFUSERS.