



# DIALOG™

stamp



|          |                |            |
|----------|----------------|------------|
| 01       | ISSUED FOR BID | 2013/10/04 |
| revision | description    | date       |

Do not scale drawings  
Verify all dimensions and conditions on site and  
immediately notify the Departmental Representative of all  
discrepancies

|   |          |   |
|---|----------|---|
|  | <b>A</b> | detail no.<br>no. du détail   |
|   | <b>B</b> | drawing no. - where detail required<br>dessin no. - où détail exigé |
|   | <b>C</b> | drawing no. - where detailed<br>dessin no. - où détaillé            |

|                 |  |
|-----------------|--|
| project title   |  |
| titre du projet |  |

GRAND VALLEY INSTITUTION FOR WOMEN  
1575 HOMER WATSON BLVD.  
KITCHENER, ONTARIO, N2P 2C5

PRINCIPAL ENTRANCE BUILDING

drawing title  
titre du dessin

GROUND FLOOR PLAN  
BUILDING-A

|                         |    |
|-------------------------|----|
| drawn by<br>dessine par | GR |
|-------------------------|----|

|                         |     |
|-------------------------|-----|
| designed by<br>conc par | JDB |
|-------------------------|-----|

|                             |    |
|-----------------------------|----|
| approved by<br>approuvé par | RD |
|-----------------------------|----|

|       |    |                              |
|-------|----|------------------------------|
| bid   |    | project manager              |
| offre | RP | administrateur<br>de projets |

|                                |            |
|--------------------------------|------------|
| project date<br>date du projet | 2013-04-19 |
|--------------------------------|------------|

|                              |                                      |
|------------------------------|--------------------------------------|
| project no.<br>no. du projet | DIALOG NO. 09487T.02<br>R.047995.001 |
|------------------------------|--------------------------------------|

drawing no.  
dessine no. **M7.01**

## GENERAL NOTES


1. CONTRACTOR TO REFER TO PHASING PLAN AND SPECIFICATIONS FOR WORK PHASING. BUILDING TO REMAIN FULLY OPERATIONAL DURING CONTROLS UPGRADE.
2. DRAWINGS INDICATE LOCATION OF BAS CONTROLLED EQUIPMENT AND DEVICES THAT REQUIRE REPLACEMENT OR EXISTING TO BE REUSED. CONTRACTS CONTRACTOR TO REFER TO POINT LIST WITHIN SPECIFICATIONS FOR NUMBER OF POINTS REQUIRED FOR REPROGRAMMING.
3. COORDINATE ACCESS TO EQUIPMENT WITH DEPARTMENTAL REPRESENTATIVE.
4. CONTRACTOR TO CLEAN AND CALIBRATE ALL VAV AIR FLOW STATIONS WHEN REPLACING CONTROLLER.
5. EQUIPMENT TAGS THAT APPEAR IN BRACKETS ( ) ARE THE ORIGINAL EQUIPMENT TAG. CONTRACTOR TO RE-LABEL THE EXISTING EQUIPMENT AND PROGRAM THE BAS WITH THE NEW EQUIPMENT LABEL. REFER TO SPECIFICATIONS FOR ADDITIONAL DETAILS.
6. CONTRACTOR TO ALLOW FOR AND PERFORM CUTTING AND PATCHING WHERE REQUIRED TO FACILITATE NEW CONTROL INSTALLATION.

## KEY NOTES

- 1 MOTORIZED DAMPERS INTERLOCKED WITH EXHAUST FAN OPERATION.

### CONTROL SCOPE LEGEND

E = EXISTING DEVICE TO REMAIN  
R = REPLACE EXISTING DEVICE WITH NEW  
N = NEW DEVICE TO BE INSTALLED AND PROGRAMMED



FOR CONTINUATION REFER TO DETAIL-1/DWG. M7.02

1 GROUND FLOOR PLAN BUILDING - A  
M7.01 SCALE: 1:100