




34826-200-C2.30
DETAILS PLAN
P:\P\34826\200\34826-200-C2.DWG





HD AND LD ASPHALT AREAS
1:750



AREAS REQUIRING FULL EXCAVATION
1:750






PAVEMENT STRUCTURE (PER GEOTECHNICAL INVESTIGATION PREPARED BY CRA, DATED SEPT 2010)		
PAVEMENT LAYER	LIGHT DUTY (NEW VISITOR PARKING ONLY)	HEAVY DUTY (TRUCK TRAFFIC AREAS/ FIRE ROUTE)
HL3 (OPSS 1150)	40mm	40mm
HL4 or HL8 (OPSS 1150)	50mm	60mm
GRANULAR 'A' (OPSS 1010)	150mm	150mm
GRANULAR 'B' (OPSS 1010)	250mm	400mm



TYPICAL NEW WATERMAIN CONNECTION DETAIL
N.T.S.

NOTE: WATERMAIN TO BE INSTALLED PER OPSS 441 AND 442 ALONG WITH SECTIONS C.2 AND D.2 OF THE REGION OF WATERLOO AND AREA DESIGN GUIDELINES AND SUPPLEMENTAL SPECIFICATIONS FOR MUNICIPAL SERVICES (DGSSMS), FEBRUARY 2013




MAINTENANCE SCHEDULE
-INSPECT AFTER EVERY MAJOR RAIN EVENT.
-INSPECT EVERY 3 WEEKS MINIMUM.
-SILTSACK SHOULD NEVER BE OVER HALF FULL.
-FULL BAG CAN BE REMOVED, DUMPED, CLEANED AND REUSED
(TO REMOVE INSERT 25mm REBAR INTO REMOVAL FLAP POCKETS)
(TO DUMP INSERT 25mm REBAR INTO BOTH DUMPING STRAPS)

TEMPORARY SILTSACK SILTATION CONTROL IN CURB
N.T.S.

Public Works and
Government Services Canada
Travaux publics et
Services gouvernementaux Canada

DIALOG™

stamp



Site Development Division
MTE Project # 34826-200
Ph. (519)743-6500

NOTE TO CONTRACTOR :

DO NOT SCALE DRAWINGS.

CONTRACTORS MUST CHECK AND VERIFY ALL DIMENSIONS AND REPORT ANY DISCREPANCIES TO THE DEPARTMENTAL REPRESENTATIVE BEFORE PROCEEDING WITH THE WORK.

ALL DRAWINGS REMAIN THE PROPERTY OF THE DEPARTMENTAL REPRESENTATIVE AND SHALL NOT BE REPRODUCED OR REUSED WITHOUT THE DEPARTMENTAL REPRESENTATIVE'S WRITTEN PERMISSION.

SCALE: 1:300

revision	description	date
01	ISSUED FOR BID	2013/10/04

Do not scale drawings
Verify all dimensions and conditions on site and immediately notify the Departmental Representative of all discrepancies

A	detail no. - no. du détail
B	drawing no. - where detail required dessin no. - où détail exigé
C	drawing no. - where detailed dessin no. - où détaillé

project title
titre du projet
GRAND VALLEY INSTITUTION FOR WOMEN
1575 HOMER WATSON BLVD.
KITCHENER, ONTARIO, N2P 2C5

PRINCIPAL ENTRANCE BUILDING

drawing title
titre du dessin
DETAILS PLAN

drawn by
dessiné par
JAK

designed by
conçu par
JXM

approved by
approuvé par
FJR

bid
offre
RP

project manager
administrateur
de projets

project date
date du projet
2012-11-06

project no.
no. du projet
DIALOG NO. 09487T.02
R.047995.001

drawing no.
dessiné no.
C2.30