

# DIALOG™

Do not scale drawings  
Verify all dimensions and conditions on site and  
immediately notify the Departmental Representative of all  
discrepancies

project title  
titre du projet

**GRAND VALLEY INSTITUTION FOR WOMEN  
1575 HOMER WATSON BLVD.  
KITCHENER, ONTARIO, N2P2C5**

drawing title  
titre du dessin

## GROUND FLOOR FIRE PROTECTION PLAN-PEB

drawn by  
dessine par

designed by  
conc par

JDB

approved by  
approuvé par RD

bid	
offre	RP

project date	
date du projet	2013-04-19

project no. DIALOG NO. 09487T.02  
no. du projet R.047995.001

drawing no.  
dessine no.

## M2.05



1 GROUND FLOOR FIRE PROTECTION PLAN-PEB  
M2.05 1 : 100

## GENERAL NOTES

1. FIRE PROTECTION SERVICE TO EXTEND FROM EXISTING BUILDING. FIRE PROTECTION CONTRACTOR TO COORDINATE SERVICE DISRUPTION WITH INSTITUTION.
2. REFER TO DRAWING M4.01 FOR FIRE PROTECTION ZONING, SUPERVISED VALVES AND FLOW SWITCH LOCATIONS.

## KEY NOTES

- 1 PROVIDE CLOSE SPACE SPRINKLERS AROUND OPENING SPACE AS REQUIRED BY NFPA 13. COORDINATE SPRINKLER HEAD WITH SMOKE BAFFLES, REFER TO ARCHITECTURAL PLANS.
- 2 SPRINKLER WITHIN ELEVATOR MACHINE ROOM TO BE INTERMEDIATE TEMPERATURE RATING.
- 3 PROVIDE SIDEWALL SPRINKLER AT BASE OF ELEVATOR SHAFT.
- 4 PROVIDE WINDOW SPRINKLER WITH ST01 AND P101 TO ACHIEVE REQUIRED FIRE RATING. REFER TO ARCHITECTURE FOR WALL RATING REQUIRED, ALLOW FOR TWO ROWS TO ACCOMMODATE HORIZONTAL MULLION.