

LUMINAIRE SCHEDULE					
TYPE	DESCRIPTION	MANUFACTURER	VOLTAGE	LAMPS	REMARKS
A1	610 mm X 610 mm, RECESSED DIRECT-INDIRECT FLUORESCENT HIGH EFFICIENCY ARCHITECTURAL FIXTURE, PROGRAMMED START ELECTRONIC BALLAST, MICRO PRISMATIC ACRYLIC LENS, LOW PROFILE 3-3/4" DEEP HOUSING.	COOPER CORELITE R3 MARK LIGHTING POR LEDALITE SHINE APPROVED EQUAL	347V	3-24W T5HO 3500K	LUMINAIRES INSTALLED IN T-BAR AND DRYWALL CEILING. PROVIDE DRYWALL MOUNTING KIT AS NECESSARY.
A2	RECESSED LINEAR 4FT. FLUORESCENT SLOT LUMINAIRE WITH SATIN WHITE LENS. NOMINAL DIMENSION OF 4" W X 5-1/16"D	NEORAY 23D-S-2-T5-4-S93 MARK LIGHTING SL4R-4 AXIS LIGHTING BEAM 3 APPROVED EQUAL	347V	2-28W T5 3500K	WOOD SLAT CEILING MOUNTING KIT AS NECESSARY.
A2a	RECESSED LINEAR 2FT. FLUORESCENT SLOT LUMINAIRE WITH SATIN WHITE LENS. NOMINAL DIMENSION OF 4" W X 5-1/16"D	NEORAY 23D-S-2-T5-2-S93 MARK LIGHTING SL4-2 AXIS LIGHTING BEAM 3 APPROVED EQUAL	347V	2-14W T5 3500K	WOOD SLAT CEILING MOUNTING KIT AS NECESSARY.
A2b	RECESSED LINEAR 3FT. FLUORESCENT SLOT LUMINAIRE WITH SATIN WHITE LENS. NOMINAL DIMENSION OF 4" W X 5-1/16"D	NEORAY 23D-S-2-T5-3-S93 MARK LIGHTING SL4-3 AXIS LIGHTING BEAM 3 APPROVED EQUAL	347V	2-T5 3500K	WOOD SLAT CEILING MOUNTING KIT AS NECESSARY. PROVIDE APPROPRIATE STAGGERED LAMPING AS REQUIRED FOR CONTINUOUS LENGTHS
A3	VANDAL RESISTANT RECESSED 2X2 TROFFER.	COOPER FAILSAFE FMRX MARK LIGHTING GP4-MX-R CANLYTE CFI APPROVED EQUAL	347V	2-24W T5HO 3500K	
A4	SURFACE MOUNTED 4FT. FLUORESCENT STRIP LUMINAIRE WITH REFLECTOR	METALUX SNF-228-T5-347 LITHONIA Z2 CFI SV4 APPROVED EQUAL	347V	2-28W T5 3500K	
A5	SUSPENDED 4FT. FLUORESCENT STRIP LUMINAIRE WITH REFLECTOR	METALUX SNF-228-T5-347 LITHONIA Z2 CFI SV4 APPROVED EQUAL	347V	2-28W T5 3500K	
A6	SIDE-MOUNTED FLUORESCENT STRIP LUMINAIRE FOR UNDERCABINET LIGHTING. NOMINAL DIMENSIONS OF 3-7/8"W X 1-11/16" H	METALUX SNSM-128T5-347V-SL-NC235T5ROHS-U LITHONIA SM-128T5-347 CFI SM APPROVED EQUAL	347V	1-28W T5 3500K	
A7	610 mm X 610 mm, RECESSED 2X2 TROFFER WITH ACRYLIC LENS	COOPER METALUX ACUTY CANLYTE APPROVED EQUAL	347V	3-24W T5HO 3500K	
A8	SUSPENDED LOW-PROFILE LOUVERED STRIPLIGHT	COOPER METALUX ACUTY CANLYTE APPROVED EQUAL	347V	2-28W T5 3500K	SUITABLE FOR CONTINUOUS ROW INSTALLATION
B1	RECESSED 6" LED DOWNLIGHT WITH SELF FLANGED REFLECTOR AND SEMI-SPECULAR FINISH.	COOPER PORTFOLIO LD615 GOTHAM EVO CALCULITE LOL APPROVED EQUAL	120V	LED 1500 LUMEN 3500K	
B2	RECESSED 6" LED DOWNLIGHT WITH SELF FLANGED REFLECTOR AND SEMI-SPECULAR FINISH.	COOPER PORTFOLIO LD6-20-D010-ERM6-835-6LM1-H GOTHAM EVO CALCULITE LOL APPROVED EQUAL	120V	LED 2000 LUMEN 3500K	
B2a	RECESSED 6" LED DOWNLIGHT WITH SELF FLANGED REFLECTOR AND SEMI-SPECULAR FINISH C/W GASKET KIT IP66 SUITABLE FOR EXTERIOR INSTALLATION	COOPER PORTFOLIO LD6-10-D010-ERM6-835-6LM1-H GOTHAM EVO CALCULITE LOL APPROVED EQUAL	120V	LED 1000 LUMEN 3500K	TO BE MOUNTED IN METAL CEILING
B3	RECESSED 6" CFL HORIZONTAL DOWNLIGHT WITH SELF FLANGED REFLECTOR AND SEMI-SPECULAR FINISH.	PORTFOLIO GOTHAM EVO CALCULITE APPROVED EQUAL	347V	CFL 1-32W 3500K	
B4	RECESSED 6" CFL VANDAL RESISTANT SHOWER DOWNLIGHT. WET LOCATION RATED.	COOPER PORTFOLIO CD6142E-6CH1420H-DT6L ACUTY CANLYTE APPROVED EQUAL	347V	CFL 1-32W 3500K	
B5	RECESSED 8" LED DOWNLIGHT WITH SELF FLANGED REFLECTOR AND SEMI-SPECULAR FINISH.	COOPER PORTFOLIO LD69 GOTHAM EVO JUNO INDY APPROVED EQUAL	120V	LED 3000 LUMEN 3500K	
B6	LED HANDRAIL LIGHT WITH ASYMMETRIC DISTRIBUTION. 48.3MM DIAMETER ANODIZED ALUMINUM CONSTRUCTION.	COOPER LUXRAIL 06-CAA-2-WM-GL-ASYM-3KHO-XX-120-200 WATT DRIVER INTENSE LIGHTING VRAIL CANLYTE APPROVED EQUAL	120V	LED HIGH OUTPUT 3500K	SEE ARCHITECTURAL DRAWING ELEVATION AND SECTIONS. HANDRAIL LENGTHS TO BE CONFIRMED.
D1	SURFACE MOUNTED 4FT. FLUORESCENT LUMINAIRE WITH WHITE OPAL LENS. NOMINAL DIMENSIONS OF 4-1/4"W X 4-1/4" H	COOPER METALUX BC LITHONIA WC CANLYTE CFI CS APPROVED EQUAL	347V	2-28W T5 3500K	
D2	SURFACE MOUNTED 3FT. LENGTH VANITY LIGHT WITH OPAL LENS.	EUREKA LIGHTING MOONRISE CLASSIC 3520 OCL LIGHTING EL-1-S1SA-36-MW-PTD-1LF21-120 AXIS LIGHTING AIR WALL APPROVED EQUAL	347V	T5 3500K	REFER TO ARCHITECTURAL DWGS. FOR APPROPRIATE LENGTH
D3	NOT USED				
P	ELEVATOR PIT LIGHT	COOPER LIGHTING LUMARK VS VAPORTIGHT SERIES CANLET 08-02-F-C-F-43-09-09 CANLYTE STONCO VAPORTIGHT SERIES APPROVED EQUAL	347V	1-42 WATT CFL 3500K	CLEAR GLASS JAR WITH GLOBE
W1	WALL MOUNTED LED LUMINAIRE WITH DIRECT ASYMMETRICAL LIGHT DISTRIBUTION. NOMINAL DIMENSIONS OF 10-1/4"W X 8-1/2"H C/W INTEGRAL PHOTOCELL	COOPER INVUE ENTRI ENV-B01-LED-120-BL4-XX LITHONIA WSR GARDCO APPROVED EQUAL	120V	27 W LED 4000K	

DIALOG™

stamp



01	ISSUED FOR BID	2013/10/04
revision	description	date

Do not scale drawings
Verify all dimensions and conditions on site and
Immediately notify the Departmental Representative of all
discrepancies

A

B

C

A

B

C

detail no.
no. du détail

drawing no. - where detail required
dessain no. - où détail exigé

drawing no. - where detailed
dessain no. - où détaillé

project title
titre du projet

GRAND VALLEY INSTITUTION FOR WOMEN
1575 HOMER WATSON BLVD.
KITCHENER, ONTARIO, N2P 2C5

PRINCIPAL ENTRANCE BUILDING

drawing title
titre du dessin

LUMINAIRE SHEDULE

drawn by
dessiné par

OS

designed by
conc par

OS

approved by
approuve par

NA

bid
offre

RP

project manager
administrateur
de projets

project date
date du projet

2012-11-06

project no.
no. du projet

DIALOG NO. 09487T.02
R.047995.001

drawing no.
dessiné no.

E5.01