




01	<b>ISSUED FOR BID</b>	2013/10/04
revision		date

Do not scale drawings  
Verify all dimensions and conditions on site and  
Immediately notify the Departmental Representative of all  
discrepancies

	<b>A</b>	detail no. no. du détail
	<b>B</b>	drawing no. - where detail required dessin no. - où détail exigé
	<b>C</b>	drawing no. - where detailed dessin no. - où détaillé

Project title  
Titre du projet

**BRAND VALLEY INSTITUTION FOR WOMEN  
575 HOMER WATSON BLVD.  
ITCHENER, ONTARIO, N2P2C5**

## PRINCIPAL ENTRANCE BUILDING

awing title  
re du dessin

## GROUND FLOOR PLUMBING PLAN-PEB

GR

Designed by  
Inc par

JDB

RD

d fre	RP	project manager administrateur de projets
----------	----	---

Project date	
Date du projet	2013-04-19

project no.  
n. du projet

DIALOG NO. 09487T.02  
R.047995.001

Drawing no.  
essine no.

# M2.02



### GENERAL NOTES

1. PROVIDE ALL MATERIALS AND EQUIPMENT AND PERFORM ALL LABOUR AS INDICATED AND AS REQUIRED TO COMPLETE THE WORK
2. UNLESS OTHERWISE NOTED ALL DRAINAGE PIPING 75 AND SMALLER TO BE SLOPED AT 2%. ALL DRAINAGE PIPING 100 AND LARGER TO BE SLOPED AT 1%.
3. CONTRACTOR TO TRAP, PRIME & VENT ALL DRAINS AND FIXTURES AS PER NATIONAL AND LOCAL BUILDING CODES.
4. FIRE STOP ALL PENETRATIONS THROUGH FIRE RATED ASSEMBLIES WITH APPROVED FIRE STOPPING SYSTEM TO MAINTAIN INTEGRITY OF ASSEMBLY.
5. ALL PIPING BRANCHES TO BE COMPLETE WITH ISOLATION VALVES.
6. HOT WATER RECIRC BALANCING VALVES TO BE PRESSURE INDEPENDENT TYPE.
7. MECHANICAL CONTRACTOR TO TERMINATE VENTS AT COORDINATED LOCATIONS INDICATED ON DWGS
8. CONTRACTOR IS TO BE RESPONSIBLE FOR FINAL CONNECTIONS TO ALL OWNER SUPPLIED EQUIPMENT.

## KEY NOTES

- FUNNEL FLOOR DRAIN TO BE PROVIDED WITH MILLWORK. MECHANICAL CONTRACTOR TO COORDINATE INSTALLATION.
- CONTRACTOR TO PROVIDE HEAT TRACING FOR RAIN GUTTER.

MECHANICAL PLUMBING SERVICE REQUIREMENTS					
TAG	DCW (MM)	DHW (MM)	DRAIN (MM)	VENT (MM)	REMARKS
JS	20	20	75	40	
LAV	15	15	40	32	
SK	15	15	40	32	
SH	15	15	-	-	
WC	25	-	100	50	
FD-1	-	-	75	40	
NFHB	20	-	-	-	