


stamp



01 ISSUED FOR BID 2013/10/04

revision description date

Do not scale drawings
Verify all dimensions and conditions on site and
immediately notify the Departmental Representative of all
discrepancies

A detail no.
no. du détail
B drawing no. - where detail required
dessin no. - où détail exigé
C drawing no. - where detailed
dessin no. - où détaillé

project title
titre du projet
GRAND VALLEY INSTITUTION FOR WOMEN
1575 HOMER WATSON BLVD.
KITCHENER, ONTARIO, N2P 2C5

PRINCIPAL ENTRANCE BUILDING

drawing title
titre du dessin
GROUND FLOOR PLAN
BUILDING-SLE

drawn by
dessiné par GR

designed by
conçu par JDB

approved by
approuvé par RD

bid
offre RP project manager
administrateur de projets

project date
date du projet 2013-04-19

project no.
no. du projet DIALOG NO. 09487T.02
R.047995.001

drawing no.
dessiné no. M7.08

GENERAL NOTES


- CONTRACTOR TO REFER TO PHASING PLAN AND SPECIFICATIONS FOR WORK PHASING. BUILDING TO REMAIN FULLY OPERATIONAL DURING CONTROLS UPGRADE.
- DRAWINGS INDICATE LOCATION OF BAS CONTROLLED EQUIPMENT AND DEVICES THAT REQUIRE REPLACEMENT OR EXISTING TO BE REUSED. CONTRACTOR TO REFER TO POINT LIST WITHIN SPECIFICATIONS FOR NUMBER OF POINTS REQUIRED FOR REPROGRAMMING.
- COORDINATE ACCESS TO EQUIPMENT WITH DEPARTMENTAL REPRESENTATIVE.
- EQUIPMENT TAGS THAT APPEAR IN BRACKETS () ARE THE ORIGINAL EQUIPMENT TAG. CONTRACTOR TO RE-LABEL THE EXISTING EQUIPMENT AND PROGRAM THE BAS WITH THE NEW EQUIPMENT LABEL. REFER TO SPECIFICATIONS FOR ADDITIONAL DETAILS.
- CONTRACTOR TO PERFORM CUTTING AND PATCHING WHERE REQUIRED TO FACILITATE NEW CONTROL INSTALLATION.

KEY NOTES

- 1 NEW TEMPERATURE SENSORS WITHIN INMATE AREAS ARE TO BE GLUED TO THE BACK OF A STAINLESS STEEL COVER PLATE. INSTALLATION TO BE SIMILAR TO EXISTING IN ROOM 150.

CONTROL SCOPE LEGEND

- E = EXISTING DEVICE TO REMAIN
R = REPLACE EXISTING DEVICE WITH NEW
N = NEW DEVICE TO BE INSTALLED AND PROGRAMMED



1 GROUND FLOOR PLAN BUILDING - SLE

M7.08 SCALE: 1:100