

FP802-130232 Q&A 1

QUESTION 1

In the attached specifications, it makes reference to a "fire-retardant treatment of lumber by pressure processes" Is this required?

ANSWER TO QUESTION 1

Those are standard references in the spec and it is only referring to the CSA standard, not requiring it.