

1 General

1.1 REFERENCES

- .1 Canadian General Standards Board (CGSB).
 - .1 CAN/CGSB 1.181 99, Ready Mixed Organic Zinc Rich Coating.
- .2 Canadian Standards Association (CSA International).
 - .1 CSA B139-04, Installation Code for Oil Burning Equipment.
- .3 National Fire Code of Canada (NFCC 2005).
- .4 Fabricate Systems in accordance with the following fabrication standards:
 - .1 Flanged, welded steel piping systems:
 - .1 Butt-welded ends: to ANSI/ASME B16.25-1992.
 - .2 Steel pipe flanges: to ANSI/ASME B16.5-1996.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheets for piping and equipment and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 MATERIAL

- .1 Paint: zinc-rich to CAN/CGSB-1.181.
 - .1 Primers, Paints, and Coating: in accordance with manufacturer's recommendations for surface conditions.

3 Execution

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION REQUIREMENTS

- .1 Install chilled water piping systems in accordance with the recommendations of ASHRAE Guide:
- .2 Install piping to allow for expansion and contraction without exceeding maximum allowable stresses for pipe and equipment flanges.
- .3 Provide clearance for proper installation of insulation and for access to valves, air vents, drains and unions.
- .4 Provide all offsets necessary to install piping systems within the physical limitations of the building.

3.3 ROUTES AND GRADES

- .1 Route piping in an orderly manner and maintain proper grades.
- .2 Install piping to conserve headroom and space.
- .3 Route above grade piping parallel to walls.
- .4 Where practicable, group piping at common elevations.
- .5 Slope hydronic system piping at 0.2% and drain at low points.
- .6 On closed loop water systems, equip low points with 20 mm drain valves and hose nipples. At high points, provide collecting chambers and high capacity float operated automatic air vents.
- .7 Make reductions in water piping with eccentric reducing fittings to provide complete drainage and venting.

- .8 Grade horizontal sanitary and storm drainage vent piping at 2% minimum.

3.4 STEEL PIPING SYSTEM – GENERAL

- .1 Use mechanical grooved couplings and fittings in accessible locations only.
- .2 Use only long radius elbows.
- .3 Ream piping and tubing. Clean off scale and dirt inside and outside before assembly. Remove welding slag or other foreign material from piping.
- .4 Protect galvanized pipe threads with pipe paste.

3.5 STEEL PIPING SYSTEM – TEEING OFF MAIN LINE

- .1 Mains 150 mm (NPS 6) and smaller:
 - .1 Use saddle type connections where main is at least one size larger than branch.
 - .2 Use direct connection where branch is at least three sizes smaller than main.
- .2 Mains 200 mm (NPS 8) and larger:
 - .1 Use saddle type connections where main is at least two sizes larger than branch.
 - .2 Use direct connection for branches 65 mm and smaller.
 - .3 Do not project branch pipe inside main line.

3.6 PRESS-FITTING SYSTEM

- .1 Install press-fitting system in accordance with system manufacturer's instructions.

3.7 NON-FERROUS PIPING CONNECTIONS

- .1 Use non-toxic joint compound on potable water lines.
- .2 Provide non-conducting type connections wherever joining dissimilar metals. Brass adaptors and valves are acceptable.
- .3 Sleeve copper piping buried under building so that pipe can move freely; joints are not allowed in piping buried under building.

3.8 COPPER PIPING – MECHANICALLY FORMED CONNECTIONS

- .1 Mechanically formed tee connections with brazed joints may be used in lieu of tee fittings in copper tubing provided they meet the following:
 - .1 Size and wall thickness of main tube and branch tube are listed by manufacture of forming equipment as an acceptable application.
 - .2 Height of drawn collar is not less than three times wall thickness of main tubing.

.3 End of branch tube is notched to conform to inner curve of tube and dimpled to set exact penetration depth into collar.

.4 Resulting joint is brazed and is minimum of three times as long as thickness of thinner joint member.

3.9 UNIONS AND FLANGES

- .1 Make connections to equipment and branch mains with unions or flanges.
- .2 Use 1.5 mm thick preformed synthetic rubber asbestos gaskets for flanged connections for all services except gas.

3.10 CONNECTIONS TO EQUIPMENT

- .1 In accordance with manufacturer's instructions unless otherwise indicated.
- .2 Use valves and either unions or flanges for isolation and ease of maintenance and assembly.
- .3 Use double swing joints when equipment mounted on vibration isolation and when piping subject to movement.

3.11 CLEARANCES

- .1 Provide clearance around systems, equipment and components for observation of operation, inspection, servicing, maintenance and as recommended by manufacturer.
- .2 Provide space for disassembly, removal of equipment and components as recommended by manufacturer or as indicated (whichever is greater) without interrupting operation of other system, equipment and components.

3.12 DRAINS

- .1 Install piping with grade in direction of flow except as indicated.
- .2 Install drain valve at low points in piping systems, at equipment and at section isolating valves.
- .3 Pipe each drain valve discharge separately to above floor drain. Discharge to be visible.
- .4 Drain valves: 20 mm (NPS ¾) gate or globe valves unless indicated otherwise, with hose end male thread, cap and chain.

3.13 AIR VENTS

- .1 Install manual air vents at high points in piping systems.
- .2 Install isolating valve at each automatic air valve.

- .3 Install drain piping to approved location and terminate where discharge is visible.

3.14 DIELECTRIC COUPLINGS

- .1 General: Compatible with system, to suit pressure rating of system.
- .2 Locations: Where dissimilar metals are joined.
- .3 50 mm (NPS 2) and under: isolating unions or bronze valves.
- .4 Over 50 mm (NPS 2): Isolating flanges.

3.15 PIPEWORK INSTALLATION

- .1 Screwed fittings jointed with Teflon tape.
- .2 Protect openings against entry of foreign material.
- .3 Install to isolate equipment and allow removal without interrupting operation of other equipment or systems.
- .4 Assemble piping using fittings manufactured to ANSI standards.
- .5 Saddle type branch fittings may be used on mains if branch line is no larger than half the size of main.
- .6 Hole saw (or drill) and ream main to maintain full inside diameter of branch line prior to welding saddle.
- .7 Install exposed piping, equipment, rectangular cleanouts and similar items parallel or perpendicular to building lines.
- .8 Install concealed pipework to minimize furring space, maximize headroom, and conserve space.
- .9 Slope piping, except where indicated, in direction of flow for positive drainage and venting.
- .10 Install, except where indicated, to permit separate thermal insulation of each pipe.
- .11 Group piping wherever possible and as indicated.
- .12 Ream pipes, remove scale and other foreign material before assembly.
- .13 Use eccentric reducers at pipe size changes to ensure positive drainage and venting.
- .14 Provide for thermal expansion as indicated.
- .15 Valves:

- .1 Install in accessible locations.
- .2 Remove interior parts before soldering.
- .3 Install with stems above horizontal position unless otherwise indicated.
- .4 Valves accessible for maintenance without removing adjacent piping.
- .5 Install globe valves in bypass around control valves.
- .6 Use ball valves at branch take-offs for isolating purposes except where otherwise specified.
- .7 Install butterfly valves on chilled water and related condenser water systems only.
- .8 Install butterfly valves between weld neck flanges to ensure full compression of liner.
- .9 Use chain operators on valves 65 mm (NPS 2-1/2) and larger where installed more than 2400 mm above floor in Mechanical Rooms.
- .16 Check Valves:
 - .1 Install silent check valves on discharge of pumps and in vertical pipes with downward flow and elsewhere as indicated.
 - .2 Install swing check valves in horizontal lines on discharge of pumps and elsewhere as indicated.

3.16 SLEEVES

- .1 General: Install where pipes pass through masonry, concrete structures, fire rated assemblies, and elsewhere as indicated.
- .2 Material: Schedule 40 black steel pipe.
- .3 Construction: Foundation walls and where sleeves extend above finished floors to have annular fins continuously welded on at mid-point.
- .4 Sizes: 6 mm minimum clearance between sleeve and uninsulated pipe or between sleeve and insulation.
- .5 Installation:
 - .1 Concrete, masonry walls, concrete floors on grade: Terminate flush with finished surface.
 - .2 Other floors: Terminate 25 mm above finished floor.
 - .3 Before installation, paint exposed exterior surfaces with heavy application of zinc-rich paint to CAN/CGSB-1.181.
- .6 Sealing:
 - .1 Foundation walls and below grade floors: Fire retardant, waterproof non-hardening mastic.

- .2 Elsewhere: Provide space for firestopping. Maintain fire rating integrity.
- .3 Sleeves installed for future use: Fill with lime plaster or other easily removable filler.
- .4 Ensure no contact between copper pipe or tube and sleeve.

3.17 ESCUTCHEONS

- .1 Install on pipes passing through walls, partitions, floors, and ceilings in finished areas.
- .2 Construction: One piece type with set screws. Chrome or nickel plated brass or type 302 stainless steel.
- .3 Sizes: Outside diameter to cover opening or sleeve. Inside diameter to fit around pipe or outside of insulation if so provided.

3.18 PREPARATION FOR FIRESTOPPING

- .1 Material and installation within annular space between pipes, ducts, insulation and adjacent fire separation.
- .2 Uninsulated unheated pipes not subject to movement: No special preparation.
- .3 Uninsulated heated pipes subject to movement: Wrap with non-combustible smooth material to permit pipe movement without damaging firestopping material or installation.
- .4 Insulated pipes and ducts: Ensure integrity of insulation and vapour barriers.

3.19 FLUSHING OUT OF PIPING SYSTEMS

- .1 Before start up, clean interior of new piping systems in accordance with Section 23 08 02 -Cleaning and Start-up of Mechanical Piping Systems.
- .2 Preparatory to acceptance, clean and refurbish equipment and leave in operating condition, including replacement of filters in piping systems.

3.20 PRESSURE TESTING EQUIPMENT AND PIPEWORK

- .1 Advise Departmental Representative prior to performance of pressure tests.
- .2 Attempt to conduct tests in presence of Departmental Representative, during next scheduled trip to site.
- .3 Pework: Test as specified in relevant sections of Mechanical Division.
- .4 Maintain specified test pressure without loss for 4 hours minimum unless specified for longer period of time in relevant sections of Mechanical Division.

- .5 Prior to tests, isolate equipment and other parts which are not designed to withstand test pressure or media.
- .6 Pay costs for repairs or replacement, retesting, and making good. Departmental Representative shall determine whether repair or replacement is appropriate.
- .7 Insulate or conceal work only after approval and certification of tests. Submit a copy of certified test to Departmental Representative for review.

3.21 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 General

1.1 REFERENCES

- .1 American National Standards Institute/American Society of Mechanical Engineers (ANSI/ASME).
 - .1 ANSI/ASME Boiler and Pressure Vessel Code-2007:
 - .1 BPVC 2007 Section V: Nondestructive Examination.
 - .2 BPVC 2007 Section IX: Welding and Brazing Qualifications.
 - .2 American National Standards Institute/American Water Works Association (ANSI/AWWA).
 - .1 ANSI/AWWA C206-03, Field Welding of Steel Water Pipe.
 - .3 American Welding Society (AWS).
 - .1 AWS C1.1M/C1.1-2000(R2006), Recommended Practices for Resistance Welding.
 - .2 AWS Z49.1-2005, Safety in Welding, Cutting and Allied Process.
 - .3 AWS W1-2000, Welding Inspection Handbook.
 - .4 Canadian Standards Association (CSA International).
 - .1 CSA W48-06, Filler Metals and Allied Materials for Metal Arc Welding.
 - .2 CSA B51-03(R2007), Boiler, Pressure Vessel and Pressure Piping Code.
 - .3 CSA-W117.2-2006, Safety in Welding, Cutting and Allied Processes.
 - .4 CSA W178.1-2008, Certification of Welding Inspection Organizations.
 - .5 CSA W178.2-2008, Certification of Welding Inspectors.
 - .5 The Statutes of Saskatchewan.
 - .1 B-51 The Boiler and Pressure Vessel Act, 1999, as amended by the statutes of Saskatchewan, 2006, c.3; and 2010, c.T-9.2.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

1.3 QUALITY ASSURANCE

- .1 Qualifications:
 - .1 Welders:
 - .1 Welding qualifications in accordance with CSA B51 and the statutes of Saskatchewan B-5.1.

- .2 Use qualified and licensed welders possessing certificate for each procedure performed from authority having jurisdiction.
- .3 Submit welder's qualifications to Departmental Representative.
- .4 Each welder to possess identification symbol issued by authority having jurisdiction.
- .5 Certification of companies for fusion welding of aluminum in accordance with CSA W47.2.
- .2 Inspectors:
 - .1 Inspectors qualified to CSA W178.2.
- .3 Certifications:
 - .1 Registration of welding procedures in accordance with CSA B51.
 - .2 Copy of welding procedures available for inspection.
 - .3 Safety in welding, cutting and allied processes in accordance with CSA-W117.2.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.

2 Products

2.1 ELECTRODES

- .1 Electrodes: in accordance with CSA W48 Series.

3 Execution

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 QUALITY OF WORK

- .1 Welding: in accordance with ANSI/ASME Boiler and Pressure Vessel Code, Sections I and IX and ANSI/AWWA C206, using procedures conforming to AWS B3.0, AWS C1.1, and applicable requirements of provincial authority having jurisdiction.

3.3 INSTALLATION REQUIREMENTS

- .1 Identify each weld with welder's identification symbol.
- .2 Backing rings:
 - .1 Where used, fit to minimize gaps between ring and pipe bore.
 - .2 Do not install at orifice flanges.
- .3 Fittings:
 - .1 NPS 2 and smaller: install welding type sockets.
 - .2 Branch connections: install welding tees or forged branch outlet fittings.

3.4 INSPECTION AND TESTS – GENERAL REQUIREMENTS

- .1 Review weld quality requirements and defect limits of applicable codes and standards with Departmental Representative before work is started.
- .2 Formulate "Inspection and Test Plan" in co-operation with Departmental Representative.
- .3 Do not conceal welds until they have been inspected, tested and approved by inspector.
- .4 Provide for inspector to visually inspect welds during early stages of welding procedures in accordance with Welding Inspection Handbook. Repair or replace defects as required by codes and as specified.

3.5 SPECIALIST EXAMINATIONS AND TESTS

- .1 General:
 - .1 Perform examinations and tests by specialist qualified to CSA W178.1 and CSA W178.2 and approved by Engineer.
 - .2 To ANSI/ASME Boiler and Pressure Vessels Code, Section V, CSA B51 and requirements of authority having jurisdiction.
 - .3 Inspect and test of welds in accordance with "Inspection and Test Plan" by non-destructive visual examination.
- .2 Visual examinations: include entire circumference of weld externally and, wherever possible, internally.
- .3 Failure of visual examinations:
 - .1 Upon failure of welds by visual examination, perform additional testing as directed by Departmental Representative 10% of welds, selected at random by Departmental Representative.

3.6 DEFECTS CAUSING REJECTION

- .1 As described in ANSI/ASME Boiler and Pressure Vessels Code.
- .2 In addition, chilled water systems below 690 kPa:
 - .1 Undercutting greater than 0.8 mm adjacent to cover bead on outside of pipe.
 - .2 Undercutting greater than 0.8 mm adjacent to root bead on inside of pipe.
 - .3 Undercutting greater than 0.8 mm at combination of internal surface and external surface.
 - .4 Incomplete penetration and incomplete fusion greater than total length of 38 mm in 1500 mm length of weld depth of such defects being greater than 0.8 mm.
 - .5 Repair cracks and defects in excess of 0.8 mm in depth.
 - .6 Repair defects whose depth cannot be determined accurately on basis of visual examination.

3.7 REPAIR OF WELDS WHICH FAILED TESTS

- .1 Re-inspect and re-test repaired or re-worked welds at Contractor's expense.

3.8 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 General

1.1 REFERENCES

- .1 American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME).
 - .1 ANSI/ASME B1.20.1-1983(R2006), Pipe Threads, General Purpose (Inch).
 - .2 ANSI/ASME B16.18-2001, Cast Copper Alloy Solder Joint Pressure Fittings.
- .2 ASTM International.
 - .1 ASTM A276-08, Standard Specification for Stainless Steel Bars and Shapes.
 - .2 ASTM B62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .3 ASTM B283-08a, Standard Specification for Copper and Copper Alloy Die Forgings (Hot-Pressed).
 - .4 ASTM B505/B505M-08a, Standard Specification for Copper-Base Alloy Continuous Castings.
- .3 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS).
 - .1 MSS-SP-25-1998, Standard Marking System for Valves, Fittings, Flanges and Unions.
 - .2 MSS-SP-80-2008, Bronze Gate Globe, Angle and Check Valves.
 - .3 MSS-SP-110-1996, Ball Valves, Threaded, Socket-Welding, Solder Joint, Grooved and Flared Ends.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and data sheets for equipment and systems and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit WHMIS MSDS - Material Safety Data Sheets.
- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Saskatchewan, Canada.
 - .2 Submit data for valves specified in this Section.

1.3 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 MAINTENANCE MATERIAL SUBMITTALS

- .1 Extra Materials/Spare Parts:
 - .1 Furnish following spare parts:
 - .1 Valve seats: one for every 10 valves each size, minimum 1.
 - .2 Discs: one for every 10 valves, each size. Minimum 1.
 - .3 Stem packing: one for every 10 valves, each size. Minimum 1.
 - .4 Valve handles: 2 of each size.
 - .5 Gaskets for flanges: one for every 10 flanged joints.
 - .2 Tools:
 - .1 Furnish special tools for maintenance of systems and equipment.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse of pallets, crates, padding, and packaging materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 MATERIALS

- .1 Valves:
 - .1 Except for specialty valves, to be single manufacturer.
 - .2 Products to have CRN registration numbers.
- .2 End Connections:
 - .1 Connection into adjacent piping/tubing:
 - .1 Steel pipe systems: screwed ends to ANSI/ASME B1.20.1.
 - .2 Copper tube systems: grooved ends to ANSI/ASME B16.18.

.3 Gate Valves:

- .1 Requirements common to gate valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Bonnet: union with hexagonal shoulders.
 - .3 Connections: screwed with hexagonal shoulders.
 - .4 Inspection and pressure testing: to MSS SP-80. Tests to be hydrostatic.
 - .5 Packing: non-asbestos.
 - .6 Handwheel: non-ferrous.
 - .7 Handwheel Nut: bronze to ASTM B62.
- .2 50 mm(NPS 2) and under, rising stem, split wedge disc, Class 125:
 - .1 Body: with long disc guides, screwed bonnet.
 - .2 Disc: split wedge, bronze to ASTM B283, loosely secured to stem.
 - .3 Operator: handwheel.

.4 Globe Valves:

- .1 Requirements common to globe valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Bonnet: union with hexagonal shoulders.
 - .3 Connections: screwed with hexagonal shoulders.
 - .4 Pressure testing: to MSS SP-80. Tests to be hydrostatic.
 - .5 Stuffing box: threaded to bonnet with gland follower, packing nut, high grade non-asbestos packing.
 - .6 Handwheel: non-ferrous.
 - .7 Handwheel Nut: bronze to ASTM B62.
- .2 50 mm NPS 2 and under, composition disc, Class 125:
 - .1 Body and bonnet: screwed bonnet.
 - .2 Disc and seat: renewable rotating PTFE disc composition to suit service conditions, regrindable bronze seat, loosely secured to bronze stem to ASTM B505.
 - .3 Operator: handwheel.
- .3 Angle valve, 50 mm (NPS 2) and under, composition disc, Class 150:
 - .1 Body and bonnet: union bonnet.
 - .2 Disc and seat: renewable rotating PTFE disc in slip-on easily removable disc holder having integral guides, regrindable bronze seat, loosely secured to stem.
 - .3 Operator: handwheel .

- .5 Check Valves:
 - .1 Requirements common to check valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Connections: screwed with hexagonal shoulders.
 - .2 50 mm (NPS 2) and under, swing type, bronze disc, Class 125:
 - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: regrindable.
- .6 Silent Check Valves:
 - .1 50 mm (NPS 2) and under:
 - .1 Body: cast high tensile bronze to ASTM B62 with integral seat.
 - .2 Pressure rating: Class 125.
 - .3 Connections: screwed ends to ANSI B1.20.1 and with hex. shoulders.
 - .4 Disc and seat: renewable rotating disc.
 - .5 Stainless steel spring for downflow applications, heavy duty.
 - .6 Seat: regrindable.
- .7 Ball Valves:
 - .1 50 mm (NPS 2) and under:
 - .1 Body and cap: cast high tensile bronze to ASTM B62.
 - .2 Pressure rating: Class 125.
 - .3 Connections: screwed ends to ANSI B1.20.1 and with hexagonal shoulders.
 - .4 Stem: tamperproof ball drive.
 - .5 Stem packing nut: external to body.
 - .6 Ball and seat: replaceable stainless steel solid ball and Teflon seats.
 - .7 Stem seal: TFE with external packing nut.
 - .8 Operator: removable lever handle.

3 Execution

3.1 INSTALLATION

- .1 Install rising stem valves in upright position with stem above horizontal.
- .2 Remove internal parts before soldering.

- .3 Install valves with unions at each piece of equipment arranged to allow servicing, maintenance, and equipment removal.

3.2 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse or recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 General

1.1 REFERENCES

- .1 American Society of Mechanical Engineers (ASME).
 - .1 ASME B16.1-05, Cast Iron Pipe Flanges and Flanged Fittings.
- .2 ASTM International Inc.
 - .1 ASTM A49-01(2006), Standard Specification for Heat-Treated Carbon Steel Joint Bars.
 - .2 ASTM A126-04, Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings.
 - .3 ASTM A536-84(2004)e1, Standard Specification for Ductile Iron Castings.
 - .4 ASTM B61-08, Standard Specification for Steam or Valve Bronze Castings.
 - .5 ASTM B62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .6 ASTM B85/B85M-08, Standard Specification for Aluminum-Alloy Die Castings.
 - .7 ASTM B209-07, Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- .3 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS).
 - .1 MSS SP-61-03, Pressure Testing of Steel Valves.
 - .2 MSS SP-70-06, Grey Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS SP-71-05, Grey Iron Swing Check Valves, Flanged and Threaded Ends.
 - .4 MSS SP-82-1992, Valve Pressure Testing Methods.
 - .5 MSS SP-85-2002, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheets for valves and include product characteristics, performance criteria, physical size, finish and limitations.

- .3 Shop Drawings:
 - .1 Provide drawings stamped and signed by professional engineer registered or licensed in Province s of Saskatchewan, Canada.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse of pallets crates padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.5 MAINTENANCE MATERIAL SUBMITTALS

- .1 Extra Materials/Spare Parts:
- .2 Furnish following spare parts:
 - .1 Valve seats: one for every 10 valves each size, minimum 1.
 - .2 Discs: one for every 10valves, each size, minimum 1.
 - .3 Stem packing: one for every 10 valves, each size, minimum 1.
 - .4 Valve handles: 2 of each size.
 - .5 Gaskets for flanges: one for every 10 flanged joints.
- .3 Tools:
 - .1 Furnish special tools for maintenance of systems and equipment.

2 Products

2.1 MATERIAL

- .1 Valves:
 - .1 Except for specialty valves, to be of single manufacturer.
- .2 Standard specifications:
 - .1 Gate valves: MSS SP-70.
 - .2 Globe valves: MSS SP-85.

- .3 Check valves: MSS SP-71.
- .3 Requirements common to valves, unless specified otherwise:
 - .1 Body, bonnet: cast iron to ASTM B209 Class B.
 - .2 Connections: grooved ends to ANSI B16.1.
 - .3 Inspection and pressure testing: to MSS SP-82.
 - .4 Bonnet gasket: non-asbestos.
 - .5 Stem: to have precision-machined Acme or 60 degrees V threads, top screwed for handwheel nut.
 - .6 Stuffing box: non-galling two-piece ball-jointed packing gland, gland bolts and nuts.
 - .7 Gland packing: non-asbestos.
 - .8 Handwheel: die-cast aluminum alloy to ASTM B85/B85M or malleable iron to ASTM A49. Nut of bronze to ASTM B62.
 - .9 Identification tag: with catalogue number, size, other pertinent data.
- .4 All products to have CRN registration numbers.

2.2 GATE VALVES

- .1 65 mm – 200 mm (NPS 2 1/2-8), outside screw and yoke (OS Y), bronze trim, solid wedge disc:
 - .1 Body and multiple-bolted bonnet: with bosses in body and bonnet for taps and drains, full length disc guides designed to ensure correct re-assembly, yoke, yoke hub, yoke sleeve and nut. Class 125.
 - .2 Disc: solid offset taper wedge, bronze to ASTM B62 up to NPS 3, cast iron with bronze disc rings on other sizes, secured to stem through integral forged T-head disc-stem connection.
 - .3 Seat rings: renewable bronze screwed into body.
 - .4 Stem: nickel-plated steel .

2.3 GLOBE VALVES

- .1 65 mm – 250 mm (NPS 2 1/2 – 10), OSY:
 - .1 Body: with multiple-bolted bonnet.
 - .2 WP: 860 kPa steam, 1.4 MPa CWP.
 - .3 Bonnet-yoke gasket: non-asbestos.
 - .4 Disc: bronze to ASTM B62, fully guided from bottom, securely yet freely connected to stem for swivel action and accurate engagement with disc.
 - .5 Seat ring: renewable, regrindable, screwed into body.
 - .6 Stem: bronze to ASTM B62.
 - .7 Operator: handwheel or motor: as indicated.

2.4 VALVE OPERATORS

- .1 Install valve operators as follows:
 - .1 Handwheel: on valves except as indicated.

2.5 CHECK VALVES

- .1 Swing check valves, Class 125:
 - .1 Body and bolted cover: with tapped and plugged opening on each side for hinge pin. Grooved or flanged ends: plain faced with smooth finish.
 - .1 Cast iron to ASTM A126 Class B.
 - .2 NPS 18 and over: cast iron to ASTM A126 Class C.
 - .2 Ratings: 1.4 MPa
 - .3 Disc: rotating for extended life.
 - .1 Up to 150 mm (NPS 6): bronze to ASTM B62.
 - .2 200 mm (NPS 8) and over: bronze-faced cast iron.
 - .4 Seat rings: renewable bronze to ASTM B62 screwed into body.
 - .5 Hinge pin, bushings: renewable bronze to ASTM B62.

2.6 SILENT CHECK VALVES

- .1 Construction:
 - .1 Body: malleable with integral seat.
 - .2 Pressure rating: Class 125, WP = 860 kPa.
 - .3 Connections: grooved ends.
 - .4 Disc: bronze renewable rotating disc.
 - .5 Seat: renewable, EPDM.
 - .6 Stainless steel spring, heavy duty.

3 Execution

3.1 INSTALLATION

- .1 Install rising stem valves in upright position with stem above horizontal.

3.2 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
- .2 Clean installed products in accordance to manufacturer's recommendation.
- .3 Waste Management: separate waste materials for reuse or recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 General

1.1 REFERENCES

- .1 ASTM International.
 - .1 ASTM A125 1996 (2007), Standard Specification for Steel Springs, Helical, Heat Treated.
 - .2 ASTM A307 07b, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .3 ASTM A563 07a, Standard Specification for Carbon and Alloy Steel Nuts.
- .2 Factory Mutual (FM).
- .3 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .4 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS).
 - .1 MSS SP58 2002, Pipe Hangers and Supports Materials, Design and Manufacture.
 - .2 MSS SP69 2003, Pipe Hangers and Supports Selection and Application.
 - .3 MSS SP89 2003, Pipe Hangers and Supports Fabrication and Installation Practices.
- .5 Underwriter's Laboratories of Canada (ULC).

1.2 SYSTEM DESCRIPTION

- .1 Design Requirements:
 - .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.
 - .2 Base maximum load ratings on allowable stresses prescribed by ASME B31.1 or MSS SP58.
 - .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure.
 - .4 Design hangers and supports to support systems under conditions of operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment.
 - .5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment in accordance with MSS SP58.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and data sheets for hangers and supports and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Saskatchewan of Canada.
 - .2 Submit shop drawings for:
 - .1 Bases, hangers and supports.
 - .2 Connections to equipment and structure.
 - .3 Structural assemblies.
- .4 Certificates:
 - .1 Submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Manufacturers' Instructions:
 - .1 Provide manufacturer's installation instructions.

1.4 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 GENERAL

- .1 Fabricate hangers, supports and sway braces in accordance with ANSI B31.1 and MSS SP58.
- .2 Use components for intended design purpose only. Do not use for rigging or erection purposes.

2.2 PIPE HANGERS

- .1 Finishes:
 - .1 Pipe hangers and supports: galvanized after manufacture.
 - .2 Use hot dipped galvanizing process.
 - .3 Ensure steel hangers in contact with copper piping are epoxy coated.
- .2 Upper attachment structural: suspension from lower flange of I-Beam:
 - .1 Cold piping 50 mm (NPS 2) maximum: malleable iron C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip.
 - .1 Rod: 9 mm UL listed.
 - .2 Cold piping 65 mm (NPS 2 ½) or greater, hot piping: malleable iron beam clamp, eye rod, jaws and extension with carbon steel retaining clip, tie rod, nuts and washers, UL listed to MSS-SP58 and MSS-SP69.
- .3 Upper attachment structural: suspension from upper flange of I-Beam:
 - .1 Cold piping 50 mm (NPS 2) maximum: ductile iron top-of-beam C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip, UL listed to MSS SP69.
 - .2 Cold piping 65 mm (NPS 2 ½) or greater, hot piping: malleable iron top-of-beam jaw clamp with hooked rod, spring washer, plain washer and nut UL listed.
- .4 Upper attachment to concrete:
 - .1 Ceiling: carbon steel welded eye rod, clevis plate, clevis pin and cotters with weldless forged steel eye nut. Ensure eye 6mm minimum greater than rod diameter.
 - .2 Concrete inserts: wedge shaped body with knockout protector plate UL listed to MSS SP69.
- .5 Hanger rods: threaded rod material to MSS SP58:
 - .1 Ensure that hanger rods are subject to tensile loading only.
 - .2 Provide linkages where lateral or axial movement of pipework is anticipated.
 - .3 Do not use rods over 22 mm.

- .6 Pipe attachments: material to MSS SP58:
 - .1 Attachments for steel piping: carbon steel galvanized.
 - .2 Attachments for copper piping: copper plated black steel.
 - .3 Use insulation shields for hot pipework.
 - .4 Oversize pipe hangers and supports.
- .7 Adjustable clevis: material to MSS SP69 UL listed, clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.
 - .1 Ensure "U" has hole in bottom for rivetting to insulation shields.
- .8 U-bolts: carbon steel to MSS SP69 with 2 nuts at each end to ASTM A563.
 - .1 Finishes for steel pipework: galvanized.
 - .2 Finishes for copper, glass, brass or aluminum pipework: galvanized with formed portion plastic coated or epoxy coated.

2.3 RISER CLAMPS

- .1 Steel or cast iron pipe: galvanized carbon steel to MSS SP58, type 42, UL listed.
- .2 Copper pipe: carbon steel copper plated to MSS SP58, type 42.
- .3 Bolts: to ASTM A307.
- .4 Nuts: to ASTM A563.

2.4 INSULATION PROTECTION SHIELDS

- .1 Insulated cold piping:
 - .1 64 kg/m³ density insulation plus insulation protection shield to: MSS SP69, galvanized sheet carbon steel. Length designed for maximum 3 m span.
- .2 Insulated hot piping:
 - .1 Curved plate 300 mm long, with edges turned up, welded-in centre plate for pipe sizes 300 mm (NPS 12) and over, carbon steel to comply with MSS SP69.

2.5 EQUIPMENT SUPPORTS

- .1 Fabricate equipment supports not provided by equipment manufacturer from structural grade steel meeting requirements of Section 05 50 00 – Metal Fabrications. Submit calculations with shop drawings.

2.6 EQUIPMENT ANCHOR BOLTS AND TEMPLATES

- .1 Provide templates to ensure accurate location of anchor bolts.

2.7 HOUSE-KEEPING PADS

- .1 Provide 100 mm high concrete housekeeping pads for base-mounted equipment; size pads 50mm larger than equipment; chamfer pad edges.
- .2 Concrete: as indicated.

2.8 OTHER EQUIPMENT SUPPORTS

- .1 Fabricate equipment supports from structural grade steel meeting requirements of Section 05 50 00 - Metal Fabrications.
- .2 Submit structural calculations with shop drawings.

3 Execution**3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install in accordance with:
 - .1 Manufacturer's instructions and recommendations.
- .2 Vibration Control Devices:
 - .1 Install on piping systems at pumps, boilers, chillers, cooling towers, and as indicated.
- .3 Clamps on riser piping:
 - .1 Support independent of connected horizontal pipework using riser clamps and riser clamp lugs welded to riser.
 - .2 Bolt tightening torques to industry standards.
 - .3 Steel pipes: install below coupling or shear lugs welded to pipe.
 - .4 Cast iron pipes: install below joint.
- .4 Clevis plates:
 - .1 Attach to concrete with 4 minimum concrete inserts, one at each corner.
- .5 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.
- .6 Use approved constant support type hangers where:

- .1 Vertical movement of pipework is 13 mm or more.
- .2 Transfer of load to adjacent hangers or connected equipment is not permitted.
- .7 Use variable support spring hangers where:
 - .1 Transfer of load to adjacent piping or to connected equipment is not critical.
 - .2 Variation in supporting effect does not exceed 25% of total load.

3.3 HANGER SPACING

- .1 Plumbing piping: to Canadian Plumbing Code, Provincial Code, ASHRAE Standards, Natural Gas Installation Code, and authority having jurisdiction.
- .2 Fire protection: to applicable fire code.
- .3 Gas and fuel oil piping: up to 15 mm (NPS ½): every 1.8 m.
- .4 Copper piping: up to 15 mm (NPS ½): every 1.5 m.
- .5 Chilled water: in accordance with table below, but not less than one hanger at joints.
- .6 Within 300mm of each elbow.

Maximum Pipe Size: NPS	Maximum Spacing Steel	Maximum Spacing Copper
up to 1-1/4	2.1 m	1.8 m
1-1/2	2.7 m	2.4 m
2	3.0 m	2.7 m
2-1/2	3.6 m	3.0 m
3	3.6 m	3.0 m
3-1/2	3.9 m	3.3 m
4	4.2 m	3.6 m
5	4.8 m	
6	5.1 m	
8	5.7 m	
10	6.6 m	
12	6.9 m	

- .7 Pipework greater than 300 mm (NPS 12): to MSS SP69.

3.4 HANGER INSTALLATION

- .1 Install hanger so that rod is vertical under operating conditions.
- .2 Adjust hangers to equalize load.
- .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural steel members.

3.5 HORIZONTAL MOVEMENT

- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4 degrees from vertical.
- .2 Where horizontal pipe movement is less than 13 mm, offset pipe hanger and support so that rod hanger is vertical in the hot position.

3.6 FINAL ADJUSTMENT

- .1 Adjust hangers and supports:
 - .1 Ensure that rod is vertical under operating conditions.
 - .2 Equalize loads.
- .2 Adjustable clevis:
 - .1 Tighten hanger load nut securely to ensure proper hanger performance.
 - .2 Tighten upper nut after adjustment.
- .3 C-clamps:
 - .1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.
- .4 Beam clamps:
 - .1 Hammer jaw firmly against underside of beam.

3.7 FIELD QUALITY CONTROL

- .1 Manufacturer's Field Services:
 - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in Part 1 - ACTION AND INFORMATIONAL SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in Part 1 – QUALITY ASSURANCE.

3.8 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 General

1.1 REFERENCES

- .1 Canadian Gas Association (CGA).
 - .1 CSA/CGA B149.1-05, Natural Gas and Propane Installation Code.
- .2 Canadian General Standards Board (CGSB).
 - .1 CAN/CGSB 1.60 97, Interior Alkyd Gloss Enamel.
- .3 CAN/CGSB 24.3 92, Identification of Piping Systems.
- .4 Canadian Standards Association (CSA International).
 - .1 CSA B52 99, Mechanical Refrigeration Code.
- .5 National Fire Protection Association (NFPA).
 - .1 NFPA 13 2002, Standard for the Installation of Sprinkler Systems.
 - .2 NFPA 14 2003, Standard for the Installation of Standpipe and Hose Systems.

1.2 SUBMITTALS

Submittals: in accordance with Section 01 33 00 - Submittal Procedures.

- .1 Product data to include paint colour chips, other products specified in this section.
- .2 Samples:
 - .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Samples to include nameplates, labels, tags, lists of proposed legends.

1.3 QUALITY ASSURANCE

- .1 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.

.2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

.2 Waste Management and Disposal:

.1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

.2 Dispose of unused paint material at official hazardous material collections site.

.3 Do not dispose of unused paint material into sewer system, into streams, lakes, onto ground or in locations where it will pose health or environmental hazard.

2 Products

2.1 MANUFACTURER'S EQUIPMENT NAMEPLATES

.1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.

.2 Lettering and numbers raised or recessed.

.3 Information to include, as appropriate:

.1 Equipment: manufacturer's name, model, size, serial number, capacity.

.2 Motor: voltage, Hz, phase, power factor, duty, frame size.

2.2 SYSTEM NAMEPLATES

.1 Colours:

.1 Hazardous: red letters, white background.

.2 Elsewhere: black letters, white background (except where required otherwise by applicable codes).

.2 Construction:

.1 3 mm thick laminated plastic or white anodized aluminum, matte finish, with square corners, letters accurately aligned and machine engraved into core.

.3 Sizes:

.1 Conform to following table:

Size # mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1	10 x 50	1	3
2	13 x 75	1	5
3	13 x 75	2	3
4	20 x 100	1	8
5	20 x 100	2	5
6	20 x 200	1	8
7	25 x 125	1	12
8	25 x 125	2	8
9	35 x 200	1	20

.2 Use maximum of 25 letters/numbers per line.

.4 Identification for Departmental Representative Preventive Maintenance Support System (PMSS):

.1 Use arrangement of Main identifier, Source identifier, Destination identifier.

.2 Equipment in Mechanical Room:

.1 Main identifier: size #9.

.2 Source and Destination identifiers: size #6.

.3 Terminal cabinets, control panels: size #5.

.3 Equipment elsewhere: sizes as appropriate.

2.3 EXISTING IDENTIFICATION SYSTEMS

.1 Apply existing identification system to new work.

.2 Where existing identification system does not cover for new work, use identification system specified this section.

2.4 PIPING SYSTEMS GOVERNED BY CODES

- .1 Identification:
 - .1 Natural gas: to CSA/CGA B149.1 and authority having jurisdiction.
 - .2 Sprinklers: to NFPA 13.
 - .3 Refrigeration to CSA/CGA B52 and authority having jurisdiction.

2.5 IDENTIFICATION OF PIPING SYSTEMS

- .1 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.
- .2 Pictograms:
 - .1 Where required: Workplace Hazardous Materials Information System (WHMIS) regulations.
- .3 Legend:
 - .1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.
- .4 Arrows showing direction of flow:
 - .1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.
 - .2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.
 - .3 Use double headed arrows where flow is reversible.
- .5 Extent of background colour marking:
 - .1 To full circumference of pipe or insulation.
 - .2 Length to accommodate pictogram, full length of legend and arrows.
- .6 Materials for background colour marking, legend, arrows:
 - .1 Pipes and tubing 20 mm and smaller: waterproof and heat resistant pressure sensitive plastic marker tags.
 - .2 Other pipes: pressure sensitive plastic coated cloth with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100% RH and continuous operating temperature of 150 degrees C and intermittent temperature of 200°C.

.7 Colours and Legends:

- .1 Where not listed, obtain direction from Departmental Representative.
- .2 Colours for legends, arrows: to following table:

Background Colour	Legend, Arrows
Yellow	BLACK
Green	WHITE
Red	WHITE

.3 Background colour marking and legends for piping systems:

Contents	Background Colour Marking	Legend
** Add design temperature		
++ Add design temperature and pressure		
City water	Green	CITY WATER
Treated water	Green	TREATED WATER
Chilled water supply	Green	CH. WTR. SUPPLY
Chilled water return	Green	CH. WTR. RETURN
Refrigeration suction	Yellow	REF. SUCTION
Refrigeration liquid	Yellow	REF. LIQUID
Refrigeration hot gas	Yellow	REF. HOT GAS
Natural gas	to Codes	
Gas regulator vents	to Codes	
Fire protection water	Red	FIRE PROT. WTR
Sprinklers	Red	SPRINKLERS

2.6 IDENTIFICATION DUCTWORK SYSTEMS

- .1 50 mm high stencilled letters and directional arrows 150 mm long x 50 mm high.
- .2 Colours: back, or co-ordinated with base colour to ensure strong contrast.

2.7 VALVES, CONTROLLERS

- .1 Brass tags with 12 mm stamped identification data filled with black paint.
- .2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.

2.8 CONTROLS COMPONENTS IDENTIFICATION

- .1 Identify all systems, equipment, components, controls, sensors with system nameplates specified in this section.
- .2 Inscriptions to include function and (where appropriate) fail safe position.

2.9 LANGUAGE

- .1 Identification in English and French.
- .2 Use one nameplate and label for both languages.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 TIMING

- .1 Provide identification only after painting specified Section 05 50 00 – Metal Fabrications has been completed.

3.3 INSTALLATION

- .1 Perform work in accordance with CAN/CGSB 24.3 except as specified otherwise.
- .2 Provide ULC and/or CSA registration plates as required by respective agency.
- .3 Identify systems, equipment to conform to Departmental Representative PMSS.

3.4 NAMEPLATES

- .1 Locations:
 - .1 In conspicuous location to facilitate easy reading and identification from operating floor.

- .2 Standoffs:
 - .1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection:
 - .1 Do not paint, insulate or cover.

3.5 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS

- .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: at not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
- .2 Adjacent to each change in direction.
- .3 At least once in each small room through which piping or ductwork passes.
- .4 On both sides of visual obstruction or where run is difficult to follow.
- .5 On both sides of separations such as walls, floors, partitions.
- .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
- .7 At beginning and end points of each run and at each piece of equipment in run.
- .8 At point immediately upstream of major manually operated or automatically controlled valves, and dampers. Where this is not possible, place identification as close as possible, preferably on upstream side.
- .9 Identification easily and accurately readable from usual operating areas and from access points.
 - .1 Position of identification approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.

3.6 VALVES, CONTROLLERS

- .1 Valves and operating controllers, except at plumbing fixtures, radiation, or where in plain sight of equipment they serve: Secure tags with non-ferrous chains or closed "S" hooks.
- .2 Install one copy of flow diagrams, valve schedules mounted in frame behind non glare glass where directed by Departmental Representative. Provide one copy (reduced in size if required) in each operating and maintenance manual.
- .3 Number valves in each system consecutively.

3.7 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 SUMMARY

- .1 TAB is used throughout this Section to describe the process, methods and requirements of testing, adjusting and balancing for HVAC.
- .2 TAB means to test, adjust and balance to perform in accordance with requirements of Contract Documents and to do other work as specified in this section.

1.2 QUALIFICATIONS OF TAB PERSONNEL

- .1 Submit names of personnel to perform TAB to Departmental Representative within 90 days of award of contract.
- .2 Provide documentation confirming qualifications, successful experience.
- .3 TAB: performed in accordance with the requirements of standard under which TAB Firm's qualifications are approved:
 - .1 Associated Air Balance Council, (AABC) National Standards for Total System Balance, MN-1-2002.
 - .2 National Environmental Balancing Bureau (NEBB) TABES, Procedural Standards for Testing, Adjusting, Balancing of Environmental Systems-1998.
 - .3 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA), HVAC TAB HVAC Systems - Testing, Adjusting and Balancing-2002.
- .4 Recommendations and suggested practices contained in the TAB Standard: mandatory.
- .5 Use TAB Standard provisions, including checklists, and report forms to satisfy Contract requirements.
- .6 Use TAB Standard for TAB, including qualifications for TAB Firm and Specialist and calibration of TAB instruments.
- .7 Where instrument manufacturer calibration recommendations are more stringent than those listed in TAB Standard, use manufacturer's recommendations.
- .8 TAB Standard quality assurance provisions such as performance guarantees form part of this contract.
 - .1 For systems or system components not covered in TAB Standard, use TAB procedures developed by TAB Specialist.

.2 Where new procedures, and requirements, are applicable to Contract requirements have been published or adopted by body responsible for TAB Standard used (AABC, NEBB, or TABB), requirements and recommendations contained in these procedures and requirements are mandatory.

1.3 PURPOSE OF TAB

- .1 Test to verify proper and safe operation, determine actual point of performance, evaluate qualitative and quantitative performance of equipment, systems and controls at design, average and low loads using actual or simulated loads.
- .2 Adjust and regulate equipment and systems to meet specified performance requirements and to achieve specified interaction with other related systems under normal and emergency loads and operating conditions.
- .3 Balance systems and equipment to regulate flow rates to match load requirements over full operating ranges.

1.4 EXCEPTIONS

- .1 TAB of systems and equipment regulated by codes, standards to satisfaction of authority having jurisdiction.

1.5 CO-ORDINATION

- .1 Schedule time required for TAB (including repairs, re testing) into project construction and completion schedule to ensure completion before acceptance of project.
- .2 Do TAB of each system independently and subsequently, where interlocked with other systems, in unison with those systems.

1.6 PRE-TAB REVIEW

- .1 Review contract documents before project construction is started and confirm in writing to Departmental Representative adequacy of provisions for TAB and other aspects of design and installation pertinent to success of TAB.
- .2 Review specified standards and report to Departmental Representative in writing proposed procedures which vary from standard.
- .3 During construction, co-ordinate location and installation of TAB devices, equipment, accessories, measurement ports and fittings.

1.7 START-UP

- .1 Follow start up procedures as recommended by equipment manufacturer unless specified otherwise.

- .2 Follow special start up procedures specified elsewhere in Division 23.

1.8 OPERATION OF SYSTEMS DURING TAB

- .1 Operate systems for length of time required for TAB and as required by Departmental Representative for verification of TAB reports.

1.9 START OF TAB

- .1 Notify Departmental Representative 7 days prior to start of TAB.
- .2 Start TAB when installation is essentially completed including: Start up, verification for proper, normal and safe operation of mechanical and associated electrical and control systems affecting TAB including but not limited to:
 - .1 Proper thermal overload protection in place for electrical equipment.
 - .2 Pressure , Leakage, other tests specified elsewhere in Division 23.
 - .3 Provisions for TAB installed and operational.
 - .4 Air systems:
 - .1 Filters in place, clean.
 - .2 Duct systems clean.
 - .3 Ducts, air shafts, ceiling plenums are airtight to within specified tolerances.
 - .4 Correct fan rotation.
 - .5 Fire, smoke, volume control dampers installed and open.
 - .6 Access doors, installed, closed.
 - .7 Outlets installed, volume control dampers open.
 - .5 Liquid systems:
 - .1 Flushed, filled, vented.
 - .2 Correct pump rotation.
 - .3 Strainers in place, baskets clean.
 - .4 Isolating and balancing valves installed, open.
 - .5 Calibrated balancing valves installed, at factory settings.
 - .6 Chemical treatment systems complete, operational.

1.10 APPLICATION TOLERANCES

- .1 Do TAB to following tolerances of design values:
 - .1 HVAC systems: plus 5%, minus 5%.
 - .2 Hydronic systems: plus or minus 10%.

1.11 ACCURACY TOLERANCES

- .1 Measured values accurate to within plus or minus 2% of actual values.

1.12 INSTRUMENTS

- .1 Prior to TAB, submit to Departmental Representative list of instruments used together with serial numbers.
- .2 Calibrate in accordance with requirements of most stringent of referenced standard for either applicable system or HVAC system.
- .3 Calibrate within 3 months of TAB. Provide certificate of calibration to Departmental Representative.

1.13 SUBMITTALS

- .1 Submit, prior to commencement of TAB:
- .2 Proposed methodology and procedures for performing TAB if different from referenced standard.

1.14 PRELIMINARY TAB REPORT

- .1 Submit for checking and approval of Departmental Representative, prior to submission of formal TAB report, sample of rough TAB sheets. Include:
 - .1 Details of instruments used.
 - .2 Details of TAB procedures employed.
 - .3 Calculations procedures.
 - .4 Summaries.

1.15 TAB REPORT

- .1 Format in accordance with referenced standard.
- .2 TAB report to show results in SI units and to include:
 - .1 Project record drawings.
 - .2 System schematics.
- .3 Submit 3 copies of TAB Report to Departmental Representative for verification and approval, in English in D ring binders, complete with index tabs.

1.16 VERIFICATION

- .1 Reported results subject to verification by Departmental Representative.
- .2 Provide personnel and instrumentation to verify up to 30% of reported results.

- .3 Number and location of verified results as directed by Departmental Representative.
- .4 Pay costs to repeat TAB as required to satisfaction of Engineer.

1.17 SETTINGS

- .1 After TAB is completed to satisfaction of Engineer, replace drive guards, close access doors, lock devices in set positions, ensure sensors are at required settings.
- .2 Permanently mark settings to allow restoration at any time during life of facility. Do not eradicate or cover markings.

1.18 COMPLETION OF TAB

- .1 TAB considered complete when final TAB Report received and approved by Engineer.

1.19 AIR SYSTEMS

- .1 Standard: TAB to most stringent of this section or TAB standards of AABC or NEBB.
- .2 Do TAB of following systems, equipment, components, controls:
 - .1 New boiler room ventilation system.
 - .2 Modified electrical room ventilation system.

- .3 Locations of equipment measurements: to include as appropriate:
 - .1 Inlet and outlet of dampers, filter, coil, humidifier, fan, other equipment causing changes in conditions.
 - .2 At controllers, controlled device.
- .4 Locations of systems measurements to include as appropriate: main ducts, main branch, sub branch, run out (or grille, register or diffuser).

1.20 HYDRONIC SYSTEMS

- .1 Standard: TAB to most stringent of this section or TAB standards of AABC or NEBB.
- .2 Do TAB to the following systems, equipment components, controls:
 - .1 Refrigeration system.
 - .2 Chilled water pumps.

1.21 OTHER TAB REQUIREMENTS

- .1 Qualifications: personnel performing TAB current member in good standing of AABC or NEBB.
- .2 Quality assurance: perform TAB under direction of supervisor qualified by AABC or NEBB.
- .3 Measurements: to include as appropriate for systems, equipment, components, controls: air velocity, static pressure, flow rate, pressure drop (or loss), temperatures (dry bulb, wet bulb, dewpoint), duct cross sectional area, RPM, electrical power, voltage, noise, vibration.
- .4 Building pressure conditions:
 - .1 Adjust HVAC systems, equipment, controls to ensure specified pressure conditions at all times.
- .5 Measurement of noise and vibration from equipment specified in Division 23.

1.22 POST-OCCUPANCY

- .1 Measure NC levels, in occupied zone of following areas: offices adjacent to condensers.

2 Products

Not Used.

3 Execution

Not Used.

END OF SECTION

1 General

1.1 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
- .3 Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.

1.2 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE).
 - .1 ANSI/ASHRAE/IESNA 90.1-01, SI; Energy Standard for Buildings Except Low-Rise Residential Buildings.
- .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM C335-95, Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.
 - .2 ASTM C411-97, Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation.
 - .3 ASTM C449/C449M-00, Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
 - .4 ASTM C547-00, Specification for Mineral Fiber Pipe Insulation.
 - .5 ASTM C553-00, Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications.
 - .6 ASTM C612-00a, Specification for Mineral Fiber Block and Board Thermal Insulation.
- .3 Canadian General Standards Board (CGSB).
 - .1 CGSB 51-GP-52Ma-89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
- .4 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (R1999).
- .5 Underwriters Laboratories of Canada (ULC).
 - .1 CAN/ULC-S102-M88(R2000), Surface Burning Characteristics of Building Materials and Assemblies.
 - .2 CAN/ULC-S701-01, Thermal Insulation Polyotrene, Boards and Pipe Covering.

1.3 DEFINITIONS

- .1 For purposes of this section:
 - .1 "CONCEALED" - insulated mechanical services and equipment in suspended ceilings and non-accessible chases and furred-in spaces.
 - .2 "EXPOSED" - will mean "not concealed" as defined herein.

- .3 Insulation systems - insulation material, fasteners, jackets, and other accessories.
- .2 TIAC Codes:
 - .1 CRD: Code Round Ductwork.
 - .2 CRF: Code Rectangular Finish.
- 1.4 SHOP DRAWINGS**
 - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit for approval manufacturer's catalogue literature related to installation, fabrication for duct jointing recommendations.
- 1.5 SAMPLES**
 - .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit for approval: complete assembly of each type of insulation system, insulation, coating, and adhesive proposed. Mount sample on 12 mm plywood board. Affix typewritten label beneath sample indicating service.
- 1.6 MANUFACTURERS' INSTRUCTIONS**
 - .1 Submit manufacturer's installation instructions in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Installation instructions to include procedures used, and installation standards achieved.
- 1.7 QUALIFICATIONS**
 - .1 Installer: specialist in performing work of this section, and have at least 3 years successful experience in this size and type of project, and member of TIAC.
- 1.8 DELIVERY, STORAGE AND HANDLING**
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
 - .2 Protect from weather and construction traffic.
 - .3 Protect against damage from any source.
 - .4 Store at temperatures and conditions recommended by manufacturer.
- 1.9 WASTE MANAGEMENT AND DISPOSAL**
 - .1 Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposal.
 - .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.

- .3 Collect and separate for disposal paper, plastic, and corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal materials from landfill to metal recycling facility approved by Departmental Representative.
- .5 Divert unused adhesive material from landfill to official hazardous material collections site approved by Departmental Representative.
- .6 Do not dispose of unused adhesive materials into sewer systems, into lakes, streams, onto ground or in other locations where it will pose health or environmental hazard.

2 Products

2.1 FIRE AND SMOKE RATING

- .1 In accordance with CAN/ULC-S102:
 - .1 Maximum flame spread rating: 25.
 - .2 Maximum smoke developed rating: 50.

2.2 INSULATION

- .1 Mineral fibre: as specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24°C mean temperature when tested in accordance with ASTM C335.
- .3 TIAC Code C-1: Rigid mineral fibre board to ASTM C612, with factory applied vapour retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this Section).
- .4 TIAC Code C-2: Mineral fibre blanket to ASTM C553 faced with factory applied vapour retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this section).
 - .1 Mineral fibre: to ASTM C553.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: to ASTM C553.

2.3 JACKETS

- .1 TIAC Code E-2 Canvas (inside only):
 - .1 220 gm/m² cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C921.
- .2 TIAC Code E-5: Vapour retarder facing adhesives; insulation and fabric coatings; fittings mastic, fabric adhesives and mastic coatings.
 - .1 Standard of Acceptance: Foster/Childers.

2.4 ACCESSORIES

- .1 Vapour retarder lap adhesive:
 - .1 Water based, fire retardant type, compatible with insulation.
- .2 Indoor Vapour Retarder Finish:
 - .1 Vinyl emulsion type acrylic, compatible with insulation.
- .3 Insulating Cement: hydraulic setting on mineral wool, to ASTM C449.
- .4 ULC Listed Canvas Jacket:
 - .1 220 gm/m² cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C921 untreated.
- .5 Outdoor Vapour Retarder Mastic:
 - .1 Vinyl emulsion type acrylic, compatible with insulation.
 - .2 Reinforcing fabric: Fibrous glass, untreated 305 g/m².
- .6 Tape: self-adhesive, aluminum, plain reinforced, 50 75 mm wide minimum.
- .7 Contact adhesive: quick-setting.
- .8 Canvas adhesive: washable.
- .9 Tie wire: 1.5 mm stainless steel.
- .10 Banding: 19 mm wide, 0.5 mm thick stainless steel.
- .11 Facing: 25 mm stainless steel hexagonal wire mesh stitched on one face of insulation.
- .12 Fasteners: 4 mm diameter pins with 35 mm diameter clips, length to suit thickness of insulation.

3 Execution

3.1 PRE-INSTALLATION REQUIREMENTS

- .1 Pressure testing of ductwork systems complete, witnessed and certified.
- .2 Surfaces clean, dry, free from foreign material.

3.2 INSTALLATION

- .1 Install in accordance with TIAC Best Practices Guide Specification 1502, Ductwork and Plenum.
 - .1 Rigid External (Duct and Plenum):
 - .1 Hot: Apply insulation in accordance with TIAC Specification CER/1.

- .2 Cold: Apply insulation in accordance with TIAC Specification CER/2.
- .2 Flexible External (Duct and Plenum):
 - .1 Hot: Apply insulation in accordance with TIAC Specification CEF/1.
 - .2 Cold: Apply insulation in accordance with TIAC Specification CEF/2.
- .3 Finishes – Rectangular Ducts:
 - .1 Exposed ducts – general: Apply TIAC CRF/1 – Indoor.
- .4 Finishes – Round Ducts:
 - .1 Exposed ducts – general: Apply TIAC CRD/1 – Indoor.
- .2 Apply materials in accordance with manufacturers instructions and as indicated.
- .3 Use two layers with staggered joints when required nominal thickness exceeds 75 mm.
- .4 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
 - .1 Hangers, supports to be outside vapour retarder jacket.
- .5 Supports, Hangers in accordance with Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
 - .1 Apply high compressive strength insulation where insulation may be compressed by weight of ductwork.
- .6 Fasteners: At 300 mm oc in horizontal and vertical directions, minimum two rows each side.

3.3 DUCTWORK INSULATION SCHEDULE

- .1 Insulation types and thicknesses: Conform to following table:

	TIAC Code	Vapour Retarder	Thickness (mm)
Rectangular air ducts in loading bay	C-1	yes	50
Round cold air ducts in loading bay	C-2	yes	50
Round warm air ducts	C-1	no	25
Supply and exhaust ducts exposed in boiler room			none

- .1 Finishes Jackets:

- .1 Finishes shall conform to the following table:

Service	TIAC Code	TIAC Code Accessories
Indoor, exposed	E-2 or E-4	F-2

3.4 FIRE RESISTANT DUCT INSULATION INSTALLATION

- .1 Ensure all banding and pinning is in accordance with listing documents.
- .2 Grease duct require the use of 2-layers of duct insulation.

- .3 Support roads and cradles must be properly sized and spaced according to manufacturer's requirements.
- .4 Firestop systems for ductwork 'through-penetrations' in the fire separations must be installed per WH approved listing RQ-PHV/120-01 both for application details and substrate allowances.
- .5 Seams to be properly overlapped and sealed according to manufacturer's requirements.

END OF SECTION

1 General

1.1 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE).
 - .1 ASHRAE Standard 90.1-01, Energy Standard for Buildings Except Low Rise Residential Buildings (IESNA co-sponsored; ANSI approved; Continuous Maintenance Standard).
- .2 American Society for Testing and Materials International (ASTM).
 - .1 ASTM B209M-04, Standard Specification for Aluminum and Aluminum Alloy Sheet and Plate Metric.
 - .2 ASTM C335-04, Standard Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.
 - .3 ASTM C411-04, Standard Test Method for Hot Surface Performance of High Temperature Thermal Insulation.
 - .4 ASTM C449/C449M-00, Standard Specification for Mineral Fiber Hydraulic Setting Thermal Insulating and Finishing Cement.
 - .5 ASTM C533-2004, Calcium Silicate Block and Pipe Thermal Insulation.
 - .6 ASTM C547-2003, Mineral Fiber Pipe Insulation.
 - .7 ASTM C795-03, Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel.
 - .8 ASTM C921-03a, Standard Practice for Determining the Properties of Jacketing Materials for Thermal Insulation.
- .3 Canadian General Standards Board (CGSB).
 - .1 CGSB 51 GP 52Ma 89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
 - .2 CAN/CGSB 51.53 95, Poly (Vinyl Chloride) Jacketing Sheet, for Insulated Pipes, Vessels and Round Ducts.
- .4 Department of Justice Canada (Jus) Canadian Environmental Assessment Act (CEAA), 1995, c. 37.
 - .1 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
 - .2 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34.

- .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .6 Manufacturer's Trade Associations.
 - .1 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (Revised 2004).
- .7 Underwriters' Laboratories of Canada (ULC).
 - .1 CAN/ULC-S102-03, Surface Burning Characteristics of Building Materials and Assemblies.
 - .2 CAN/ULC-S701-01, Thermal Insulation, Polystyrene, Boards and Pipe Covering.
 - .3 CAN/ULC-S702-1997, Thermal Insulation, Mineral Fibre, for Buildings.
 - .4 CAN/ULC-S702.2-03, Thermal Insulation, Mineral Fibre, for Buildings, Part 2: Application Guidelines.

1.2 DEFINITIONS

- .1 For purposes of this section:
 - .1 "CONCEALED" insulated mechanical services in suspended ceilings and non-accessible chases and furred in spaces.
 - .2 "EXPOSED" will mean "not concealed" as specified.
- .2 TIAC ss:
 - .1 CRF: Code Rectangular Finish.
 - .2 CPF: Code Piping Finish.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Shop Drawings:
 - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.

- .1 Shop drawings: submit drawings stamped and signed by professional engineer registered or licensed in Province of Saskatchewan, Canada.
- .4 Samples:
 - .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit for approval: complete assembly of each type of insulation system, insulation, coating, and adhesive proposed. Mount sample on 12 mm plywood board. Affix label beneath sample indicating service.
- .5 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.

1.4 QUALITY ASSURANCE

- .1 Installer: specialist in performing work of this Section, and have at least 5 years successful experience in this size and type of project, qualified to standards of TIAC.
- .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with manufacturer's written instructions and Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
 - .3 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .2 Storage and Protection:
 - .1 Protect from weather, construction traffic.
 - .2 Protect against damage.
 - .3 Store at temperatures and conditions required by manufacturer.
- .3 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

- .2 Place excess or unused insulation and insulation accessory materials in designated containers.
- .3 Divert unused metal materials from landfill to metal recycling facility.
- .4 Dispose of unused adhesive material at official hazardous material collections site.

2 Products

2.1 FIRE AND SMOKE RATING

- .1 In accordance with CAN/ULC-S102.
 - .1 Maximum flame spread rating: 25.
 - .2 Maximum smoke developed rating: 50.

2.2 INSULATION

- .1 Mineral fibre specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24 degrees C mean temperature when tested in accordance with ASTM C335.
- .3 TIAC Code A 1: rigid moulded mineral fibre without factory applied vapour retarder jacket.
 - .1 Mineral fibre: to CAN/ULC S702.
 - .2 Maximum "k" factor: to CAN/ULC S702.
- .4 TIAC Code A 3: rigid moulded mineral fibre with factory applied vapour retarder jacket.
 - .1 Mineral fibre: to CAN/ULC S702.
 - .2 Jacket: to CGSB 51 GP 52Ma.
 - .3 Maximum "k" factor: to CAN/ULC S70.
- .5 TIAC Code A 6: flexible unicellular tubular elastomer.
 - .1 Insulation: to CAN/CGSB-51.40-95.
 - .2 Jacket: to CGSB 51 GP 52Ma.
 - .3 Maximum "k" factor: 0.04W/M.C at 24°C mean temperature.
 - .4 Certified by manufacturer: free of potential stress corrosion cracking corrodants.
- .6 TIAC Code A-2: rigid moulded calcium silicate in sections and blocks, and with special shapes to suit project requirements.
 - .1 Insulation: to ASTM C533.

- .2 Maximum "k" factor: to CAN/ULC-S702.
- .3 Design to permit periodic removal and re-installation.

2.3 INSULATION SECUREMENT

- .1 Tape: self-adhesive, aluminum, plain reinforced, 50 mm wide minimum.
- .2 Contact adhesive: quick setting.
- .3 Canvas adhesive: washable.
- .4 Tie wire: 1.5 mm diameter stainless steel.
- .5 Bands: stainless steel, 19mm wide, 0.5 mm thick.

2.4 CEMENT

- .1 Thermal insulating and finishing cement:
 - .1 Air drying on mineral wool, to ASTM C449/C449M.

2.5 VAPOUR RETARDER LAP ADHESIVE

- .1 Water based, fire retardant type, compatible with insulation.

2.6 INDOOR VAPOUR RETARDER FINISH

- .1 Vinyl emulsion type acrylic, compatible with insulation.

2.7 OUTDOOR VAPOUR RETARDER FINISH

- .1 Vinyl emulsion type acrylic, compatible with insulation.
- .2 Reinforcing fabric: fibrous glass, untreated 305 g/m².

2.8 JACKETS

- .1 TIAC Code E-3: Polyvinyl Chloride (PVC):
 - .1 One-piece moulded type and sheet to CAN/CGSB-51.53 with pre-formed shapes as required.
 - .2 Minimum service temperatures: 20°C.
 - .3 Maximum service temperature: 65°C.
 - .4 Moisture vapour transmission: 0.02 perm.
 - .5 Fastenings:
 - .1 Use solvent weld adhesive compatible with insulation to seal laps and joints.
 - .2 Tacks.

.3 Pressure sensitive vinyl tape of matching colour.

.2 TIAC Code E-6 Aluminium.

.1 To ASTM B209.

.2 Thickness: 0.50 mm sheet.

.3 Finish: smooth.

.4 Joining: longitudinal and circumferential slip joints with 50 mm laps.

.5 Fittings: 0.5 mm thick die shaped fitting covers with factory attached protective liner.

.6 Metal jacket banding and mechanical seals: stainless steel, 19 mm wide, 0.5mm thick at 300 mm spacing.

.3 TIAC Code E-6 Stainless steel.

.1 Type: 304.

.2 Thickness: 0.25 mm.

.3 Finish: smooth.

.4 Joining: longitudinal and circumferential slip joints with 50 mm laps.

.5 Fittings: 0.5 mm thick die shaped fitting covers with factory attached protective liner.

.6 Metal jacket banding and mechanical seals: stainless steel, 19 mm wide, 0.5mm thick at 300 mm spacing.

2.9 WEATHERPROOF CAULKING FOR JACKETS INSTALLED OUTDOORS

.1 Caulk all joints for outside installation.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

.1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 PRE-INSTALLATION REQUIREMENT

.1 Pressure testing of piping systems and adjacent equipment to be complete, witnessed and certified.

.2 Surfaces clean, dry, free from foreign material.

3.3 INSTALLATION

- .1 Install in accordance with TIAC National Standards. Insulate all new piping and all existing piping where existing insulation is impacted by the work.
- .2 Apply materials in accordance with manufacturer's instructions and this specification. Use two layers with staggered joints when required nominal wall thickness exceeds 75 mm.
- .3 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
 - .1 Install hangers, supports outside vapour retarder jacket.
- .4 Supports, Hangers:
 - .1 Apply high compressive strength insulation, suitable for service, at oversized saddles and shoes where insulation saddles have not been provided.

3.4 REMOVEABLE, PRE-FABRICATED, INSULATION AND ENCLOSURES

- .1 Application: at expansion joints, flanges and unions at equipment.
- .2 Design: to permit movement of expansion joint and to permit periodic removal and replacement without damage to adjacent insulation.

3.5 INSTALLATION OF ELASTOMERIC INSULATION

- .1 Insulation to remain dry. Overlaps to manufacturer's instructions. Ensure tight joints.
- .2 Provide vapour retarder as recommended by manufacturer.

3.6 PIPING INSULATION SCHEDULES

- .1 Includes valves, valve bonnets, strainers, flanges and fittings unless otherwise specified. TIAC Code: A 1.
 - .1 Securements: SS bands at 300 mm on centre.
 - .2 Seals: lap seal adhesive, lagging adhesive.
 - .3 Installation: TIAC Code: 1501 H.
- .2 TIAC Code: A 3.
 - .1 Securements: SS band at 300 mm on centre.
 - .2 Seals: VR lap seal adhesive, VR lagging adhesive.
 - .3 Installation: TIAC Code: 1501 C.

.3 TIAC Code: A 6.

- .1 Securements: to manufacturer's instructions.
- .2 Seals: lap seal adhesive, lagging adhesive.
- .3 Installation: TIAC Code: 1501-H.

.4 TIAC Code: A 2.

- .1 Insulation securements: to manufacturer's instructions.
- .2 Seals: lap seal adhesive, lagging adhesive.
- .3 Installation: TIAC Code: 1501 C.

.5 Thickness of insulation as listed in following table.

- .1 Run outs to individual units and equipment not exceeding 4000 mm long.
- .2 Do not insulate exposed runouts to plumbing fixtures, chrome plated piping, valves, fittings.

Application	Temp degrees C	TIAC code	Pipe sizes (NPS) and insulation thickness (mm)					
			Run out	to 1	1 1/4 to 2	2 1/2 to 4	5 to 6	8 & over
Steam	up to 175	A-1	38	50	65	75	90	90
Condensate	60 - 94	A-1	25	38	38	38	38	38
		A-1	25	25	25	25	25	25
Hot Water	up to 59	A-1	25	25	25	25	38	38
Domestic		A-1	25	25	25	38	38	38
Chilled Water	4 - 13	A-3/ A-2	25	25	25	25	25	25
Refrigerant		A-6	13	13	13	25	25	25

.6 Finishes:

- .1 Exposed indoors: PVC jacket.
- .2 Exposed in mechanical rooms: PVC jacket.
- .3 Concealed, indoors: canvas on valves, fittings. No further finish.
- .4 Use vapour retarder jacket on TIAC code A 3 insulation compatible with insulation.
- .5 Outdoors: water proof aluminum or SS jacket.
- .6 Finish attachments: SS bands, at 150 mm on centre. Seals: closed.
- .7 Installation: to appropriate TIAC code CRF/1 through CPF/5.

3.7 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 REFERENCES

- .1 American Society for Testing and Materials International (ASTM).
 - .1 ASTM E202-04, Standard Test Methods for Analysis of Ethylene Glycols and Propylene Glycols.

1.2 CLEANING AND START-UP OF MECHANICAL PIPING SYSTEMS

- .1 In accordance with Section 23 08 02 - Cleaning and Start-up of Mechanical Piping Systems.

1.3 HYDRONIC SYSTEMS – PERFORMANCE VERIFICATION (PV)

- .1 Perform hydronic systems performance verification after cleaning is completed and system is in full operation.
- .2 When systems are operational, perform following tests:
 - .1 Conduct full scale tests at maximum design flow rates, temperatures and pressures for continuous consecutive period of 48 hours to demonstrate compliance with design criteria.
 - .2 Verify performance of hydronic system circulating pumps as specified, recording system pressures, temperatures, fluctuations by simulating maximum design conditions and varying.
 - .1 Pump operation.
 - .2 Chiller operation.
 - .3 Pressure bypass open/closed.
 - .4 Control pressure failure.
 - .5 Minimum cooling demand.
 - .6 Maximum cooling demand.
 - .7 Chiller failure.
 - .8 Condenser fan failure.

1.4 HYDRONIC SYSTEM CAPACITY TEST

- .1 Perform hydronic system capacity tests after:
 - .1 TAB has been completed.
 - .2 Verification of operating, limit, safety controls.
 - .3 Verification of pump flow rates.

- .4 Verification of accuracy of temperature and pressure sensors and gauges.
- .2 Calculate system capacity at test conditions.
- .3 Using manufacturer's published data and calculated capacity at test conditions, extrapolate system capacity at design conditions.
- .4 When capacity test is completed, return controls and equipment status to normal operating conditions.
- .5 Submit sample of system water to approved testing agency to determine if chemical treatment is correct. Include cost.
- .6 Chilled water system capacity test:
 - .1 Perform capacity test when ambient temperature is within 10% of design conditions. Simulate design conditions by:
 - .1 Adding heat from building heating system or;
 - .2 Raising space temperature by turning off cooling and air systems for sufficient period of time before starting testing and pre-heating building to summer design space temperature (occupied) or above. Set OAD and RAD for minimum outside air if OAT is near outside design temperature or to maximum recirculation if RAT is greater than OAT. RAT to be at least 23°C minimum.
 - .2 Test procedures:
 - .1 Open fully cooling coil control valves.
 - .2 Set thermostats on associated AHU's for maximum cooling.
 - .3 Set AHU's for design maximum air flow rates.
 - .4 Set load or demand limiters on chillers to 100%.
 - .5 After system has stabilized, record chilled water, and condenser water flow rates and supply and return temperatures simultaneously.

1.5 REPORTS

- .1 In accordance with Section 01 91 31 - Commissioning (Cx) Plan: Reports, supplemented as specified herein.

1.6 TRAINING

- .1 In accordance with Section 01 91 31 - Commissioning (Cx) Plan: Training of O&M Personnel, supplemented as specified herein.

2 Products

Not Used.

3 Execution

Not Used.

END OF SECTION

1 General

1.1 SUMMARY

- .1 Section Includes:
 - .1 Procedures and cleaning solutions for cleaning mechanical piping systems.

1.2 REFERENCES

- .1 American Society for Testing and Materials International (ASTM).
 - .1 ASTM E202-00, Standard Test Methods for Analysis of Ethylene Glycols and Propylene Glycols.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).

1.3 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
- .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Instructions: submit manufacturer's installation instructions.

1.4 QUALITY ASSURANCE

- .1 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with manufacturer's written instructions and Section 01 61 00 - Common Product Requirements.

.2 Waste Management and Disposal:

- .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 CLEANING SOLUTIONS

- .1 Tri-sodium phosphate: 0.40 kg per 100 L water in system.
.2 Sodium carbonate: 0.40 kg per 100 L water in system.
.3 Low foaming detergent: 0.01 kg per 100 L water in system.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 CLEANING HYDRONIC AND STEAM SYSTEMS

- .1 Timing: now piping is in place but prior to final connection to existing, hydrostatically tested and with safety devices functional, before cleaning is carried out.
.2 Cleaning Agency:
.1 Retain qualified water treatment specialist to perform system cleaning.
.3 Install instrumentation such as flow meters, orifice plates, pitot tubes, flow metering valves only after cleaning is certified as complete by water treatment specialist.
.4 Cleaning procedures:
.1 Provide detailed report outlining proposed cleaning procedures at least 4weeks prior to proposed starting date. Report to include:
.1 Cleaning procedures, flow rates, elapsed time.
.2 Chemicals and concentrations used.
.3 Inhibitors and concentrations.
.4 Specific requirements for completion of work.
.5 Special precautions for protecting piping system materials and components.

- .6 Complete analysis of water used to ensure water will not damage systems or equipment.
- .5 Conditions at time of cleaning of systems:
 - .1 Systems: free from construction debris, dirt and other foreign material.
 - .2 Control valves: operational, fully open to ensure that terminal units can be cleaned properly.
 - .3 Strainers: clean prior to initial fill.
 - .4 Install temporary filters on pumps not equipped with permanent filters.
 - .5 Install pressure gauges on strainers to detect plugging.
- .6 Report on Completion of Cleaning:
 - .1 When cleaning is completed, submit report, complete with certificate of compliance with specifications of cleaning component supplier.
- .7 Hydronic Systems:
 - .1 Fill system with water, ensure air is vented from system.
 - .2 Fill expansion tanks 1/3 to 1/2 full, charge system with compressed air to at least 35 kPa (does not apply to diaphragm type expansion tanks).
 - .3 Use water metre to record volume of water in system to +/- 0.5%.
 - .4 Add chemicals under direct supervision of chemical treatment supplier.
 - .5 Closed loop systems: circulate system cleaner at 60°C for at least 36 h. Drain as quickly as possible. Refill with water and inhibitors. Test concentrations and adjust to recommended levels.
 - .6 Flush velocity in system mains and branches to ensure removal of debris. System pumps may be used for circulating cleaning solution provided that velocities are adequate.
 - .7 Add chemical solution to system.
 - .8 Establish circulation, raise temperature slowly to 82 °C minimum. Circulate for 12 h, ensuring flow in all circuits. Remove heat, continue to circulate until temperature is below 38°C. Drain as quickly as possible. Refill with clean water. Circulate for 6 h at design temperature. Drain and repeat procedures specified above. Flush through low point drains in system. Refill with clean water adding to sodium sulphite (test for residual sulphite).

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 REFERENCES

- .1 American National Standards Institute/American Water Works Association (ANSI/AWWA).
 - .1 ANSI/AWWA C111/A21.11-06, Standard for Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
- .2 American Society of Mechanical Engineers (ASME).
 - .1 ASME B16.1-10, Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250.
 - .2 ASME B16.3-06, Malleable Iron Threaded Fittings: Classes 150 and 300.
 - .3 ASME B16.5-09, Pipe Flanges and Flanged Fittings: NPS through NPS 24 Metric/Inch Standard.
 - .4 ASME B16.9-07, Factory-Made Wrought Butt welding Fittings.
 - .5 ASME B18.2.1-10, Square Hex, Heavy Hex and Askew Head Bolts and Hex, Heavy Hex, Hex Flange. Loded Head and Lag Screws (Inch Series).
 - .6 ASME B18.2.2-10, Nuts for General Applications: Machine Screw Nuts, Hex, Square, Hex Flange, and Coupling Nuts (Inch Series).
- .3 ASTM International.
 - .1 ASTM A47/A47M-99(2009), Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A53/A53M-10, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated Welded and Seamless.
 - .3 ASTM A536-84(2009), Standard Specification for Ductile Iron Castings.
 - .4 ASTM B61-08, Standard Specification for Steam or Valve Bronze Castings.
 - .5 ASTM B62-09, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .6 ASTM E202-10, Standard Test Method for Analysis of Ethylene Glycols and Propylene Glycols.
- .4 CSA International.
 - .1 CSA B242-05(R2011), Groove and Shoulder Type Mechanical Pipe Couplings.
 - .2 CSA W48-06, Filler Metals and Allied Materials for Metal Arc Welding.
- .5 Manufacturer's Standardization of the Valve and Fittings Industry (MSS).
 - .1 MSS-SP-67-2002a, Butterfly Valves.
 - .2 MSS-SP-70-06, Gray Iron Gate Valves, Flanged and Threaded Ends.

- .3 MSS-SP-71-05, Gray Iron Swing Check Valves Flanged and Threaded Ends.
- .4 MSS-SP-80-08, Bronze Gate, Globe, Angle and Check Valves.
- .5 MSS-SP-85-02, Gray Iron Globe and Angle Valves, Flanged and Threaded Ends.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for hydronic systems and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Saskatchewan, Canada.
 - .2 Indicate on drawings:
 - .1 Components and accessories.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for hydronic systems for incorporation into manual.
 - .1 Include special servicing requirements.

1.4 EXTRA STOCK MATERIALS

- .1 Supply spare parts as follows:
 - .1 Valve seats: 1 minimum for every ten valves, each size. Minimum one.
 - .2 Discs: 1 minimum for every ten valves, each size. Minimum one.
 - .3 Stem packing: 1 minimum for every ten valves, each size. Minimum one.
 - .4 Valve handles: 2 minimum of each size.
 - .5 Gaskets for flanges: 1 minimum for every ten flanges.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.

- .3 Storage and Handling Requirements:
 - .1 Store materials in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect hydronic systems from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.
- .5 Packaging Waste Management: remove for reuse of pallets, crates, padding, packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 PIPE

- .1 Steel pipe: to ASTM A53/A53M, Grade B, as follows:
 - .1 To 150 mm (NPS 6): Schedule 40.
 - .2 200 mm (NPS 8) and over, 10.

2.2 PIPE JOINTS

- .1 50 mm (NPS 2) and under: screwed fittings with lead-free pipe dope.
- .2 65 mm (NPS 2-1/2) and over: welding fittings and flanges to CSA W48.
- .3 Roll grooved: standard coupling to CSA B242.
- .4 Flanges: plain to ANSI/AWWA C111/ A21.11.
- .5 Orifice flanges: slip-on raised face, 2100 kPa.
- .6 Flange gaskets: to ANSI/AWWA C111/ A21.11.
- .7 Pipe thread: taper.
- .8 Bolts and nuts: to ASME B18.2.1.
- .9 Roll grooved coupling gaskets: type EPDM.

2.3 FITTINGS

- .1 Screwed fittings: malleable iron, to ASME B16.3, Class 150.
- .2 Pipe flanges and flanged fittings:
 - .1 Cast iron: to ASME B16.1, Class 125.
 - .2 Steel: to ASME B16.5.
- .3 Butt-welding fittings: steel, to ASME B16.9.
- .4 Unions: malleable iron, to ASTM A47/A47M.

- .5 Fittings for roll grooved piping: malleable iron to ASTM A47/A47M.

2.4 VALVES

- .1 Connections:
 - .1 50 mm (NPS 2) and smaller: screwed ends.
 - .2 65 mm (NPS 2-1/2) and larger: To match existing ends.
- .2 Gate valves: to MSS-SP-70.
 - .1 Application: isolating equipment, control valves, pipelines:
 - .2 50 mm (NPS 2) and under:
 - .1 Class 125, rising stem, split wedge disc, as specified Section 23 05 23.01 - Valves - Bronze.
 - .3 65 mm (NPS 2-1/2) and over:
 - .1 rising stem, split wedge disc, bronze trim , as specified Section 23 05 23.02 - Valves - Cast Iron.
 - .1 Operators: manual.
- .3 Butterfly valves: to MSS-SP-67.
 - .1 65 mm (NPS 2-1/2) and over: grooved ends: as specified Section 23 05 17 - Pipe Welding.
- .4 Globe valves: to MSS-SP- 80:
 - .1 Application: throttling, flow control, emergency bypass.
 - .2 50 mm (NPS 2) and under:
 - .1 PTFE disc , as specified Section 23 05 23.01 - Valves - Bronze.
 - .3 65 mm (NPS 2-1/2) and over:
 - .1 With bronze disc, bronze trim as specified Section 23 05 23.02 - Valves - Cast Iron.
 - .2 Operators: as indicated.
- .5 Balancing, for TAB:
 - .1 Sizes: calibrated balancing valves, as specified this section.
 - .2 50 mm (NPS 2) and under:
 - .1 Globe, with plug disc as specified Section 23 05 23.01 - Valves - Bronze.
- .6 Drain valves: Gate, Class 125, non-rising stem, solid wedge disc , as specified Section 23 05 23.01 - Valves - Bronze.
- .7 Bypass valves on gate valves 200 mm (NPS 8) and larger: 20 mm (NPS 3/4), Globe, with PTFE disc as specified Section 23 05 23.01 - Valves - Bronze.
- .8 Swing check valves: to MSS-SP-71.

- .1 50 mm (NPS 2) and under:
 - .1 Class 125, swing, with composition disc as specified Section 23 05 23.01 - Valves - Bronze.
- .2 65 mm (NPS 2-1/2) and over:
 - .1 Grooved ends as specified Section 23 05 23.02 - Valves - Cast Iron.
- .9 Silent check valves:
 - .1 NPS 2 and under:
 - .1 As specified Section 23 05 23.01 - Valves - Bronze.
 - .2 65 mm (NPS 2-1/2) and over:
 - .1 Grooved ends as specified Section 23 05 23.02 - Valves - Cast Iron
- .10 Ball valves:
 - .1 50 mm (NPS 2) and under: as specified Section 23 05 23.01 - Valves - Bronze.

3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for hydronic systems installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 PIPING INSTALLATION

- .1 Install pipework in accordance with Section 23 05 05 - Installation of Pipe Work.

3.3 CIRCUIT BALANCING VALVES

- .1 Install flow measuring stations and flow balancing valves as indicated.
- .2 Remove handwheel after installation and when TAB is complete.
- .3 Tape joints in prefabricated insulation on valves installed in chilled water mains.

3.4 CLEANING, FLUSHING AND START-UP

- .1 In accordance with Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems.

3.5 TESTING

- .1 Test system in accordance with Section 21 05 01 - Common Work Results for Mechanical.

3.6 BALANCING

- .1 Balance water systems to within plus or minus 5 % of design output.
- .2 In accordance with Section 23 05 93 - Testing, Adjusting and Balancing for HVAC for applicable procedures.

3.7 PERFORMANCE VERIFICATION

- .1 In accordance with Section 23 08 01 - Performance Verification Mechanical Piping Systems.

3.8 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

3.9 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by hydronic systems installation.

END OF SECTION

1 General

1.1 REFERENCES

- .1 American Society of Mechanical Engineers (ASME).
 - .1 ASME 04(2007), Boiler and Pressure Vessel Code.
- .2 ASTM International Inc.
 - .1 ASTM A47/A47M 99(2004), Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A278/A278M 01(2006), Standard Specification for Gray Iron Castings for Pressure Containing Parts for Temperatures up to 650 degrees F (350 degrees C).
 - .3 ASTM A516/A516M 06, Standard Specification for Pressure Vessel Plates, Carbon Steel, for Moderate and Lower Temperature Service.
 - .4 ASTM A536 84(2004), Standard Specification for Ductile Iron Castings.
 - .5 ASTM B62 02, Standard Specification for Composition Bronze or Ounce Metal Castings.
- .3 Canadian Standards Association (CSA International).
 - .1 CSA B51 03(R2003), Boiler, Pressure Vessel, and Pressure Piping Code.
 - .2 CSA B51 03(R2005), Boiler, Pressure Vessel, and Pressure Piping Code, Supplement #1.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for expansion tanks, air vents, separators, valves, and strainers and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Provide drawings stamped and signed by professional engineer registered or licensed in the Province of Saskatchewan, Canada.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit maintenance and operation data in accordance with Section 01 78 00 - Closeout Submittals.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 AUTOMATIC AIR VENT

- .1 Standard float vent: brass body and 6 mm (NPS 1/8) connection and rated at 690 kPa working pressure.

2.2 COMBINATION LOW PRESSURE RELIEF AND REDUCING VALVE

- .1 Adjustable pressure setting: 206 kPa relief, 55 to 172 kPa reducing.
- .2 Low inlet pressure check valve.
- .3 Removable strainer.

3 Execution

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 GENERAL

- .1 Run drain lines and blow off connections to terminate above nearest drain.
- .2 Maintain adequate clearance to permit service and maintenance.
- .3 Should deviations beyond allowable clearances arise, request and follow Departmental Representative's directive.
- .4 Check shop drawings for conformance of tappings for ancillaries and for equipment operating weights.

3.3 STRAINERS

- .1 Install in horizontal or down flow lines.

- .2 Ensure clearance for removal of basket.
- .3 Install ahead of each pump.
- .4 Install ahead of each automatic control valve larger than 25 mm (NPS 1) and as indicated.

3.4 AIR VENTS

- .1 Install at high points of systems.
- .2 Install gate valve on automatic air vent inlet. Run discharge to nearest drain.

3.5 PRESSURE SAFETY RELIEF VALVES

- .1 Run discharge pipe to terminate above nearest drain.

3.6 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 General

1.1 REFERENCES

- .1 American Society of Mechanical Engineers (ASME).
 - .1 ASME B16.22-01, Wrought Copper and Copper Alloy Solder Joint Pressure Fittings.
 - .2 ASME B16.24-02, Cast Copper Pipe Flanges and Flanged Fittings: Class 150, 300, 400, 600, 900, 1500 and 2500.
 - .3 ASME B16.26-88, Cast Copper Alloy Fittings for Flared Copper Tubes.
 - .4 ASME B31.5-01, Refrigeration Piping and Heat Transfer Components.
- .2 American Society for Testing and Materials International (ASTM).
 - .1 ASTM A307-04, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .2 ASTM B280-03, Standard Specification for Seamless Copper Tube for Air Conditioning and Refrigeration Field Service.
- .3 Canadian Standards Association (CSA International).
 - .1 CSA B52-99, Mechanical Refrigeration Code.
- .4 Environment Canada (EC).
 - .1 EPS 1/RA/1-96, Environmental Code of Practice for the Elimination of Fluorocarbon Emissions from Refrigeration and Air Conditioning Systems.
- .5 Health Canada / Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet for piping, fittings and equipment.
 - .2 Submit WHMIS MSDS in accordance with Section 02 81 01 - Hazardous Materials. Indicate VOC's for adhesive and solvents during application and curing.
- .3 Test Reports: submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.

- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.
- .6 Closeout submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.3 QUALITY ASSURANCE

- .1 Pre-Installation Meeting:
 - .1 Convene pre-installation meeting one week prior to beginning work of this Section and on-site installations in accordance with Section 01 32 16 -Construction Progress Schedule – Bar (GANTT) Chart.
 - .1 Verify project requirements.
 - .2 Review installation and substrate conditions.
 - .3 Co-ordination with other building sub-trades.
 - .4 Review manufacturer's installation instructions and warranty requirements.
 - .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.
 - .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
 - .3 Divert unused materials from landfill to recycling facility.

2 Products

2.1 TUBING

- .1 Processed for refrigeration installations, deoxidized, dehydrated and sealed.
 - .1 Hard copper: to ASTM B280, type ACR.
 - .2 Annealed copper: to ASTM B280, with minimum wall thickness as per CSA B52 and ASME B31.5.

2.2 FITTINGS

- .1 Service: design pressure 2070 kPa and temperature 121°C.
- .2 Brazed:
 - .1 Fittings: wrought copper to ASME B16.22.
 - .2 Joints: silver solder, 15% Ag 80% Cu-5%P or copper phosphorous, 95% Cu 5%P and non-corrosive flux.
- .3 Flanged:
 - .1 Bronze or brass, to ASME B16.24, Class 150 and Class 300.
 - .2 Gaskets: suitable for service.
 - .3 Bolts, nuts and washers: to ASTM A307, heavy series.
- .4 Flared:
 - .1 Bronze or brass, for refrigeration, to ASME B16.26.

2.3 PIPE SLEEVES

- .1 Hard copper or steel, sized to provide 6 mm clearance around between sleeve and uninsulated pipe or between sleeve and insulation.

2.4 VALVES

- .1 22 mm and under: Class 500, 3.5 Mpa, globe or angle non directional type, diaphragm, packless type, with forged brass body and bonnet, moisture proof seal for below freezing applications, brazed connections.
- .2 Over 22 mm: Class 375, 2.5 Mpa, globe or angle type, diaphragm, packless type, back seating, cap seal, with cast bronze body and bonnet, moisture proof seal for below freezing applications, brazed connections.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 GENERAL

- .1 Install in accordance with CSA B52, EPS1/RA/1 and ASME B31.5 Section 23 05 01 - Installation of Pipework.

3.3 BRAZING PROCEDURES

- .1 Bleed inert gas into pipe during brazing.
- .2 Remove valve internal parts, solenoid valve coils, sight glass.
- .3 Do not apply heat near expansion valve and bulb.

3.4 PIPING INSTALLATION

- .1 General:
 - .1 Soft annealed copper tubing: bend without crimping or constriction. Hard drawn copper tubing: do not bend. Minimize use of fittings.
- .2 Hot gas lines:
 - .1 Pitch at least 1:240 down in direction of flow to prevent oil return to compressor during operation.
 - .2 Provide trap at base of risers greater than 2400 mm high and at each 7600 mm thereafter.
 - .3 Provide inverted deep trap at top of risers.
 - .4 Provide double risers for compressors having capacity modulation.
 - .1 Large riser: install traps as specified.
 - .2 Small riser: size for 5.1 m/s at minimum load. Connect upstream of traps on large riser.

3.5 PRESSURE AND LEAK TESTING

- .1 Close valves on factory charged equipment and other equipment not designed for test pressures.
- .2 Leak test to CSA B52 before evacuation to 2MPa and 1MPa on high and low sides respectively.
- .3 Test Procedure: build pressure up to 35 kPa with refrigerant gas on high and low sides. Supplement with nitrogen to required test pressure. Test for leaks with electronic or halide detector. Repair leaks and repeat tests.

3.6 FIELD QUALITY CONTROL

- .1 Site Tests/Inspection:
 - .1 Close service valves on factory charged equipment.
- .2 Ambient temperatures to be at least 13 degrees C for at least 12 hours before and during dehydration.

-
- .3 Use copper lines of largest practical size to reduce evacuation time.
 - .4 Use two stage vacuum pump with gas ballast on 2nd stage capable of pulling 5Pa absolute and filled with dehydrated oil.
 - .5 Measure system pressure with vacuum gauge. Take readings with valve between vacuum pump and system closed.
 - .6 Triple evacuate system components containing gases other than correct refrigerant or having lost holding charge as follows:
 - .1 Twice to 14 Pa absolute and hold for 4 h.
 - .2 Break vacuum with refrigerant to 14 kPa.
 - .3 Final to 5 Pa absolute and hold for at least 12 h.
 - .4 Isolate pump from system, record vacuum and time readings until stabilization of vacuum.
 - .5 Submit test results to Construction Manager.
 - .7 Charging:
 - .1 Charge system through filter drier and charging valve on high side. Low side charging not permitted.
 - .2 With compressors off, charge only amount necessary for proper operation of system. If system pressures equalize before system is fully charged, close charging valve and start up. With unit operating, add remainder of charge to system.
 - .3 Re-purge charging line if refrigerant container is changed during charging process.
 - .8 Checks:
 - .1 Make checks and measurements as per manufacturer's operation and maintenance instructions.
 - .2 Record and report measurements to Construction Manager.
 - .9 Manufacturer's Field Services:
 - .1 Have manufacturer of products, supplied under this Section, review Work involved in the handling, installation/application, protection and cleaning, of its products and submit written reports, in acceptable format, to verify compliance of Work with Contract.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.

- .3 Schedule site visits, to review Work, at stages listed:
 - .1 After delivery and storage of products, and when preparatory Work, or other Work, on which the Work of this Section depends, is complete but before installation begins.
 - .2 Once during progress of Work at 50% complete.
 - .3 Upon completion of the Work, after cleaning is carried out.
 - .4 Obtain reports, within 3 days of review, and submit, immediately, to Construction Manager.

3.7 DEMONSTRATION

- .1 Instructions:
 - .1 Post instructions in frame with glass cover in accordance with Section 01 78 00 - Closeout Submittals and CSA B52. Provide a copy of instruction in the Operation and Maintenance Manual.

3.8 CLEANING

- .1 Perform cleaning operations as specified in Section 21 05 01 - Common Work Results for Mechanical and in accordance with manufacturer's recommendations.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 SUMMARY

.1 Section Includes:

.1 Materials and installation of low-pressure metallic ductwork, joints and accessories.

.2 Related Sections:

.1 Section 01 33 00 - Submittal Procedures.

.2 Section 01 35 30 - Health and Safety Requirements.

.3 Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.

1.2 REFERENCES

.1 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).

.2 American Society for Testing and Materials International, (ASTM).

.1 ASTM A480/A480M-03c, Standard Specification for General Requirements for Flat Rolled Stainless and Heat Resisting Steel Plate, Sheet and Strip.

.2 ASTM A635/A635M-02, Standard Specification for Steel, Sheet and Strip, Heavy Thickness Coils, Carbon, Hot Rolled.

.3 ASTM A653/A653M-03, Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc Iron Alloy Coated (Galvannealed) by the Hot Dip Process.

.3 Department of Justice Canada (Jus).

.1 Canadian Environmental Protection Act (CEPA), 1999, c. 33.

.4 Health Canada/Workplace Hazardous Materials Information System (WHMIS).

.1 Material Safety Data Sheets (MSDS).

.5 National Fire Protection Association (NFPA).

.1 NFPA 90A-02, Standard for the Installation of Air-Conditioning and Ventilating Systems.

.2 NFPA 90B-02, Standard for the Installation of Warm Air Heating and Air-Conditioning Systems.

.6 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).

.1 SMACNA HVAC Duct Construction Standards - Metal and Flexible, 2nd Edition 1995 and Addendum No. 1, 1997.

.2 SMACNA HVAC Air Duct Leakage Test Manual, 1985, 1st Edition.

.3 IAQ Guideline for Occupied Buildings Under Construction 1995, 1st Edition.

.7 Transport Canada (TC).

.1 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34.

1.3 SUBMITTALS

.1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.

1.4 QUALITY ASSURANCE

.1 Certification of Ratings:

.1 Catalogue or published ratings shall be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.

.2 Health and Safety:

.1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

.3 Indoor Air Quality (IAQ) Management Plan.

.1 During construction meet or exceed the requirements of SMACNA IAQ Guideline for Occupied Buildings under Construction.

1.5 DELIVERY, STORAGE AND HANDLING

.1 Protect on site stored or installed absorptive material from moisture damage.

.2 Waste Management and Disposal:

.1 Separate waste materials for reuse and recycling in accordance with Section 01 47 19 - Construction/Demolition Waste Management and Disposal.

.2 Remove from site and dispose of packaging materials at appropriate recycling facilities.

.3 Collect and separate for disposal paper, plastic, and corrugated cardboard packaging material for recycling in accordance with Waste Management Plan.

.4 Separate for reuse and recycling and place in designated containers Steel, Metal, and Plastic waste in accordance with Waste Management Plan.

.5 Place materials defined as hazardous or toxic in designated containers.

.6 Handle and dispose of hazardous materials in accordance with Regional and Municipal regulations.

.7 Fold up metal banding, flatten and place in designated area for recycling.

2 Products

2.1 SEAL CLASSIFICATION

- .1 Classification as follows:

Maximum Pressure Pa	SMACNA Seal Class
500	C
250	C
125	C
125	Unsealed

- .2 Seal classification:

- .1 Class A: longitudinal seams, transverse joints, duct wall penetrations and connections made airtight with sealant and tape.
- .2 Class B: longitudinal seams, transverse joints and connections made airtight with sealant, tape, or combination thereof.
- .3 Class C: transverse joints and connections made air tight with sealant, tape, or combination thereof. Longitudinal seams unsealed.
- .4 Unsealed seams and joints.

2.2 SEALANT

- .1 Sealant: oil resistant, water borne, polymer type flame resistant duct sealant. Temperature range of -30°C to +93°C.

2.3 TAPE

- .1 Tape: polyvinyl treated, open weave fiberglass tape, 50 mm wide.

2.4 DUCT LEAKAGE

- .1 In accordance with SMACNA HVAC Air Duct Leakage Test Manual.

2.5 FITTINGS

- .1 Fabrication: to SMACNA.
- .2 Radiused elbows.
 - .1 Rectangular: standard radius. Centreline radius: 1.5 times width of duct.
 - .2 Round: five piece. Centreline radius: 1.5 times diameter.

- .3 Mitred elbows, rectangular:
 - .1 To 400mm: with single thickness turning vanes.
 - .2 Over 400mm: with double thickness turning vanes.
- .4 Branches:
 - .1 Rectangular main and branch: with radius on branch 1.5 times width of duct 45 degrees entry on branch.
 - .2 Round main and branch: enter main duct at 45 degrees with conical connection.
 - .3 Provide volume control damper in branch duct near connection to main duct.
 - .4 Main duct branches: with splitter damper.
- .5 Transitions:
 - .1 Diverging: 20 degrees maximum included angle.
 - .2 Converging: 30 degrees maximum included angle.
- .6 Offsets:
 - .1 Full radiused elbows.
- .7 Obstruction deflectors: maintain full cross sectional area.
 - .1 Maximum included angles: as for transitions.

2.6 FIRE STOPPING

- .1 Retaining angles around duct, on both sides of fire separation.
- .2 Fire stopping material and installation must not distort duct.

2.7 GALVANIZED STEEL

- .1 Lock forming quality: to ASTM A653/A653M, Z90 zinc coating.
- .2 Thickness, fabrication and reinforcement: to ASHRAE and SMACNA Standards.
- .3 Joints: to ASHRAE or SMACNA Standards.

2.8 STAINLESS STEEL

- .1 To ASTM A480/A480M, Type 304.
- .2 Finish: 2B
- .3 Thickness, fabrication and reinforcement to: SMACNA.

- .4 Joints: to SMACNA be continuous inert gas welded.
 - .1 Acceptable material: 304 grade stainless steel.

2.9 HANGERS AND SUPPORTS

- .1 Hangers and Supports: in accordance with Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
 - .1 Strap hangers: of same material as duct but next sheet metal thickness heavier than duct.
 - .1 Maximum size duct supported by strap hanger: 500.
 - .2 Hanger configuration: to ASHRAE and SMACNA.
 - .3 Hangers: galvanized steel angle with galvanized steel rods to ASHRAE and SMACNA as following table:

Duct Size (mm)	Angle Size (mm)	Rod Size (mm)
up to 750	25 x 25 x 3	6
751 to 1050	40 x 40 x 3	6
1051 to 1500	40 x 40 x 3	10
1501 to 2100	50 x 50 x 3	10
2101 to 2400	50 x 50 x 5	10
2401 and over	50 x 50 x 6	10

- .4 Upper hanger attachments:
 - .1 For concrete: manufactured concrete inserts.
 - .2 For steel joist: manufactured joist clamp.
 - .3 For steel beams: manufactured beam clamps:

3 Execution

3.1 GENERAL

- .1 Do work in accordance with NFPA 90A, NFPA 90B, ASHRAE and SMACNA, whichever is applicable.
- .2 Do not break continuity of insulation vapour barrier with hangers or rods.
 - .1 Insulate strap hangers 100 mm beyond insulated duct. Ensure diffuser is fully seated.
- .3 Support risers in accordance with ASHRAE and SMACNA.

- .4 Install breakaway joints in ductwork on sides of fire separation.
- .5 Install proprietary manufactured flanged duct joints in accordance with manufacturer's instructions.
- .6 Manufacture duct in lengths and diameter to accommodate installation of acoustic duct lining.

3.2 HANGERS

- .1 Strap hangers: install in accordance with SMACNA Standards.
- .2 Angle hangers: complete with locking nuts and washers.
- .3 Hanger spacing: in accordance with ASHRAE SMACNA as follows:

Duct Size (mm)	Spacing (mm)
to 1500	3000
1501 and over	2500

3.3 WATERTIGHT DUCT

- .1 Provide watertight duct for:
 - .1 Fresh air intake.
 - .2 As indicated.
- .2 Form bottom of horizontal duct without longitudinal seams.
 - .1 Solder joints of bottom and side sheets.
 - .2 Seal other joints with duct sealer.
- .3 Slope horizontal branch ductwork down towards the main and slope header ducts down toward risers.
- .4 Fit base of riser with 150 mm deep drain sump and 32 mm drain connected, with deep seal trap and valve and discharging to as indicated.

3.4 SEALING AND TAPING

- .1 Apply sealant to outside of joint to manufacturer's recommendations.
- .2 Bed tape in sealant and recoat with minimum of one coat of sealant to manufacturers recommendations.

3.5 LEAKAGE TESTS

- .1 Refer to Section 23 05 93 - Testing, Adjusting, and Balancing for HVAC.
- .2 In accordance with SMACNA HVAC Duct Leakage Test Manual.
- .3 Do leakage tests in sections.
- .4 Make trial leakage tests as instructed to demonstrate workmanship.
- .5 Do not install additional ductwork until trial test has been passed.
- .6 Test section minimum of 30 m long with not less than three branch takeoffs and two 90 degrees elbows.
- .7 Complete test before performance insulation or concealment Work.

END OF SECTION

1 General

1.1 SUMMARY

.1 Section Includes:

- .1 Operating dampers for mechanical forced air ventilation and air conditioning systems.

1.2 REFERENCES

.1 American Society for Testing and Materials International (ASTM).

- .1 ASTM A653/A653M 04a, Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc Iron Alloy Coated (Galvannealed) by Hot Dip Process.

.2 Health Canada/Workplace Hazardous Materials Information System (WHMIS).

- .1 Material Safety Data Sheets (MSDS).

1.3 SUBMITTALS

.1 Product Data:

- .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.

.2 Indicate the following:

- .1 Performance data.

.3 Instructions:

- .1 Submit manufacturer's installation instructions and maintenance data.

.2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.

- .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

.2 Closeout Submittals.

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 QUALITY ASSURANCE

- .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

.2 Certificates:

- .1 Catalogue or published ratings those obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency.

1.5 DELIVERY, STORAGE AND HANDLING

.1 Packing, shipping, handling and unloading:

- .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.

- .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

.2 Waste Management and Disposal:

- .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 THERMALLY INSULATED DAMPERS WITH THERMALLY BROKEN FRAMES

- .1 Extruded aluminum damper frame shall be 2.03 mm in thickness. Damper frame to be 101.6 mm deep.
- .2 Entire frame shall be thermally broken by means of polyurethane resin pockets, complete with thermal cuts.
- .3 Blades to be extruded aluminum profiles, internally insulated with expanded polyurethane foam and shall be thermally broken. Complete blade shall have an insulating factor of R-2.29.
- .4 Bearings are to be composed of a Celcon inner bearing fixed to a 11.11 mm aluminum hexagon blade pin, rotating within a polycarbonate outer bearing inserted in the frame,(no metal-to-metal or metal-to-plastic contact).
- .5 Linkage hardware shall be installed in the frame side and constructed of aluminum and corrosion-resistant, zinc-plated steel, complete with cup-point trunnion screws for a slip-proof grip.
- .6 Dampers shall be available with either opposed blade action or parallel blade action.
- .7 Leakage shall not exceed 15.2 l/s/m² against 250 Pa w.g. differential static pressure, 25 l/s/m² against 1000 Pa w.g. differential static pressure at -40°C.

- .8 Pressure drop of a fully open 1220 mm x 1220 mm damper shall not exceed 7 Pa at 5.08 m/s.
- .9 Dampers shall be made to size required without blanking off free area.
- .10 Dampers shall be available as "Flanged to Duct" mounting type.
- .11 Standard of Acceptance.
 - .1 Standard Cold Temperature Dampers.
 - .1 Dampers are to be designed for operation in temperatures ranging between -40°C and 85°C.
 - .2 Blade and frame seals shall be of extruded silicone and be secured in an integral slot within the aluminum extrusions.
 - .3 Standard cold temperature dampers shall be TAMCO Series 9000 BF.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install where indicated.
- .2 Install in accordance with recommendations of SMACNA and manufacturer's instructions.
- .3 Seal multiple damper modules with silicon sealant.
- .4 Intermediate or tubular steel structural support is required to resist applied pressure loads for dampers that consist of two or more sections in both height and width.
- .5 Multiple damper modules shall be individually operated by a damper operator or connected by means of Jack shafts arrangements supplied by the manufacturer.
- .6 Co-ordinate the damper arrangements with the controls sub trade.
- .7 Install access door adjacent to each damper. See Section 23 33 00 - Air Duct Accessories.
- .8 Ensure dampers are observable and accessible.
- .9 Upon system start-up, ensure that dampers operate properly.

- .10 Back draft dampers with dimensions greater than maximum section size shall be manufactured in multiple sections. Multiple sections are not interlinked or connected. To install, each section must be individually fastened to a structural frame prepared on site.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 SUMMARY

1.2 REFERENCES

- .1 American National Standards Institute/National Fire Protection Association (ANSI/NFPA).
 - .1 ANSI/NFPA 90A-2002, Standard for the Installation of Air Conditioning and Ventilating Systems.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .3 Underwriters Laboratories of Canada (ULC).
 - .1 CAN4-S112-M1990, Fire Test of Fire Damper Assemblies.
 - .2 CAN4-S112.2-M84, Standard Method of Fire Test of Ceiling Firestop Flap Assemblies.
 - .3 ULC-S505-1974, Fusible Links for Fire Protection Service.

1.3 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .2 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
 - .3 Indicate the following:
 - .1 Fire dampers.
 - .2 Smoke dampers.
 - .3 Fire stop flaps.
 - .4 Operators.
 - .5 Fusible links.
 - .6 Design details of break-away joints.
- .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

- .2 Instructions: submit manufacturer's installation instructions.
- .3 Closeout Submittals:
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 QUALITY ASSURANCE

- .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.
- .2 Certificates:
 - .1 Catalogue or published ratings those obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards.

1.5 MAINTENANCE

- .1 Extra Materials:
 - .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
 - .2 Provide following:
 - .1 6 fusible links of each type.

1.6 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

2 Products

2.1 FIRE DAMPERS

- .1 Fire dampers: arrangement Type A B C, listed and bear label of ULC, meet requirements of provincial fire authority, Fire Commissioner of Canada (FCC) CFFM and ANSI/NFPA 90A and authorities having jurisdiction. Fire damper assemblies fire tested in accordance with CAN4-S112.

- .2 Mild steel, factory fabricated for fire rating requirement to maintain integrity of fire wall and/or fire separation.
 - .1 Fire dampers: 1-1/2 hour fire rated unless otherwise indicated.
 - .2 Fire dampers: automatic operating type and have dynamic rating suitable for maximum air velocity and pressure differential to which it will be subjected.
- .3 Top hinged: offset single damper, round or square; multi-blade hinged or interlocking type; sized to maintain full duct cross section as indicated.
- .4 Fusible link actuated, weighted to close and lock in closed position when released or having negator-spring-closing operator for multi-leaf type or roll door type in horizontal position with vertical air flow.
- .5 40 x 40 x 3 mm retaining angle iron frame, on full perimeter of fire damper, on both sides of fire separation being pierced.
- .6 Equip fire dampers with steel sleeve or frame installed disruption ductwork or impair damper operation.
- .7 Equip sleeves or frames with perimeter mounting angles attached on both sides of wall or floor opening. Construct ductwork in fire-rated floor-ceiling or roof-ceiling assembly systems with air ducts that pierce ceiling to conform with ULC.
- .8 Design and construct dampers to not reduce duct or air transfer opening cross-sectional area.
- .9 Dampers shall be installed so that the centerline of the damper depth or thickness is located in the centerline of the wall, partition of floor slab depth or thickness.
- .10 Unless otherwise indicated, the installation details given in SMACNA Install Fire Damp HVAC and in manufacturer's instructions for fire dampers shall be followed.

2.2 FIRE STOP FLAPS

- .1 Fire smoke flaps: ULC listed and labelled and fire tested in accordance with CAN4-S112.2.
- .2 Construct of minimum 1.5 mm thick sheet steel with 1.6 mm thick non-asbestos ULC listed insulation and corrosion-resistant pins and hinges.
- .3 Flaps held open with fusible link conforming to ULC-S505 and close at 74 degrees C.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install in accordance with ANSI/NFPA 90A and in accordance with conditions of ULC listing.
- .2 Maintain integrity of fire separation.
- .3 After completion and prior to concealment obtain approvals of complete installation from authority having jurisdiction.
- .4 Install access door adjacent to each damper. See Section 23 33 00 - Air Duct Accessories.
- .5 Co-ordinate with installer of firestopping.
- .6 Ensure access doors/panels, fusible links, damper operators are easily observed and accessible.
- .7 Install break-away joints of approved design on each side of fire separation.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 SUMMARY

.1 Section Includes:

- .1 Fans, motors, accessories and hardware for commercial use.

1.2 REFERENCES

.1 Air Conditioning and Mechanical Contractors (AMCA).

- .1 AMCA Publication 99-2003, Standards Handbook.
- .2 AMCA 300-1996, Reverberant Room Method for Sound Testing of Fans.
- .3 AMCA 301-1990, Methods for Calculating Fan Sound Ratings from Laboratory Test Data.

.2 American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME).

- .1 ANSI/AMCA 210 1999, Laboratory Methods of Testing Fans for Aerodynamic Performance Rating.

.3 Canadian General Standards Board (CGSB).

- .1 CAN/CGSB 1.181-99, Ready-Mixed Organic Zinc-Rich Coating.

.4 Health Canada/Workplace Hazardous Materials Information System (WHMIS).

- .1 Material Safety Data Sheets (MSDS).

1.3 SYSTEM DESCRIPTION

.1 Performance Requirements:

- .1 Catalogued or published ratings for manufactured items: obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards in force.
- .2 Capacity: flow rate, total pressure, W, efficiency, revolutions per minute, power, model, size, sound power data and as indicated on schedule.
- .3 Fans: statically and dynamically balanced, constructed in conformity with AMCA 99.
- .4 Sound ratings: comply with AMCA 301, tested to AMCA 300.
- .5 Performance ratings: based on tests performed in accordance with ANSI/AMCA 210.

1.4 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
- .2 Shop Drawings:
 - .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Shop Drawings: submit drawings stamped and signed by professional engineer registered or licensed in Province of Saskatchewan, Canada.
- .3 Provide:
 - .1 Fan performance curves showing point of operation, kW and efficiency.
 - .2 Sound rating data at point of operation.
- .4 Indicate:
 - .1 Motors, sheaves, bearings, shaft details.
 - .2 Minimum performance achievable with variable speed controllers.
- .5 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .6 Closeout Submittals:
 - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.5 QUALITY ASSURANCE

- .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.6 MAINTENANCE

.1 Extra Materials:

.1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.

.1 Spare parts to include:

.1 Matched sets of belts.

.2 Furnish list of individual manufacturer's recommended spare parts for equipment, include:

.1 Bearings and seals.

.2 Addresses of suppliers.

.3 List of specialized tools necessary for adjusting, repairing or replacing.

1.7 DELIVERY, STORAGE AND HANDLING

.1 Packing, shipping, handling and unloading:

.1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.

.2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

.2 Waste Management and Disposal:

.1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 FANS GENERAL

.1 Capacity: flow rate, external static pressure, BHP/kW, efficiency, revolutions per minute, motor power, model, size, sound power data and as indicated on schedule.

.2 Fans: statically and dynamically balanced, construction in conformity with AMCA 99.

.3 Sound ratings: comply with AMCA 301, tested to AMCA 300.

.4 Performance ratings: based on tests performed in accordance with ANSI/AMCA 210 and ANSI/ASHRAE 51. Unit shall bear AMCA certified rating seal.

.5 Motors:

.1 Provide motors to all fans as required.

- .6 Accessories and hardware: matched sets of V-belt drives, adjustable motor bases, belt guards, coupling guards fan inlet and/or outlet safety screens as required, inlet/outlet dampers and vanes as indicated.
- .7 Factory primed before assembly in colour standard to manufacturer.
- .8 Bearing lubrication systems plus extension lubrication tubes where bearings are not easily accessible.
- .9 Vibration isolations as required.
- .10 Fans shall be capable of accommodating static pressure variations of +10% with no objectionable operating characteristics.
- .11 All belt drives shall have adjustable sheaves.
- .12 Provide electrical disconnect on each fan.

2.2 ROOF DOWNBLAST CENTRIFUGAL FANS

- .1 General:
 - .1 Downblast fan for roof mounted applications.
 - .2 Belt driven.
- .2 Fan wheel:
 - .1 Aluminum construction.
 - .2 Backward inclined blades.
- .3 Bearings:
 - .1 Heavy duty, regreasable in pillow blocks.
 - .2 Selectred with L1Ø life in excess of 100,000 hours at maximum speed.
- .4 Housing:
 - .1 Heavy gauge aluminum with rigid internal support structure.
- .5 Motor and Electrical:
 - .1 Motor type: TEFC.
 - .2 Inverter duty motor.
 - .3 Mounted on vibration isolators out of air stream.
 - .4 Provide variable frequency drive to modulate fan rpm complete with all standard features and capabilities. Variable frequency drive is to be controlled by the ECMS.
 - .5 Provide line reactor and load filter to be installed by Division 26.

- .6 Accessories:
 - .1 Aluminum bird screen.
 - .2 Hinge kit with restraint cables.
- .7 Performance data:
 - .1 Refer to the schedule on the drawings.
- .8 Acceptable products:
 - .1 Cook, Penn Barry, Twin city, Greenheck.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 FAN INSTALLATION

- .1 Install fans as indicated, complete with resilient mountings flexible electrical leads and flexible connections.
- .2 Provide sheaves and belts required for final air balance.
- .3 Bearings and extension tubes to be easily accessible.
- .4 Access doors and access panels to be easily accessible.

3.3 ANCHOR BOLTS AND TEMPLATES

- .1 Size anchor bolts to withstand seismic acceleration and velocity forces as specified.

3.4 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 SUMMARY

.1 Section Includes:

- .1 Supply, return and exhaust grilles and registers, diffusers and linear grilles, for commercial and residential use.

1.2 SYSTEM DESCRIPTION

.1 Performance Requirements:

- .1 Catalogued or published ratings for manufactured items: obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards.

1.3 SUBMITTALS

.1 Product Data:

- .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.

.2 Samples:

- .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.

.3 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.

- .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

1.4 QUALITY ASSURANCE

- .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.5 DELIVERY, STORAGE AND HANDLING

.1 Packing, shipping, handling and unloading:

- .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.

- .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.

.2 Waste Management and Disposal:

- .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

1.6 MAINTENANCE

.1 Extra Materials:

- .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Include:
- .1 Keys for volume control adjustment.
- .2 Keys for air flow pattern adjustment.

2 Products

2.1 GENERAL

- .1 To meet capacity, pressure drop, terminal velocity, throw, noise level, neck velocity as indicated.
- .2 Frames:
- .1 Full perimeter gaskets.
- .2 Plaster frames where set into plaster or gypsum board and as specified.
- .3 Concealed fasteners.
- .3 Concealed manual volume control damper operators.
- .4 Colour: standard as directed by Departmental Representative.

2.2 MANUFACTURED UNITS

- .1 Grilles, registers and diffusers of same generic type, products of one manufacturer.
- .2 Steel, 32mm Border, Single Degree Deflection, Horizontal face bars, white finish.
- .3 Standard of Acceptance: E. H. Price, Nailor, Krueger.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install in accordance with manufacturer's instructions.
- .2 Install with oval head stainless steel screws in countersunk holes where fastenings are visible.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 SUMMARY

.1 Section Includes:

- .1 Mechanical louvers; intakes; vents; and reinforcement and bracing for air vents, intakes and gooseneck hoods.

1.2 REFERENCES

.1 American National Standards Institute (ANSI)/ National Fire Protection Association (NFPA).

- .1 ANSI/NFPA 96 04, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.

.2 American Society for Testing and Materials International (ASTM).

- .1 ASTM E90 04, Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.

.3 Health Canada/Workplace Hazardous Materials Information System (WHMIS).

- .1 Material Safety Data Sheets (MSDS).

.4 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).

.5 Society of Automotive Engineers (SAE).

1.3 SYSTEM DESCRIPTION

.1 Performance Requirements:

- .1 Catalogued or published ratings for manufactured items: obtained from tests carried out by manufacturer or those ordered by manufacturer from independent testing agency signifying adherence to codes and standards.

1.4 SUBMITTALS

.1 Product Data:

- .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.

- .2 Indicate the following:
 - .1 Pressure drop.
 - .2 Face area.
 - .3 Free area.
- .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .3 Test Reports:
 - .1 Submit certified data from independent laboratory substantiating acoustic and aerodynamic performance to ASTM E90.

1.5 QUALITY ASSURANCE

- .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.6 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 LOUVRED PENTHOUSE

- .1 Construction: 6063-T5 Extruded Aluminum, welded with exposed joints ground flush and smooth.
- .2 Support: Extruded aluminum boxed corners.
- .3 Curb cap: Extruded aluminum angle, boxed corners.
- .4 Roof: Sheet aluminum.

- .5 Blade: 100 mm Deep, 12 gauge extruded aluminum set at 45°, 114 mm blade spacing, supports at 1220 mm o/c.
- .6 Screen: 13 mm mesh, wire aluminum birdscreen on inside face of louvres in formed U-frame.
- .7 Finish: Factory applied enamel. Colour to Project manager's approval.
- .8 Maximum 40 Pa pressure drop and 3 g per m² water penetration at design airflow.
- .9 Product of acceptance: Ventex, Westvent, E.H. Price.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 In accordance with manufacturer's and SMACNA recommendations.
- .2 Reinforce and brace as indicated.
- .3 Anchor securely into opening. Seal with caulking to ensure weather tightness.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 General

1.1 REFERENCES

- .1 Air Conditioning, Heating and Refrigeration Institute (AHRI).
 - .1 AHRI 550/590-03, Performance Rating of Water Chilling Packages Using the Vapor Compression Cycle.
- .2 CSA International.
 - .1 CSA B52 05 SMART, Mechanical Refrigeration Code.
- .3 Environment Canada, (EC)/Environmental Protection Services (EPS).
 - .1 EPS 1/RA/2 1996, Environmental Code of Practice for Elimination of Fluorocarbons Emissions from Refrigeration and Air Conditioning Systems.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for scroll modular water chillers and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Saskatchewan, Canada.
 - .2 Indicate:
 - .1 Equipment including connections, piping and fittings, valves, strainers, control assemblies and ancillaries, identifying factory and field assembled.
 - .2 Wiring as assembled and schematics.
 - .3 Dimensions, construction details, recommended installation and support, mounting bolt hole sizes and locations and point loads.
 - .4 Type of refrigerant used.
 - .3 Construction Waste Management:
 - .1 Submit project Waste Management Plan highlighting recycling and salvage requirements.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for scroll modular water chillers for incorporation into manual.
- .3 Data to include:
 - .1 Description of equipment giving manufacturers name, model type and year, capacity and serial numbers.
 - .2 Provide part load performance curves.
 - .3 Details on operation, servicing and maintenance.
 - .4 Recommended spare parts list.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect scroll modular water chillers from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Packaging Waste Management: remove or reuse as specified in Construction Waste Management Plan in accordance with Section 01 74 19 - Construction/Demolition Waste Management and Disposal.

2 Products

2.1 GENERAL

- .1 Provide complete air cooled scroll type modular chiller package including: compressor; evaporator; condenser, motor and motor starter; electrical disconnects, controls; control centre; piping; wiring; refrigeration and oil change; ready for connection to chilled water circuit, interlocks, and electric power source, installed in welded steel frame with heavy gauge panels finished to manufacturers standard.
- .2 Chiller package is to consist of four (4) chiller modules with a total of 8 compressors.

- .3 Provide two (2) individual condenser units each with connections for four (4) refrigeration circuits.
- .4 Acceptable manufacturer: Engineered Air, Multistack, Climacool.

2.2 CAPACITY

- .1 Certified ratings based on AHRI 550/590:
 - .1 340 kW (minimum), when cooling 15.75 L/s of water from 12.2 degrees C to 6.7°C.
 - .2 Air cooled condenser supplied with 35 degrees C entering air design ambient temperature and minimum ambient temperature of 5 degrees C entering air.
 - .3 Fouling resistance coefficient: 0.000045 m²K/W.
 - .4 Refrigerant: R-410A.

2.3 COMPRESSOR

- .1 Hermetic orbital scroll design with crankcase oil heater and suction strainer.
- .2 Compressor motor is to be refrigerant gas cooled, high torque, hermetic induction type, and two-pole, with inherent thermal protection on all three phases.
- .3 The lead compressor is to be fitted with an inverter-duty motor and variable frequency drive.
- .4 Provide nameplate to show capacity at design temperature, type of refrigerant used and total weight in system.
- .5 Provide integral disconnect for each compressor.

2.4 EVAPORATOR

- .1 Direct expansion type with stainless steel plates brazed together.

2.5 CONDENSER

- .1 Separate outdoor fluid cooler with copper tubes, aluminum fins, and low sound condensing fans.
- .2 Sound levels for individual condensing fans to be maximum 76.5 dBa at 915 mm.
- .3 Casing to be 18ga with lever handles for all access doors.
- .4 Capacity to match chiller heat rejection.
- .5 Dimensions: as indicated.

.6 Fans:

- .1 Drive: Direct Drive.
- .2 Blades: Sickle blade profile with serrated trailing edge and winglets on the blade outer edge.
- .3 Over temperature protection.
- .4 Maximum operating temperature of 60°C.
- .5 Maintenance-free, sealed bearings.

.7 Provide single point connection and integral disconnect for each condenser.

2.6 ACCESSORIES

- .1 Water isolation valves.
- .2 Wye-strainer for evaporator inlet.
- .3 Vibration isolators.
- .4 Disconnect switches for compressors and condensers.
- .5 Phase loss protection.

2.7 CONTROL CENTRE

- .1 The control panel are to contain a microprocessor controller providing operating and equipment protection controls plus motor starting equipment, factory wired, operationally tested, and ready for operation.
- .2 Controller components are to include:
 - .1 Control transformer with primary and secondary fusing.
 - .2 Microprocessor transformers with integral fusing.
 - .3 Compressor contactors.
 - .4 Single-point wiring arrangement.
 - .5 Switches for each circuit pump-down and unit control power.
 - .6 Variable frequency drive for lead compressor.
- .3 All components are to be pre-wired to compressors, safety controls and sensors. The control panel shall have a hinged tool-locked door.
- .4 Control panels are to include a door mounted keypad with an 8 line by 22 character screen, chilled water set-point adjustment, anti-cycle timer, and digital display with water temperature and set-point, operating temperatures and pressures, and diagnostic messages.

- .5 The unit is to be equipped with a factory-installed BAS communication module. The information communicated between the BAS and the factory mounted unit controllers is to include the reading and writing of data to allow unit monitoring, control and alarm notification as specified in the unit sequence of operation and the unit points list.
- .6 The controller shall contain the following features as a minimum:
 - .1 Equipment Protection: The unit shall be protected by alarms that shut the unit down and require manual reset to restore unit operation. Shutdown alarms shall activate an alarm signal.
 - .2 Shutdown Alarms:
 - .1 No evaporator water flow.
 - .2 Low evaporator pressure.
 - .3 High condenser pressure.
 - .3 Motor protection system.
 - .4 Phase voltage protection .
 - .5 Evaporator freeze protection.
 - .6 Digital Inputs .
 - .1 Unit off switch.
 - .2 Remote start/stop.
 - .3 Flow switch.
 - .4 Motor protection.
 - .7 Digital Outputs.
 - .1 Evaporator pump; field wired, starts pump when unit is set to start.
 - .2 Air-cooled condenser; field wired, condenser when unit is set to start.
 - .8 Master Controller – The individual chiller units in the system can be controlled by a master controller capable of controlling up to 12 individual units.
 - .1 The master controller is to control the staging of the individual units/circuits as well as compressor rotation (FIFO).
 - .2 Master controller can shut down any individual units while keeping the remaining units operational.
 - .3 The master controller is to use a colour graphic touch screen interface.
 - .4 The master controller is and will be connected to each individual unit via a quick disconnect wire.
 - .5 Touch screen is to allow operator to shift from screen to screen to see the operating status of compressors and readings of all pressures and temperatures on each module.

3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrates previously installed under other Sections or Contracts are acceptable for scroll modular water chiller installation in accordance with manufacturer's written instructions.

3.2 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, product catalogue installation instructions, product carton installation instructions, and data sheets.

3.3 GENERAL

- .1 Provide appropriate protection apparatus.
- .2 Install unit as indicated, to manufacturer's recommendations, and in accordance with EPS 1/RA/2.
- .3 Ensure adequate clearances for servicing and maintenance.
- .4 Manufacturer to approve installation, to supervise start-up and to instruct operators. Include 3 days per unit.
- .5 Adjust and level chiller in alignment on supports.
- .6 Coordinate electrical installation with electrical contractor.
- .7 Coordinate controls with control contractor.
- .8 Provide all appurtenances required to ensure a fully operational and functional chiller.

3.4 CONTROL NARRATIVE

- .1 The modular chiller control system is to stage the compressors based on the chilled water set-point temperature.
 - .1 The compressor connected to the VFD is to be the lead compressor and is to be modulated during all stages of cooling and maintain the chilled water set point temperature.
- .2 Equipment protection devices controlled by the modular chiller control system include:
 - .1 Motor protection.
 - .2 High pressure.
 - .3 Loss of refrigerant.

- .4 Loss of water flow.
- .5 Freeze protection.
- .6 Low refrigerant pressure. The following features and functions shall be included:
 - .3 Each module is to have a full controller capable to control the module without the master controller.
 - .4 Each module is to have temperature sensors (high and low side pressure sensors) on each water connection mounted in a thermowell. Temperature and pressure reading are to be displayed on the door mounted screen.
 - .5 Compressor minimum and maximum run time, dead band setting and dead band time is to be set and adjustable.
 - .6 Compressor run hours and number of starts are to be recorded for each compressor.
 - .7 Controller to contain an alarm log. Each alarm is to create a log item showing:
 - .1 Time and date of occurrence.
 - .2 Description of alarm.
 - .3 All pressures and temperatures on module at time of alarm occurrence.
 - .8 A master controller mounted on the wall with touch screen control interface is to control all the modules on chiller assembly.
 - .9 If communication is lost from local controller to master controller, the local controller is to send fault alarm and then instantaneously take over the control of the chiller module.
 - .10 Critical parameters shall have their own section of control.
 - .11 A soft load function is to prevent the system from operating at full load during the chilled water pull down period.
 - .12 Auto restart after a power failure, not requiring external battery backup or auxiliary power is to be provided to maintain program memory.
 - .13 Start-to-start and stop-to-start timers are to provide minimum compressor off-time with maximum motor protection.

3.5 START-UP

- .1 Ensure proper charge of refrigerant and oil.
- .2 Provide testing, and starting of machine, and instruct the Owner in its proper operation and maintenance.

3.6 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
 - .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

3.7 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by rotary-screw water chiller installation.

END OF SECTION