



5		
4	Issued for Tender and Construction	Oct 10, 1999
3	99% Construction Documents	Aug 30, 1999
2	50% Construction Document Submission	Jul 19, 1999
1	Design Development Submission	Jun 21, 1999
0	Pre Design	Jun 21, 1999
Revision/	Description/Description	Date/Date

**Agriculture and Agri-Food
Canada**

Client/client

R.059536.001	MI.7	4
--------------	------	---

8 OF 14



- A. DO NOT SCALE OFF THIS DRAWING. CONTRACTOR TO VERIFY ALL DIMENSIONS PRIOR TO INSTALLATION AND SHALL REPORT ANY DISCREPANCY TO DEPARTMENTAL REPRESENTATIVE.
- B. ALL EXISTING EQUIPMENT AND ASSOCIATED PIPES AND DUCTWORK TO REMAIN UNLESS OTHERWISE NOTED.
- C. CONFIRM EXACT SIZES AND LOCATIONS FOR ALL EXISTING SERVICES.

1. EXISTING EXHAUST DUCTWORK TO REMAIN.
2. UP TO EXHAUST FAN LOCATED ON PENTHOUSE ROOF.
3. EXISTING EXHAUST FAN (F-C-S143-A) ON PENTHOUSE ROOF TO BE REMOVED IN ITS ENTIRETY. FAN TO BE RETURNED TO AISC FOR STORAGE IN THEIR EXISTING EQUIPMENT STOCK.
4. EXISTING EXHAUST FAN (F-C-S147-A) ON PENTHOUSE ROOF TO BE REMOVED IN ITS ENTIRETY. FAN TO BE RETURNED TO AISC FOR STORAGE IN THEIR EXISTING EQUIPMENT STOCK.
5. UP TO EXHAUST FAN LOCATED INSIDE PENTHOUSE ABOVE.
6. EXISTING EXHAUST FAN (F-S133-A) IN PENTHOUSE TO BE REMOVED IN ITS ENTIRETY. FAN TO BE RETURNED TO AISC FOR STORAGE IN THEIR EXISTING EQUIPMENT STOCK.
7. EXISTING EXHAUST DUCT UP THRU PENTHOUSE ROOF.