

PART 1 GENERAL

- .1 This addendum forms part of the Contract Documents and amends the original Drawings and Project Manual (Specification) dated September 15, 2013.
- .2 Ensure that all parties submitting bids are aware of all items included in this Addendum.

PART 2 ARCHITECTURAL

2.1 SPECIFICATIONS

- .1 Reference: 08 71 10 – Door Hardware – General
 - .1 Clarification: 2.2 .10 .1 L1 Door Viewers is to be as specified on drawing A209: as per “Advanced Safety Devices” Model No. DS238 Door Scope (www.safety-devices.com).

DRAWINGS

- .1 Reference: A100 – SITE PLAN AND SIDEWALK DETAILS
 - .1 Clarification: All concrete shall be 32 MPa type-50 sulfate resistant cement.
- .2 Reference: Drawing E201 Main Floor Plan Electrical
 - .1 Clarification switch for exhaust fan within Cell 108, locate fan as per architectural drawings, and locate switch within light switch bank in Corridor 106.
 - .2 Provide emergency lighting in Guard Room 106.1 as per NBC 2010, article 3.2.7.3.

END OF ADDENDUM #1