

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
Pacific Region
401 - 1230 Government Street
Victoria, B.C.
V8W 3X4
Bid Fax: (250) 363-3344

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
401 - 1230 Government Street
Victoria, B. C.
V8W 3X4

Title - Sujet SUPPLY & INSTALL PIPE		
Solicitation No. - N° de l'invitation F1782-13C721/B		Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F1782-13C721		Date 2013-11-13
GETS Reference No. - N° de référence de SEAG PW-\$VIC-210-6348		
File No. - N° de dossier VIC-3-36081 (210)	CCC No./N° CCC - FMS No./N° VME	
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-11-18		Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Enquiries to: - Adresser toutes questions à: Buchan, Torrey		Buyer Id - Id de l'acheteur vic210
Telephone No. - N° de téléphone (250) 363-3249 ()		FAX No. - N° de FAX (250) 363-0395
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DEPARTMENT OF FISHERIES AND OCEANS IOS VICTORIA 9860 WEST SAANICH RD. VICTORIA, BC V8L 4B2		

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This amendment has been raised to address questions posed at the Optional Site Visit, and a change to the Basis of Payment.

----- QUESTIONS: -----

Question 1: Is there a requirement for a fabricated galvanized plate with pipe passing through it at the building envelope?

Answer 1: No

Question 2: Can the cooling tower frame be welded to?

Answer 2: Yes

Question 3: Is two foot braided stainless steel flex hose acceptable for flexible piping connections to the cooling tower?

Answer 3: Yes

Question 4: Is it acceptable to secure piping inside the building and to the tower without using external bracing as long as the piping is supported and as such omit the protective bollard post?

Answer 4: Yes, provided that the technical authority is informed of the details prior to implementation.

Question 5: May the contractor set up tools for and do pipe work on site out of the weather.

Answer 5: Yes the dynamometer room is available.

----- Solicitation Revisions -----

See following page

Solicitation No. - N° de l'invitation
F1782-13C721/B

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
vic210

Client Ref. No. - N° de réf. du client
F1782-13C721

File No. - N° du dossier
VIC-3-36081

CCC No./N° CCC - FMS No/ N° VME

ANNEX B
BASIS OF PAYMENT

Prices are in Canadian dollars, the Goods and Services Tax (GST) excluded, FOB destination for goods, shipping charges included, Customs duties and Excise taxes included.

Pricing below must be all-inclusive and include all costs associated with labour, supervision, material, equipment, transportation, overhead and profit required to complete the work detailed in Annex A. No other charges will be allowed without approval from the Contracting Authority.

The Bidder must provide a breakdown of their costs as per the schedule below, for all sections required to complete the work requested.

Item	Description	Extended Total (CAD\$)
Supply & Installation of Piping in accordance with Annex A, Statement of Work.		
1	Cost of Materials (including consumables and equipment rentals)	
2	Pipefitter - Labour Cost	
3	Apprentice / Labourer - Labour Costs	
4	Other Costs	
Firm Total Price (CAD\$)		

Change Orders / Additional Work Requested:

When Canada or the Contractor requests design change or additional work, the following rates shall apply:

Material Markup (%):		%
Pipefitter - Labour Rate (per hour):		\$ / hour
Apprentice / Labourer - Labour Rate (per hour):		\$ / hour

BEST WORK PERIOD OFFERED: _____