

**RETURN BIDS TO:  
 RETOURNER LES SOUMISSIONS A:  
 Bid Receiving/Réception des  
 soumissions**

**RCMP / GRC**  
 Procurement & Contracting services  
 c/o Commissionaires, F Division  
 6101 Dewdney Avenue  
 Regina, SK S4P 3K7

**Facsimile Number for Amendments:  
 (306) 780-3466**

**SOLICITATION AMENDMENT  
 MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les memes.

**Comments - Commentaries**

**Vendor/Firm Name and Address**  
 Raison sociale et adresse du fournisseur/de l'entrepreneur

**Facsimile No. - No de télécopieur:**

**Telephone No. - no de téléphone:**

<b>Title-Sujet</b> Selective Demolition and Renovation in Detachment, Blaine Lake, SK	
<b>Solicitation No. - No. de l=invitation</b> M5000-4-3719/A	<b>Date</b> 15 November 2013
<b>Amendment No. - No modif.</b> 04	
<b>Client Reference No. - No. De Référence du Client</b> N/A	
<b>GETS Reference No. - No. de Référence de SEAG</b> PW-13-00510230	
<b>Solicitation Closes -L' invitation prend fin</b> <b>at - à 2 :00 pm Central Standard Time Zone</b> <b>on - le 20 November 2013</b>	
<b>F.O.B. - F.A.B.</b> Destination	
<b>Address Enquiries to: - Adresser toutes questions à:</b> <b>Bonny Manz, Senior Contracting Officer</b>	
<b>Telephone No. - No de téléphone</b> (306) 780-3352	<b>Fax No. - N° de FAX:</b> (306) 780-3466
<b>Destination of Goods, Services, and Construction:</b> <b>Destinations des biens, services et construction:</b> Royal Canadian Mounted Police 5600 – 11 <sup>th</sup> Avenue Regina, SK S4P 3J7	
<b>This document contains a PERSONNEL SECURITY Clearance requirement.</b>	
<b>Delivery Required - Livraison exigée:</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l' entrepreneur</b>	



**Royal Canadian Mounted Police**  
**Gendarmerie royale du Canada**

---

Government of Canada	Gouvernement du Canada	Solicitation No./No de l' invitation:	M5000-4-3719/A4
-------------------------	---------------------------	---------------------------------------	-----------------

---

The purpose of this amendment is to answer the following questions:

**Q3)** Are there any hazardous materials on site such as Asbestos that we will need to consider in our tender?

**A2)** *Testing has been done and the results were negative. Clause R2840D, GC4.4 refers to procedures should hazardous or toxic substances or material be encountered on any government project.*

**Q4)** Do new conduit and data cables need to be installed within the walls of the building or can they be surface mounted?

**A4)** *See specification Section 260502, Items 2.4.1 and 2.4.2 which state that wiring is to be concealed, unless construction prohibits it, in which case it must be approved by the Consultant. For instruction for the conduit, see Section 260534, Item 3.1.2.*