



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

**Parks Canada Agency
Jasper National Park
Box 10
Jasper, Alberta
T0E 1E0**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same

Ce document est par la présente revise; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Parks Canada Agency
Jasper National Park
Box 10
Jasper, AB
T0E 1E0

Title-Sujet Jasper Heritage Train Station Roof Rehabilitation Jasper National Park, Parc national Jasper		Date November 18, 2013
Solicitation No. - No. de l'invitation 5P423-14-6523	Amendment No. – No modif. 01	
GETS Reference No. – No de reference de SEAG PW-13-00535965		
Solicitation Closes L'invitation prend fin – at – á 02:00 PM on – le 2013-11-28	Time Zone Fuseau horaire - Mountain Daylight Time (MDT)	
F.O.B. - F.A.B.		
Address Inquiries to: - Adresser toute demande de renseignements à :		
Margot Simpson		
Telephone No. - No de téléphone 780-852-6255	Fax No. – No de FAX: n/a	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Jasper National Park, 607 Connaught Drive, Jasper AB T0E 1E0		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature		Date

This solicitation amendment number one (01) is issued to answer a question received during the solicitation process:

QUESTION AND ANSWER

Q:

The drawings and specifications state in several locations to remove and repair damaged items such as roof deck, rafters, roof/wall junctions, reglets, crickets and repointing of mortar joints. It will be extremely difficult to determine the quantity of these damaged items until demolition begins. Would it be possible to have the General Contractors carry a specified cash allowance for such work or to have these items become extra's to the contract after construction begins? If not I will have to assume ALL roof decking, rafters etc need to be replaced and carry the cost in my bid. If this has already been addressed in the documents can you please guide me on where to find the information?

A:

Removal and replacement of roof deck, rafters, roof-wall junction, reglets and crickets and repointing of mortar joints will be completed on a cost plus 20% if the work is completed by the general contractor, 15% if the work is completed by a subcontractor. For bidding purposes assume 5% of roof deck and rafters need to be replaced, 10% of reglets, crickets and mortar joints need to be replaced/repointed. Variance in the required work from the assumed percentages will be dealt with by change order.

A man lift as well as ladders will be available during the site visit.

All other Terms and Conditions remain unchanged