



1. THIS DRAWING SHOWS THE EXISTING LAYOUT FOR THE AREAS AFFECTED BY THE WORK OF THIS CONTRACT. THE DEVICES SHOWN ARE THE RESULT OF A SURVEY BY THE CONSULTANT RESPONSIBILITY OF THE BIDDING CONTRACTORS TO VISIT THE SITE AND EVALUATE THE COST OF REMOVING AND RELOCATING EXISTING EQUIPMENT AND ASSOCIATED RACEWAY AND WIRING TO ACCOMMODATE THE NEW EQUIPMENT. THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND SHALL BE ALLOWED FOR DEVICES THAT ARE NOT SHOWN BUT ARE REQUIRED TO BE REMOVED OR RELOCATED OR REPLACED TO SUFFICE THE WORK OF THE CONTRACT.
2. REMOVE ALL EQUIPMENT WIRING BACK TO THE SOURCE, PROVIDE STAINLESS STEEL CONDUIT FOR FLUSH WALL OUTLET BOXES THAT CANNOT BE REMOVED.
3. RELOCATE AND RE-INSTALL EXISTING DEVICES WHERE SUCH WORK IS REQUIRED DUE TO ALTERATIONS AND DEMOLITIONS, RE-ROUTE CONDUIT AND WIRING AND RECONNECT WIRING AS NECESSARY.
4. REPAIR, RE-PAINF ALL WALLS OR CEILING SURFACES AS AFFECTED DURING ELECTRICAL DEMOLITIONS AND NEW INSTALLATIONS TO MATCH THE EXISTING, RESTORE AND MAKE GOOD ALL SURFACES TO ORIGINAL OR BETTER CONDITIONS.
5. PROTECT EXISTING BUILDING AND ALL EXISTING SERVICES (SUCH AS POWER, TEL, DATA, GAS AND WATER, ETC.) AGAINST DAMAGE DURING DEMOLITIONS AND INSTALLATION, PROTECT ANY UNOCCUPIED CHUTE IN CEILING SPACE OR INSIDE STUD WALL AGAINST POSSIBLE DAMAGE.
6. PROVIDE NEW CONDUIT AND WIRING TO NEW AND/OR RELOCATED MECHANICAL EQUIPMENT.
7. REFERENCE TO MECHANICAL DRAWINGS M101 AND M102 AND MECHANICAL SPECIFICATIONS FOR PHASING OF WORK.

[illegible]

Stantec



Stantec Consulting Ltd.
1100, 111 Dunsenair Street
Vancouver BC Canada
V6B 6A3
Tel. 604.696.8000
Fax. 604.696.8100
www.stantec.com

5		
4		
3	Issued for tender	50
2	Issued for 100% Progress Review	50
1	Issued for 80% Progress Review	50
0	Issued for 50% Review	50
0	Description/Description	1.0

**PUBLIC WORKS AND
GOVERNMENT SERVICES
CANADA**

Project title/site and project location
SUMMERLAND, BRITISH COLUMBIA
 4200 HIGHWAY 97
 PACIFIC AGRI-FOOD RESEARCH CENTRE
SUMMERLAND- LAB EXHAUST
SYSTEM ALTERATION

Consultant Approval Box Only
-
Designed by/Concept for S. LAI

PWGSC Project Manager/Administrateur de Projets TFSOC
T. DUNPHY

Caractéristiques régionales, Services d'architectural et de génie, TPS
Philip Fung

PENTHOUSE FLOOR PLAN - ELECTRICAL

Project No./No. du projet	Sheet/Feuille	Revised La Révisé
R.018297.001	E101	