


### KEY NOTES:

- ## KEY NOTES:
- 1) BREAKER NEW 225A, 3P CIRCUIT BREAKER FOR NEW COP PANEL, "COP-EP" NEW BREAKER LVA EATING TO MATCH EXISTING.
  - 2) PROVIDE NEW POWER FEEDER 63mmc = 3/450MCM FROM EXISTING MGC-5 TO NEW COP PANEL, "COP-EP".
  - 3) PROVIDE NEW POWER FEEDER 27mmc = 3/484G FROM NEW COP PANEL TO VFD(SUPPLIED BY OTHERS) AND FROM VFD TO NEW FAN MOTOR ON ROOF. TYPICAL FOR MACH. ROOM, REFRIG. ROOM, AND LER-6. ELECTRICAL DIVISION TO COORDINATE WITH MACH. ROOM, REFRIG. ROOM, AND LER-6.
  - 4) THE ADDITION OF NEW BREAKERS IN MGC-5 IS TO BE PERFORMED AFTER NORMAL WORKING HOURS. CONTRACTOR TO COORDINATE SCHEDULE 2 WEEKS DOWN OF EXISTING ELECTRICAL PANEL WITH DEPARTMENT REPRESENTATIVE NIN 2 WEEKS PRIOR TO WORK.



**Stantec**

**Stantec Consulting**  
1100, 1111 Dunsmuir St.  
Vancouver BC Canada  
V6B 6A3  
Tel. 604.696.8000  
Fax. 604.696.8100  
[www.stantec.com](http://www.stantec.com)

5			
4			
3	Issued for Review	2021/07	
2	Issued Apr 2020 Progress Review	2021/11/10	
1	Issued Apr 2019 Progress Review	2020/07/17	
0	Issued Apr 2018 Review	2020/07/17	
0	Discussion/Description	2019/04/01	

**PUBLIC WORKS AND  
GOVERNMENT SERVICES  
CANADA**

641 - 800 BURRARD STREET  
VANCOUVER, BC

**SUMMERLAND, BRITISH COLUMBIA**  
4200 HIGHWAY 97  
PACIFIC AGRIL-FOOD RESEARCH CENTRE

**SUMMERLAND-LAB EXHAUST  
SYSTEM ALTERATION**

Consultant Approval Box Only

Designed by/Concept for  
**S. LAI**

Drawn by/Detailing for  
**D. FUNK**

PWSSC Project Manager/Administrateur de Projets T530C  
**T. DUNPHY**

PWSSC, Agency Manager, Architectural and Engineering Services  
Parks, Recreation and Cultural Services Architectural and Engineering Services  
**Philip Fung**

## ELECTRICAL DETAILS

Project No./No. du projet	Sheet/Feuille	Révision no. La Révision
R.018297.001	E301	3