


1 PARTIAL ROOF PLAN
1:100

KEY NOTES:

- 1 TEMPORARILY DISCONNECT POWER TO EXISTING MOTORIZED DAMPER J-BOX AND PROVIDE RE-WIRING AND RECONNECT TO RELOCATED MOTORIZED DAMPER.
- 2 PROVIDE NEW GFI RECEPTACLE AT EXHAUST PLENUM ON ROOF LEVEL. CONNECT EACH TO DEDICATED 15A, 120V CIRCUIT. ADD NEW BREAKERS IN EMERGENCY PANEL. LOCATED AT EXISTING MCC-41 AT PENHOUSE.
- 3 NEW 15A 120V POWER AND WIRING TO NEW EXHAUST PLENUM LIGHTING. PLENUM GUARD GLASS LENS. WET LOCATION 120V, 1" X 42" PL LAMP. ELECTRONIC BALLAST. LIGHT SWITCH AND BAKING LIGHT LOCATION.
- 4 PROVIDE 120V POWER FROM EXISTING 24 OCT POWER PANEL IN PENHOUSE. MCC-41 TO MOTORIZED DAMPER J-BOX AND DAMPER. CONTROL BY MECHANICAL.



5			
4	Issued For "Final"	2009/09/16	
3	Issued For 1000 Progress Review	2009/11/26	
2	Issued For 950 Progress Review	2009/07/17	
1	Issued For 902 Review	2009/02/16	
0	Drawn (Not Permitted)	2009/01/14	


PUBLIC WORKS AND
GOVERNMENT SERVICES
CANADA

641 - 800 BURRARD STREET
VANCOUVER, BC

Project Name/Titre du projet
SUMMERLAND - BRITISH COLUMBIA
PACIFIC AGRI-FOOD RESEARCH CENTRE
SUMMERLAND - LAB EXHAUST
SYSTEM ALTERATION

Consultant Approval Box Only
Designed by/Concepteur par
Drawn by/Dessiné par
Project Manager/Manager/Administrateur de Projet
T. DUNPHY
Project Engineer/Ingénieur/Ingénier/Ingenieur et Ingenieur
Philip Fung
Drawing Date/Date de dessin


ROOF PLAN - ELECTRICAL



1:100

Project No./N° de projet	Sheet/Feuille	Revision/Version
R.018297.001	E201	3

Public Works and
Government Services
Canada
REAL PROPERTY SERVICES
Services Immobiliers
Pacific Region
Services Immobiliers
Région du Pacifique



Stantec Consulting Ltd.
1100, 111 Burrard Street
Vancouver BC Canada
V6C 2E6
Tel. 604.686.8000
Fax. 604.686.8100
www.stantec.com