

Appendix C

Fume Hood Deficiency & Comments List



Stantec

Lab Exhaust System Alteration

Date: Wednesday, February 13th, 2013

General Comments:

- Fume hood installation is NIC and information is shown for information only.
- 1. Fume Hood Serial Number: 31152-07
 - i. Front sill plate needs to be replaced.
 - ii. One (1) seismic angle bracket included.
- 2. Fume Hood Serial Number: 41872
 - i. Vent kit is missing?
 - ii. No seismic angle bracket included?

STANTEC CONSULTING LTD.

Kevin Anthony, P.Eng., LEED AP BD+C
Mechanical Engineer