

1 GENERAL

1.1 RELATED REQUIREMENTS

- .1 Section 01 33 00 - Submittal procedures.
- .2 Section 09 91 99 - Painting for minor work.

1.2 REFERENCES

- .1 Aluminum Association (AA)
 - .1 AA DAF 45-03(R2009), Designation System for Aluminum Finishes.
- .2 ASTM International
 - .1 ASTM C 475-02(2007), Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board.
 - .2 ASTM C 514-04(2009e1), Standard Specification for Nails for the Application of Gypsum Board.
 - .3 ASTM C 557-03(2009)e1, Standard Specification for Adhesives for Fastening Gypsum Wallboard to Wood Framing.
 - .4 ASTM C 840-08, Standard Specification for Application and Finishing of Gypsum Board.
 - .5 ASTM C 954-07, Standard Specification for Steel Drill Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Steel Studs From 0.033 in. (0.84 mm) to 0.112 in. (2.84 mm) in Thickness.
 - .6 ASTM C 1002-07, Standard Specification for Steel Self-Piercing Tapping Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs.
 - .7 ASTM C 1047-09, Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base.
 - .8 ASTM C 1280-99, Standard Specification for Application of Gypsum Sheathing.
 - .9 ASTM C 1177/C 1177M-08, Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing.
 - .10 ASTM C 1178/C 1178M-08, Standard Specification for Glass Mat Water-Resistant Gypsum Backing Board.
 - .11 ASTM C 1396/C 1396M-09a, Standard Specification for Gypsum Wallboard.
- .3 Association of the Wall and Ceilings Industries International (AWCI)
 - .1 AWCI Levels of Gypsum Board Finish-97.
- .4 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-51.34-M86(R1988), Vapour Barrier, Polyethylene Sheet for Use in Building Construction.
 - .2 CAN/CGSB-71.25-M88, Adhesive, for Bonding Drywall to Wood Framing and Metal Studs.
- .5 Underwriters' Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-07, Standard Method of Test of Surface Burning Characteristics of Building Materials and Assemblies.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for [gypsum

board assemblies and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store gypsum board assemblies materials level indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect gypsum board assemblies from nicks, scratches, and blemishes.
 - .3 Protect from weather, elements and damage from construction operations.
 - .4 Handle gypsum boards to prevent damage to edges, ends or surfaces.
 - .5 Protect prefinished aluminum surfaces with wrapping. Do not use adhesive papers or sprayed coatings which bond when exposed to sunlight or weather.
 - .6 Replace defective or damaged materials with new.

1.5 AMBIENT CONDITIONS

- .1 Maintain temperature 10 degrees C minimum, 21 degrees C maximum for 48 hours prior to and during application of gypsum boards and joint treatment, and for 48 hours minimum after completion of joint treatment.
- .2 Apply board and joint treatment to dry, frost free surfaces.
- .3 Ventilation: ventilate building spaces as required to remove excess moisture that would prevent drying of joint treatment material immediately after its application.

2 PRODUCTS

2.1 MATERIALS

- .1 Gypsum sheathing board fireproof : to ASTM C 1396/C 1396M, Type C, 16 mm thick, 1200 mm wide x maximum practical length.
Product: "Prorock typifies C" of CertainTeed or equivalent approved by the ministerial Representative.
- .2 Water-resistant board: to ASTM C 1396/C 1396M Type X, 16 mm thick, 1200 mm wide x maximum practical length.
Product: "Prorock" resisting the humidity and the mold of CertainTeed or approved equivalent by the ministerial Representative.
Installation: Restrooms.
- .3 Nails: to ASTM C 514.
- .4 Steel drill screws: to ASTM C 1002.
- .5 Shadow mould: 35 mm high, snap-on trim, of 0.6 mm base steel thickness galvanized sheet pre-finished in satin enamel colour.
- .6 Expansion control joints "no 093 ", the sheet steel of zinc 2 mm in thickness, of 6mm of wide and 11 mm deep covered with a plastic tape. This product fits standard 6mm openings.

- .7 Polyethylene: to CAN/CGSB-51.34, Type 2.
- .8 Joint compound: to ASTM C 475, asbestos-free.

2.2 FINISHES

- .1 Texture finish: asbestos-free standard white texture coating and primer-sealer, recommended by gypsum board manufacturer.

3 EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify conditions of substrates previously installed under other Sections or Contracts are acceptable for gypsum board assemblies installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Ministerial Representative.
 - .2 Inform Ministerial Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Ministerial Representative.

3.2 ERECTION

- .1 Do application and finishing of gypsum board to ASTM C 840 except where specified otherwise.
- .2 Do application of gypsum sheathing to ASTM C 1280.
- .3 Support light fixtures by providing additional ceiling suspension hangers within 150 mm of each corner and at maximum [600] mm around perimeter of fixture.
- .4 Install work level to tolerance of 1:1200.
- .5 Frame with furring channels, perimeter of openings for access panels, light fixtures, diffusers, grilles.
- .6 Furr above suspended ceilings for gypsum board fire and sound stops and to form plenum areas as indicated.
- .7 Furr duct shafts, beams, columns, pipes and exposed services where indicated.

3.3 APPLICATION

- .1 Apply gypsum board after bucks, anchors, blocking, sound attenuation, electrical and mechanical work have been approved.
- .2 Apply single layer gypsum board to metal furring or framing using screw fasteners. Maximum spacing of screws 300 mm on centre.
- .3 Apply water-resistant and fireproof gypsum board in the restrooms and where there is of the dampness.
- .4 Install ceiling boards in direction that will minimize number of end-butt joints. Stagger end joints at least 250 mm.
- .5 Install gypsum board on walls vertically to avoid end-butt joints. At stairwells and similar high

walls, install boards horizontally with end joints staggered over studs, except where local codes or fire-rated assemblies require vertical application.

- .6 Install gypsum board with face side out.
- .7 Do not install damaged or damp boards.
- .8 Locate edge or end joints over supports. Stagger vertical joints over different studs on opposite sides of wall.

3.4 INSTALLATION

- .1 Erect accessories straight, plumb or level, rigid and at proper plane. Use full length pieces where practical. Make joints tight, accurately aligned and rigidly secured. Mitre and fit corners accurately, free from rough edges.
- .2 Install casing beads around perimeter of suspended ceilings.
- .3 Install casing beads where gypsum board butts against surfaces having no trim concealing junction and where indicated. Seal joints with sealant if necessary.
- .4 Install insulating strips continuously at edges of gypsum board and casing beads abutting metal window and exterior door frames, to provide thermal break.
- .5 Install shadow mould at gypsum board/ceiling juncture [as indicated]. Minimize joints; use corner pieces and splicers.
- .6 Construct control joints of preformed units set in gypsum board facing and supported independently on both sides of joint.
- .7 Provide continuous polyethylene dust barrier behind and across control joints.
- .8 Locate control joints at changes in substrate construction, at approximate 8 m spacing on long corridor runs at approximate 9 m spacing on ceilings.
- .9 Install control joints straight and true.
- .10 Construct expansion joints, at building expansion and construction joints. Provide continuous dust barrier.
- .11 Install expansion joint straight and true.
- .12 Install access doors to electrical and mechanical fixtures specified in respective sections.
 - .1 Rigidly secure frames to furring or framing systems.
- .13 Finish face panel joints and internal angles with joint system consisting of joint compound, joint tape and taping compound installed according to manufacturer's directions and feathered out onto panel faces.
- .14 Gypsum Board Finish: finish gypsum board walls and ceilings to following levels in accordance with AWC Levels of Gypsum Board Finish:
 - .1 Levels of finish: embed tape for joints and interior angles in joint compound and apply three separate coats of joint compound over joints, angles, fastener heads and accessories; surfaces smooth and free of tool marks and ridges.
- .15 Finish corner beads, control joints and trim as required with two coats of joint compound and one coat of taping compound, feathered out onto panel faces.

- .16 Fill screw head depressions with joint and taping compounds to bring flush with adjacent surface of gypsum board so as to be invisible after surface finish is completed.
- .17 Sand lightly to remove burred edges and other imperfections. Avoid sanding adjacent surface of board.
- .18 Completed installation to be smooth, level or plumb, free from waves and other defects and ready for surface finish.
- .19 Apply one coat of white primer sealer over surface to be textured. When dry apply textured finish in accordance with manufacturer's instructions.
- .20 Mix joint compound slightly thinner than for joint taping.
- .21 Apply thin coat to entire surface using trowel or drywall broad knife to fill surface texture differences, variations or tool marks.
- .22 Allow skim coat to dry completely.
- .23 Remove ridges by light sanding or wiping with damp cloth.

3.5 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
 - .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

3.6 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by gypsum board assemblies installation.

END OF SECTION