



**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS Á:**

**Parks Canada Agency  
Jasper National Park  
Box 10  
Jasper, Alberta  
T0E 1E0**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same

Ce document est par la présente revise; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaries**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l=entrepreneur**

**Issuing Office - Bureau de distribution**

Parks Canada Agency  
Jasper National Park  
Box 10  
Jasper, AB  
T0E 1E0

<b>Title-Sujet</b> Jasper Heritage Train Station Roof Rehabilitation Jasper National Park, Parc national Jasper		<b>Date</b> November 27, 2013
<b>Solicitation No. - No. de l'invitation</b> 5P423-14-6523	<b>Amendment No. – No modif.</b> 02	
<b>GETS Reference No. – No de reference de SEAG</b> PW-13-00535965		
<b>Solicitation Closes L'invitation prend fin –</b>  at – á    02:00 PM on – le   2013-11-28	<b>Time Zone Fuseau horaire -</b>  Mountain Daylight Time (MDT)	
<b>F.O.B. - F.A.B.</b>		
<b>Address Inquiries to: - Adresser toute demande de renseignements à :</b>  Margot Simpson		
<b>Telephone No. - No de téléphone</b>  780-852-6255	<b>Fax No. – No de FAX:</b>  n/a	
<b>Destination of Goods, Services, and Construction: Destinations des biens, services et construction:</b>  Jasper National Park, 607 Connaught Drive, Jasper AB T0E 1E0		
<b>Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l=entrepreneur</b>		
<b>Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>		
<b>Signature</b>		<b>Date</b>

**This solicitation amendment number two (02) is issued to answer a question received during the solicitation process:**

QUESTION AND ANSWER

**Q:**

From the tender documents, I see the installation is to be 100% completed by the end of March 2014.

For the Snow melting cables, the Standard of Acceptance is: Heatizon Guttermelt SR.

The manufacturer's installation instructions, include a warning: "The minimum installation temperature is 40 degrees F.,5 degrees C".

Since this is a winter installation in Alberta, how would we be able to do the installation of these snow melt cables as per manufacturer's specifications?

**A:**

The cables in question are run inside the gutters with a loop down into the downspouts so this won't prevent the installation of the shingles and fascias or the installation of the new gutters and downspouts.

For the purposes of pricing the snow melting cables the bidders should assume that the temperature will be satisfactory.

**All other Terms and Conditions remain unchanged**