

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
 Bid Receiving Public Works and Government
 Services Canada/Réception des soumissions/Travaux
 publics et Services gouvernementaux Canada
 The Cambridge Building
 3 Queen Street/3, rue Queen
 Charlottetown
 Prince Edward Island
 C1A 4A2

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All enquiries are to be submitted in writing to the Contracting Authority, Darlene Reay, either by facsimile or by e-mail at:
 darlene.reay@pwgsc.gc.ca.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
 The Cambridge Building
 3 Queen Street/3 rue, Queen
 PO Box 1268/CP 1268
 Charlottetown
 Prince Ed
 C1A 4A2

Title - Sujet Réaménagement du laboratoire m	
Solicitation No. - N° de l'invitation E0226-141607/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client R.051909.001	Date 2013-11-27
GETS Reference No. - N° de référence de SEAG PW-\$PWC-008-3322	
File No. - N° de dossier PWC-3-36081 (008)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-11-28	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Reay, D (PWC)	Buyer Id - Id de l'acheteur pwc008
Telephone No. - N° de téléphone (902) 566-7518 ()	FAX No. - N° de FAX (902) 566-7514
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les changements suivants aux documents d'appel d'offres entrent en vigueur immédiatement. Cet addenda fera partie des documents contractuels.

APPEL D'OFFRES & ADDENDA n ° 2

éclaircissement- (CG) 10 - Assurances R2900D (2008-05-12)

.1.1 - Polices d'assurance

L'entrepreneur souscrit et maintient, à ses propres frais, des polices d'assurance relativement aux travaux et en fournit la preuve au Canada conformément aux exigences des « Conditions d'assurance ».

QUESTIONS POSÉES PAR LES SOUMISSIONNAIRES

QUESTION n ° 1

In addendum # 4 they are specifying a closer with integral adjustable stop. What are they looking for?

RÉPONSE n ° 1

This is referring to an adjustable door closer with a stop to prevent the door from swinging into new millwork, etc.

QUESTION n ° 2

The hollow metal door spec is very confusing. Do not know exactly what is required. There are three door cores listed: Honeycomb , steel stiffened with fiberglass and temperature rise. Then when you look at door construction the spec is asking for 16ga sheet metal with steel stiffeners and the voids filled with fiberglass. Then when you look at the door fabrication general the spec has interior doors with honey comb construction and the door seams welded and body filled to a smooth finish.

RÉPONSE n ° 2

Reference Specification Section 08 11 13 Hollow Metal Doors & Frames: Delete Section 2.2.1 & 2.2.3. Section 2.2.2 to remain "Stiffened: face sheets, welded, honeycomb, insulated core. .1 Fiberglass: to CSA A101, semi-rigid Type 1A density 24 kg/m3."

New door is to have a 45 minute fire rating.