

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
PO Box 1408, Room 100
167 Lombard Ave.
Winnipeg
Manitoba
R3C 2Z1
Bid Fax: (204) 983-0338

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Western Region
PO Box 1408, Room 100
167 Lombard Ave.
Winnipeg
Manitoba
R3C 2Z1

Title - Sujet ELECTRIC MOBILE FILE SYSTEM	
Solicitation No. - N° de l'invitation G5169-130002/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client G5169-130002	Date 2013-11-28
GETS Reference No. - N° de référence de SEAG PW-\$WPG-015-8702	
File No. - N° de dossier WPG-3-36170 (015)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-12-05	Time Zone Fuseau horaire Central Standard Time CST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Nnadi, Chaz	Buyer Id - Id de l'acheteur wpg015
Telephone No. - N° de téléphone (204) 983-6109 ()	FAX No. - N° de FAX (204) 983-7796
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This amendment 004 has been issued to amend solicitation G5169-130002/A, issued 2013-10-22:

Part A: Question and Answers

Part A: Question and Answers

Q36. Point 5.6.5. Q: Operator control must be provided at the end of each access aisle

Does this mean that the client will need one controller on each side of the exposed panel, meaning 2 controllers per cabinet

A36: Mobile shelving should be controlled from one side/end of the carriage.

Q37: Same for the card holder, should we supply two card holders?

A37: Same as above.

Q39: Point 6.5. Proprietary. Is 25mm shelf adjustment acceptable? instead of 38mm

A39: Yes.

Q40: Point 6.15. Q: Must provide finished metal top shelf per carriage unit. Could you please provide more clarification on this point

A40: Must have a metal top on the shelves.

Q41. Point 7.5. Proprietary. For the shelf deflection, would the client accept a certificate issued by the TUV organisation Germany for a similar test instead of the one required from BIFMA?

A41: Yes

Q42: Point 11.4. Proprietary. Our controller will maintain a 100mm clearance between the carriages, do we need to add bumpers as well, to maintain the same distance?

A42: Yes

Q43: Do you need full back fire-stops on the mobile shelving system?

A43: Yes

Point 14.4. Installers must be certified to install the units. Bidder must provide proof of certification for each installer.

Q44: Is a certification of any kind required if the installation is conducted by the manufacturer representative and engineers?

A44: No, as long as the company certifies the installers so that it doesn't affect the manufacturer's warranties.

Q45: Point 14.3. Could you please give more clarification about the required proof of warranty?

A45: No it is clearly stated in the documents.

Q46: What is the required clearance height between the shelves?

A46: Minimum 279mm (11 in)

Q47: Is a contractor permit required for the installation?

A47: Check with the local jurisdictions, but expect that installation may require an electrical permit.

Solicitation No. - N° de l'invitation

G5169-130002/A

Amd. No. - N° de la modif.

004

Buyer ID - Id de l'acheteur

wpg015

Client Ref. No. - N° de réf. du client

G5169-130002

File No. - N° du dossier

WPG-3-36170

CCC No./N° CCC - FMS No/ N° VME

Q48: 4.5.3 Fixtures must be attached to the canopy tops centered over each aisle 914 mm (36 in.) wide or less and the revised point 9.

The system must allow for three accessible aisles - minimum of one 48" wide aisle, and two 42" wide aisle - in each unit for Service staff to access files. If Static carriages are being utilized they must be placed on the perimeter of the Mobile system.

A48: The last set of answers specified 3x 42" corridors.

ALL OTHER CLAUSES REMAIN UNCHANGED.