



Project Title: Exterior Masonry Repairs
Building 94
Central Experimental Farm (CEF), Ottawa (Ontario)

Solicitation No: 13-1328

November 29, 2013

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

Q & A

Q1. Can you clarify what is note 13 shown on 2/S401 “West Elevation” between grid line G and H is referring to?

A1. Note 13 of 2/S401 should read B3 and the area be hatched accordingly.

Q2. There was mention at the site visit that only the exposed areas above grade were to be parged (no excavation required), can you confirm no excavation is required?

A2. No excavation is required. The new parging will terminate neatly at grade.

Q3. Detail 5/S001 refers to 7/S401, where is 7/S401?

A3. Detail 7/S401 should be 6/S001.

Q4. Notes AD.1 and AD.2 state that for pricing purposes, assume that the work will require either a cherry picker or rolling scaffolding. If the work areas are low or on level ground, a rolling scaffold can be used, otherwise, it will not work. Shouldn't everyone allow for a cherry picker to eliminate the possibility of extra costs for the Owner?

A4. Notes AD.1 and AD.2 are modified to reflect that the work will required a cherry picker (see below).

DRAWINGS

1. At Drawing S001, 2/S401 “West Elevation”:

Delete: NOTE 13

Replace with: NOTE B3

2. At Drawing S001, 5/S001 “Raking out Detail”:

Delete: SEE 7/S401

Replace with: SEE 6/S001

3. At Drawing S001, Additional Quantities (to be included in contract), AD.1 and AD.2:

Delete: assume that the work will require either a cherry picker or rolling scaffolding.

Replace with: assume that the work will require a cherry picker.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME