



AMENDMENT 2

Project Title: Inspection, Testing and Maintenance of Generators
Central Experimental Farm (CEF)
Ottawa (Ontario)

Solicitation No: 13-2033

November 29, 2013

Amendment 2 is raised to do the following:

- Answer questions from bidders (Q&A).
-

Q&A

Q6. At question Q2, it is written that code CSA282-09 states that belts and hoses must be changed every 5 years. It seems that this information is not totally exact. Do you want our tender priced to replace the belts and hoses or do you want our tender priced according to the CSA282-09?

A6. The belts and hoses change must be done according to all applicable codes and recommendations of the manufacturer. The price submitted in response to the Invitation to Tender must be submitted consequently.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME