

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Travaux publics et Services gouvernementaux
Canada
Place Bonaventure, portail Sud-Est
800, rue de La Gauchetière Ouest
7^{ème} étage
Montréal
Québec
H5A 1L6
FAX pour soumissions: (514) 496-3822

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Travaux publics et Services gouvernementaux Canada
Place Bonaventure, portail Sud-Est
800, rue de La Gauchetière Ouest
7^{ème} étage
Montréal
Québec
H5A 1L6

Title - Sujet compresseurs d'azote gazeux	
Solicitation No. - N° de l'invitation 31026-130010/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client 31026-13-0010	Date 2013-12-10
GETS Reference No. - N° de référence de SEAG PW-\$MTA-280-12477	
File No. - N° de dossier MTA-3-36148 (280)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2013-12-16	
F.O.B. - F.A.B. Plant-Usine: <input checked="" type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Blanchet, Annie A.	Buyer Id - Id de l'acheteur mta280
Telephone No. - N° de téléphone (514) 496-3519 ()	FAX No. - N° de FAX (514) 496-3822
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

THE ABOVE SOLICITATION IS HEREBY AMENDED AS FOLLOWS:

Amendment #1:

In Appendix A - Requirement

DELETE:

2.0 Constraints

The current system consists of two compressors, as shown in Annex C. These compressors are installed inside a structure that has overall dimensions of 147 inches long by 46 inches wide and 80 inches high. The structure consists of a mount situated 40 inches above the ground, upon which the compressors sit inside a fiberglass shelter. The mount also holds the compressor control panels. The new compressor(s) shall replace the two existing compressor units, be installed on the existing mounts and have a shelter to protect them from the elements.

The compressor(s) and control panel(s) shall be installed on the existing mounts (approximate dimensions: 147 inches long by 46 inches wide and 40 inches above the ground).

The compressor(s) shall be installed in shelters. The existing shelters may be modified and/or replaced. The approximate external dimensions of the shelters are 65 inches long by 46 inches wide and 41 inches high, while the approximate internal dimensions are 51 inches long by 40 inches wide and 41 inches high (see Annex C).

The compressor(s) shall be installed outside of the building and shall be equipped with an integrated heating system.

Shelter construction and/or modifications shall be included in the proposal.

NRC will accept proposals of one compressor or a maximum of two compressors, if the total minimum capacity of the compressor(s) is 160 Nm³/h.

INSERT:**2.0 Constraints**

The current system consists of two compressors, as shown in Annex C. Each of compressors are installed inside a structure that has overall dimensions of 147 inches long by 46 inches wide and 80 inches high. Each structure consists of a mount situated 40 inches above the ground, upon which the compressors sit inside a fibreglass shelter. Under the mount are located 2 buffer tanks that have to be preserved. The mount also holds the compressor control panels. The new compressor(s) must replace the two existing compressor units and their control panels might be installed on the existing mounts (or the existing structure can be modified as long as its overall surface does not exceed 147 inches long X 92 inches wide with a maximum height of 120 inches) and have a shelter to protect them from the elements.

The compressor(s) shall be installed in shelters. The existing shelters may be modified and/or replaced. The approximate external dimensions of the shelters are 65 inches long by 46 inches wide and 41 inches high, while the approximate internal dimensions are 51 inches long by 40 inches wide and 41 inches high (see Annex C).

The compressor(s) shall be installed outside of the building and shall be equipped with an integrated heating system enabling them to work up to a temperature of -30 degree Celcius.

Shelter construction and/or modifications shall be included in the proposal.

NRC will accept proposals of one compressor or a maximum of two compressors, if the total minimum capacity of the compressor(s) is 160 Nm³/h.

Amendment #2:

In Appendix A-Requirement, in part 3.0 Mandatory technical specifications

INSERT:

3.8 The overall compressors, tanks and existing control panels area must not exceed 147 inches long x 92 inches wide with a maximum height of 120 inches.

3.9 The compressor(s) shall be installed outside of the building and shall be equipped with an integrated heating system enabling them to work up to a temperature of -30 degree Celcius.

Mandatory specifications	Specify the location in the bid documentation or data sheets where the mandatory specifications are met
3.1	
3.2	
3.3	
3.4	
3.5	
3.6	
3.7	
3.8	For this specification, no need to provide documentation
3.9	For this specification, no need to provide documentation