

1 **GENERAL**

1.1 **REFERENCES**

- .1 American National Standards Institute/National Fire Prevention Association (ANSI/NFPA)
 - .1 ANSI/NFPA 13-2013, Installation of Sprinkler Systems.
 - .2 ANSI/NFPA 25-2011, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems.
- .2 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .3 Underwriter's Laboratories of Canada (ULC)
 - .1 CAN4 S543-M984, Standard for Internal Lug Quick Connect Couplings for Fire Hose.

1.2 **DESIGN REQUIREMENTS**

- .1 Design automatic wet pipe fire suppression sprinkler systems in accordance with required and advisory provisions of NFPA 13, by pipe schedules for light hazard occupancy.
- .2 Design and provide each system to give full consideration to blind spaces, piping, electrical equipment, ducts, and other construction and equipment in accordance with detailed shop drawings.
- .3 Locate sprinkler heads in consistent pattern with ceiling grid, lights, and air supply diffusers.
- .4 Devices and equipment for fire protection service: ULC approved for use in wet pipe sprinkler systems.
- .5 Design systems for earthquake protection for buildings in seismic zones.
- .6 Location of Sprinkler Heads:
 - .1 Locate heads in relation to ceiling and spacing of sprinkler heads not to exceed that permitted by NFPA 13 for light hazard occupancy.
 - .2 Uniformly space sprinklers on branch.

1.3 **SUBMITTALS**

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 00 10 – General Instructions.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 00 10 – General Instructions.
- .2 Shop Drawings:
 - .1 Submit shop drawings in accordance with Section 01 00 10 – General Instructions.
 - .1 Indicate:
 - .1 Materials

- .2 Finishes
 - .3 Supports
 - .3 Assurance submittals: submit following in accordance with Section 01 00 10 – General Instructions.
 - .1 Test reports:
 - .1 Submit certified test reports for wet pipe fire protection sprinkler systems from approved independent testing laboratories, indicating compliance with specifications for specified performance characteristics and physical properties.
 - .2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .3 Instructions: submit manufacturer's installation instructions.
 - .4 Closeout Submittals:
 - .1 Submit maintenance and engineering data for incorporation into manual specified in Section 01 00 10 – General Instructions in accordance with ANSI/NFPA 20.
 - .2 Manufacturer's Catalog Data, including specific model, type, and size for:
 - .1 Sprinkler heads.
 - .2 Pipe hangers and supports.
 - .3 Field Test Reports:
 - .1 Preliminary tests on piping system.
 - .4 Records:
 - .1 As-built drawings of each system.
 - .1 After completion, but before final acceptance, submit complete set of as-built drawings of each system for record purposes.
 - .5 Operation and Maintenance Manuals:
 - .1 Provide maintenance data for incorporation into manual specified in Section 01 00 10 – General Instructions.
 - .2 Provide Contractors Material and Test Certificate for aboveground piping and other documentation for incorporation into manual specified in Section 01 00 10 – General Instructions in accordance with ANSI/NFPA 13.
- 1.4 **QUALITY ASSURANCE**
 - .1 Qualifications:
 - .1 Installer: company or person specializing in wet sprinkler systems with documented experience.
 - .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29. 06 – Health and Safety Requirements.

1.5 MAINTENANCE

- .1 Extra Materials:
 - .1 Provide spare sprinklers and tools as required by ANSI/NFPA 13.

2 PRODUCTS

2.1 ABOVE GROUND PIPING SYSTEMS

- .1 Provide fittings for changes in direction of piping and for connections.
 - .1 Make changes in piping sizes through tapered reducing pipe fittings, bushings will not be permitted.
- .2 Perform welding in shop; field welding will not be permitted.
- .3 Conceal piping in areas with suspended ceiling.

2.2 PIPE, FITTINGS AND VALVES

- .1 Pipe:
 - .1 Ferrous: to ANSI/NFPA 13, schedule 40 for sizes up to NPS 6.
- .2 Fittings and joints to ANSI/NFPA 13:
 - .1 Ferrous: screwed, welded, flanged or roll grooved.
 - .2 Provide threaded, fittings into which sprinkler heads, sprinkler head riser nipples, or drop nipples are threaded.
 - .3 Plain-end fittings with mechanical couplings and fittings which use steel gripping devices to bite into pipe when pressure is applied will not be permitted.
 - .4 Rubber gasketed grooved-end pipe and fittings with mechanical couplings are permitted in pipe sizes 32mm and larger.
 - .5 Fittings: ULC approved for use in wet pipe sprinkler systems.
 - .6 Ensure fittings, mechanical couplings, and rubber gaskets are supplied by same manufacturer.
 - .7 Side outlet tees using rubber gasketed fittings are not permitted.
 - .8 Sprinkler pipe and fittings: metal.
- .3 Pipe hangers:
 - .1 ULC listed for fire protection services in accordance with NFPA.

2.3 SPRINKLER HEADS

- .1 General: to ANSI/NFPA 13 and ULC listed for fire services.
- .2 Sprinkler Head Type: pendant chrome glass bulb type, to match existing.

2.4 ESCUTCHEON PLATES

- .1 Provide one piece type metal plates for piping passing through walls and ceilings in exposed spaces.
- .2 Provide polished chromium-plated finish on copper alloy plates in finished spaces.
- .3 Provide paint finish on metal plates in unfinished spaces.

2.5 SPARE PARTS CABINET

- .1 Provide metal cabinet with extra sprinkler heads and sprinkler head wrench adjacent to each alarm valve. Number and types of extra sprinkler heads as specified in NFPA 13.

3 EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install, inspect and test to acceptance in accordance with ANSI/NFPA 13 and ANSI/NFPA 25.

3.3 PIPE INSTALLATION

- .1 Install piping straight and true to bear evenly on hangers and supports. Do not hang piping from plaster ceilings.
- .2 Keep interior and ends of new piping and existing piping thoroughly cleaned of water and foreign matter.
- .3 Keep piping systems clean during installation by means of plugs or other approved methods. When work is not in progress, securely close open ends of piping to prevent entry of water and foreign matter.
- .4 Inspect piping before placing into position.

3.4 FIELD QUALITY CONTROL

- .1 Site Test, Inspection:
 - .1 Perform test to determine compliance with specified requirements in presence of Departmental Representative.
 - .2 Test, inspect, and approve piping before covering or concealing.
 - .3 Preliminary Tests:
 - .1 Hydrostatically test each system at 200 psig for a 2 hour period with no leakage or reduction in pressure.
 - .2 Flush piping with potable water in accordance with NFPA 13.
 - .3 Piping above suspended ceilings: tested, inspected, and approved before installation of ceilings.
 - .4 Formal Tests and Inspections:
 - .1 Do not submit request for formal test and inspection until preliminary test and corrections are completed and approved.
 - .2 Submit written request for formal inspection at least 15 days prior to inspection date.
 - .3 Repeat required tests as directed.
 - .4 Correct defects and make additional tests until systems comply with contract requirements.

- .5 Furnish equipment, instruments, connecting devices, and personnel for tests.
- .6 Authority of Jurisdiction, will witness formal tests and approve systems before they are accepted.

3.5 CLEANING

- .1 Proceed in accordance with Section 01 00 10 – General Instructions.