

1.1 SECTION INCLUDES

- .1 Materials and installation for fused and non-fused disconnect switches.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International).
 - .1 CAN/CSA C22.2 No.4-M89 (R2000), Enclosed Switches.
 - .2 CSA C22.2 No.39-M89 (R2003), Fuseholder Assemblies.

1.3 SUBMITTALS

- .1 Submit product data in accordance with Section 01 00 10 – General Instructions.

1.4 HEALTH AND SAFETY

- .1 Do construction occupational health and safety in accordance with Section 01 35 29.06 – Health and Safety Requirements.

2 PRODUCTS

2.1 DISCONNECT SWITCHES

- .1 Non-fusible, disconnect switch in CSA Enclosure 1 , to CAN/CSA C22.2 No.4 size as indicated.
- .2 Provision for padlocking in off switch position by one lock.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Quick-make, quick-break action.
- .5 ON-OFF switch position indication on switch enclosure cover.

2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 – Common Work Results – Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

3 EXECUTION

3.1 INSTALLATION

- .1 Install disconnect switches complete with fuses if applicable.