

1 **GENERAL**

1.1 **REFERENCES**

- .1 Canadian Standards Association (CSA International)
 - .1 CSA C22.1-12, Canadian Electrical Code, Part 1, 22nd Edition.

1.2 **SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 00 10 – General Instructions.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Provide shop drawings: in accordance with Section 01 00 10 – General Instructions.

2 **PRODUCTS**

2.1 **JUNCTION AND PULL BOXES**

- .1 Construction: welded steel enclosure.
- .2 Covers Flush Mounted: 25 mm minimum extension all around.
- .3 Covers Surface Mounted: screw-on flat covers.

3 **EXECUTION**

3.1 **JUNCTION, PULL BOXES AND CABINETS INSTALLATION**

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Only main junction and pull boxes are indicated. Install additional pull boxes as required by CSA C22.1.

3.2 **IDENTIFICATION**

- .1 Equipment Identification: to Section 26 05 00- Common Work Results - Electrical.
- .2 Identification Labels: size 2 indicating system name voltage and phase or as indicated.