

1 GENERAL

1.1 REFERENCES

- .1 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).
- .2 American Society for Testing and Materials (ASTM).
 - .1 ASTM A 653/A653M-11, Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy Coated (Galvannealed) by the Hot-Dip Process. (Metric).
- .3 Department of Justice Canada (Jus).
 - .1 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
 - .2 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .5 Sheet Metal Air Conditioning Contractors' National Association (SMACNA).
 - .1 SMACNA HVAC Duct Construction Standards, Metal and Flexible, 05
 - .2 SMACNA HVAC Air Duct Leakage Test Manual, 2nd Edition 2012.
 - .3 SMACNA IAQ Guideline for Occupied Buildings under Construction, 2nd Edition 2007.

1.2 SUBMITTALS

- .1 Submit shop drawings and product data in accordance with Section 01 00 10 – General Instructions.
- .2 Product Data: submit WHMIS MSDS – in accordance with Section 01 00 10– General Instructions for the following:
 - .1 Sealants.
 - .2 Tape.
 - .3 Proprietary joints.
 - .4 Fittings.

1.3 QUALITY ASSURANCE

- .1 Certification of Ratings:
 - .1 Catalogue or published ratings to be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.
- .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29.06 – Health and Safety Requirements.

2 **PRODUCTS**

2.1 **DUCTWORK**

- .1 Material:
 - .1 Galvanized steel with Z90 designation zinc coating lock forming quality: to ASTM A 653/A653M.
 - .2 Thickness: to SMACNA.
- .2 Construction – round.
 - .1 Ducts: factory fabricated, spiral wound, with matching fittings and specials to SMACNA.
 - .2 Transverse joints up to 900mm: slip type with tape and sealants.
 - .3 Transverse joints over 900mm: Vanstone.
 - .4 Fittings:
 - .1 Elbows: smooth radius five -piece (for 90 degrees) three-piece (for 45 degrees). Centreline radius: 1.5 x diameter.
 - .2 Branches: conical transition with conical branch at 45 degrees and 45 degrees elbow.
- .3 Construction – rectangular:
 - .1 Ducts: to SMACNA.
 - .2 Transverse joints: proprietary duct joints SMACNA seal Class A .
 - .3 Fittings:
 - .1 Elbows: smooth radius; centreline radius 1.5 x width of duct. No vanes.
 - .2 Branches: with conical branch at 45 degrees and 45 degrees elbow.
- .4 Firestopping:
 - .1 50 x 50 x 3 mm retaining angles around duct, on both sides of fire separation.
 - .2 Firestopping material must not distort duct.

2.2 **SEAL CLASSIFICATION**

- .1 Classification as follows:

Maximum Pressure Pa	SMACNA Seal Class
2500	A
1500	A
1000	A
750	A

- .2 Seal classification:
 - .1 Class A: longitudinal seams, transverse joints, duct wall penetrations and connections made airtight with sealant and tape.

2.3 SEALANT

- .1 Oil resistant, water-borne polymer type flame resistant high velocity duct sealing compound.

2.4 TAPE

- .1 Polyvinyl treated, open weave fibre glass, 50mm wide.

2.5 HANGERS AND SUPPORTS

- .1 Hangers and Supports: in accordance with Section 23 05 29 – Hangers and Supports for HVAC Piping Equipment.
 - .1 Band hangers: use on round and oval ducts up to 200mm diameter, of same material as duct but next sheet metal thickness heavier than duct.
 - .2 Trapeze hangers: ducts over 200mm diameter or longest side, to SMACNA.
 - .3 Hangers: black steel angle with black steel rods to SMACNA.
 - .4 Upper hanger attachments:
 - .1 For concrete: manufactured concrete inserts.

3 EXECUTION

3.1 GENERAL

- .1 Do work in accordance with SMACNA
- .2 Do not break continuity of insulation vapour barrier with hangers or rods.
 - .1 Insulate band hangers 100 mm beyond insulated duct
- .3 Install breakaway joints in ductwork on sides of fire separation.
- .4 Ensure installation of fire stopping does not distort duct.

3.2 HANGERS

- .1 Band hangers: install in accordance with SMACNA.
- .2 Angle hangers: complete with locking nuts and washers.
- .3 Hanger spacing: in accordance with SMACNA.

3.3 SEALING AND TAPING

- .1 Apply sealant in accordance with SMACNA and to manufacturer's recommendations.
- .2 Bed tape in sealant and recoat with minimum of one coat of sealant to manufacturer's recommendations.

3.4 LEAKAGE TESTS

- .1 In accordance with SMACNA HVAC Duct Leakage Test Manual.
- .2 Perform leakage tests in sections.

- .3 Perform trial leakage tests, as instructed to demonstrate workmanship.
- .4 Do not install additional ductwork until trial tests have been achieved.
- .5 Test section minimum of 30 m long with not less than three branch takeoffs and two 90 degrees elbows.
- .6 Complete tests before performing insulation or concealment Work.