

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, 2nd floor  
800, rue Burrard, 2e étage  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, 12th floor  
800, rue Burrard, 12e étage  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Lab Exhaust System Alteration	
<b>Solicitation No. - N° de l'invitation</b> EZ899-141333/A	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2013-12-13
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-004-7132	
<b>File No. - N° de dossier</b> PWY-3-36145 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2014-01-07</b>	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Mestry, Ruth (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy004
<b>Telephone No. - N° de téléphone</b> (604) 775-9385 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> AAFC - Pacific Agri-Food Research Centre - Summerland, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EZ899-141333/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

005

File No. - N° du dossier

PWY-3-36145

Buyer ID - Id de l'acheteur

pw004

CCC No./N° CCC - FMS No/ N° VME

---

**EXTENSION OF TIME FOR TENDERS**

**SUMMERLAND, B.C.**

**PACIFIC BIOLOGICAL AGRI-FOOD RESEARCH CENTRE**

**LAB EXHAUST SYSTEM ALTERATION**

**Requisition No: EZ899-141333/A**

Notice is hereby given that the time for the reception of tenders previously due at 2:00 PM local time - 23 December 2013 is extended to 2:00 PM local time - 07 January 2014.

**For further Information, please contact Ruth Mestry at (604) 775-9385.**

Solicitation No. - N° de l'invitation

EZ899-141333/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

005

File No. - N° du dossier

PWY-3-36145

Buyer ID - Id de l'acheteur

pw004

CCC No./N° CCC - FMS No/ N° VME

---

Attached is Addendum No. 2

This addendum varies the Contract Documents and will form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts, including General and Supplementary General Conditions of the Contract and all Sections in Division 1. The cost of all work contained herein is to be included in the Contract Sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above named project to the extent referenced and shall become a part thereof.

---

## 1 GENERAL

- .1 This addendum is issued prior to receipt of Bids to provide for certain revisions to and clarification to the Contract Documents.
- .2 The work required by this Addendum shall be executed in accordance with the requirements of the Contract and Contract Documents.
- .3 Include in the Stipulated Price, the cost of all work described in this Addendum.

## 2 QUERIES

- .1 Question 1: Can hours of work be extended to accommodate a 12 hours a day?

Response: Yes, but work must be performed only between 0700 to 1900 including weekends and holidays.

During working hours PARC Security will “dis-arm” the building alarm system and then “re-arm” the system at the end of the shift. During weekends and holidays, building security system remains “armed” all day.

To coordinate with the security, hours of work for any given week must be established by Thursday of the preceding week so that PARC Summerland can schedule accordingly and that once those hours have been established for the upcoming week, they will not be allowed to be changed.

- .2 Question 2: Section 015600 states that all AHU filters need to be replaced at the end of construction. If this is the case, can you provide quantity and type of filters to be replaced?

Response: Delete clause “1.6 Additional Filtration” from section 015600.

- .3 Question 3: Once project has been awarded, I have been informed clearance can take up to 3 months. Who pays for the commissionaires in the interim?

Response: There is no requirement for Commissionaires. Contract will not be awarded until security clearance has been completed.

End of Addendum