DRAWING NOTES:

1. THIS AREA TO BE RENOVATED. RELOCATE EXISTING DEVICES/OUTLETS AND EQUIPMENT WHEREVER POSSIBLE FOR NEW CONSTRUCTION, OTHERWISE PROVIDE NEW AS SHOWN OR INDICATED. RELOCATE EXISTING CIRCUITS TO NEW PANELBOARDS WHERE APPLICABLE. DISCONNECT AND REMOVE FROM SITE ALL UNUSED LIGHTING, DEVICES, OUTLETS, CONDUITS AND ALL ASSOCIATED WIRING BACK TO RESPECTIVE PANELS UNLESS OTHERWISE NOTED. REFER TO ELECTRICAL DRAWINGS E4-02 FOR NEW/RELOCATED LOCATIONS OF EXISTING OUTLETS/DEVICES. PATCH HOLES AND MAKE GOOD.
2. EXISTING POWER AND VOICE/DATA IN THIS AREA (MARKED 'ER') TO BE DISCONNECTED AND REMOVED. CAP-OFF WIRING AND PROVIDE COVER TO EXISTING JB. REFER TO DWG. E4-02 & E5-02 & E6-02 FOR NEW POWER & VOICE/DATA LAYOUT. REMOVE ALL EXISTING VOICE/DATA CABLES BACK TO SOURCE. POWER WIRING TO BE REMOVED FROM DEVICE UP TO NEAREST JUNCTION BOX.
3. EXISTING POWER AND VOICE/DATA PACK POLES IN THIS AREA (MARKED 'ER') TO BE DISCONNECTED AND REMOVED. REMOVE WIRING BACK TO BACK OR CEILING MOUNTED JB.
4. MAKE ALL PROVISIONS TO DISCONNECT, REMOVE AND RECONNECT RELOCATED HVAC UNIT. EXTEND WIRING AS REQUIRED. REFER TO MECHANICAL AND E4-02 FOR NEW LOCATION.
5. EXISTING CEILING MOUNTED JUNCTION BOXES AND CONDUITS TO REMAIN FOR REUSE.
6. EXISTING ELECTRICAL DISTRIBUTION TO REMAIN.
7. MAKE ALL ALLOWANCES TO DISCONNECT AND RECONNECT ESSENTIAL EXISTING CIRCUITS, SYSTEM, ETC, THAT REQUIRE DISCONNECTION FOR DEMOLITION AND RECONNECTION TO MAKE ALL SUCH SYSTEMS FULLY AND COMPLETELY OPERATIONAL AFTER DEMOLITION IS COMPLETE.



Public Works and Government Services Canada
Travaux publics et Services gouvernementaux Canada

REAL PROPERTY SERVICES
Western Region
SERVICES IMMOBILIERS
Région de l'ouest

CONSULTANT

These design documents are prepared solely for the use by the party with whom the design professional has entered into a contract and there are no representations of any kind made by the design professional to any party with whom the design professional has not entered into a contract.
Any use of the drawing, disk or electronic data without the expressed written permission of Tower Engineering Group is strictly prohibited.
The contractor is responsible to verify all dimensions with conditions on the site and report discrepancies to Tower Engineering for adjustment.
All prints to be returned.

TOWER PROJECT NO. : 13039

TOWER ENGINEERING GROUP
UNIT 1 – 1140 WAVERLEY ST. WINNIPEG, MB R3T 0P4
TEL: (204) 925–1150 FAX: (204) 925–1155
EMAIL: towereng@towereng.ca WEB: www.towereng.ca
• WINNIPEG • CALGARY • CAMBRIDGE

APEGM
Certificate of Authorization
Tower Engineering Group
No. 4156 Expiry: April 30, 2014

DO NOT SCALE DRAWINGS

Revision/ Revision	Description/Description	Date/Date
0	ISSUED FOR TENDER/CONSTRUCTION	26/11/13

Client/client

PUBLIC WORKS GOVERNMENT SERVICES CANADA

100-167 LOMBARD AVENUE
PO BOX 1408
WINNIPEG, MANITOBA R3C 2Z1

Project title/Titre du projet

STANLEY KNOWLES FIT-UP
391 YORK AVENUE

Approved by/Approuve par
TT

Designed by/Concept par
DA

Drawn by/Dessine par
LS

PWGSC Project Manager/Administrateur de Projets TPSGC
OH

PWGSC, Architectural and Engineering Resources Manager/ Gestionnaire Architectural et de Directeur D'ingénierie, TPSGC
SO

Client/client
PWGSC

Drawing title/Titre du dessin

ELECTRICAL
MAIN FLOOR
POWER & SYSTEMS
DEMOLITION

Project No./No. du projet	Sheet/ Feuille	Revision no./ La Révision no.
R.056754.002	E2-02 OF 21	0

A0 - PWGSC - A0 - 1189X841

0 10 20 30 40 50 60 70 80 90 100mm

Title Block 1