

- 1 PROVIDE NEW SURFACE MOUNTED ACCESS DOOR IN EXISTING RADIATION COVER FOR VALVE ACCESS, 300mm X 300mm IN SIZE.
- 2 EXISTING RADIATION THERMOSTAT
- 3 CONTROL RADIATION FROM THIS THERMOSTAT.
- 4 RELOCATE FANCOIL AND ACCESSORIES TO THIS LOCATION. PROVIDE NEW HYDRONIC PIPING AND INSULATION TO MATCH EXISTING.

