

DRAWING NOTES:

- THIS AREA TO BE RENOVATED. RELOCATE EXISTING DEVICES/OUTLETS AND EQUIPMENT WHEREVER POSSIBLE FOR NEW CONSTRUCTION. OTHERWISE, PROVIDE NEW AS SHOWN OR INDICATED. RELOCATE EXISTING CIRCUITS TO NEW PANELBOARDS WHERE APPLICABLE. DISCONNECT AND REMOVE FROM SITE ALL UNUSED LIGHTING DEVICES, OUTLETS, CONDUITS AND ALL ASSOCIATED WIRING BACK TO RESPECTIVE PANELS UNLESS OTHERWISE NOTED. REFER TO ELECTRICAL DRAWINGS E3-02 AND E4-02 FOR NEW/RELOCATED LOCATIONS OF EXISTING LIGHTING AND OUTLET/SIDE DEVICES. PATCH HOLES AND MAKE GOOD.
- EXISTING POWER AND VOICEDATA IN THIS AREA (MARKED ER) TO BE DISCONNECTED AND REMOVED. CAP-OFF WIRING AND PROVIDE COVER TO EXISTING JB. REFER TO DWG. E5-01 & E5-03 FOR NEW POWER & VOICEDATA LAYOUT.
- EXISTING POWER AND VOICEDATA PACKPOLES IN THIS AREA (MARKED ER) TO BE DISCONNECTED AND REMOVED. REMOVE WIRING BACK TO BACK OR CEILING MOUNTED JB.
- MAKE ALL PROVISIONS TO DISCONNECT, REMOVE HVAC UNIT.
- EXISTING CEILING MOUNTED JUNCTION BOXES AND CONDUITS TO REMAIN AND REUSED. PROVIDE CODE COMPLIANT SUPPORTS AND FASTENERS AS REQUIRED.
- EXISTING ELECTRICAL DISTRIBUTION TO REMAIN.
- MAKE ALL ALLOWANCES TO DISCONNECT AND RECONNECT ESSENTIAL EXISTING CIRCUITS SYSTEM, ETC. THAT REQUIRE DISCONNECTION FOR DEMOLITION AND RECONNECTION TO MAKE ALL SUCH SYSTEMS FULLY AND COMPLETELY OPERATIONAL AFTER DEMOLITION IS COMPLETE.
- MAKE ALL PROVISIONS TO DISCONNECT, REMOVE, REINSTALL AND RECONNECT ALL EXISTING CEILING MOUNTED FIRE ALARM DEVICES, STROBES AND SPEAKERS AFTER NEW CEILING IS INSTALLED. REFER TO E5-02 AND E5-03 FOR NEW LOCATIONS AND ADDITIONAL NEW DEVICES.
- ALL EXISTING EXIT LIGHTS WITHIN THE SCOPE OF WORK AREA TO BE DISCONNECTED, REMOVED AND REPLACED WITH NEW. REFER TO E5-02 AND E5-03 FOR NEW EMERGENCY LIGHTING LAYOUT.

CONSULTANT

These design documents are prepared solely for the use by the party with whom the design professional has entered into a contract and there are no representations of any kind made by the design professional to any other party with whom the design professional has not entered into a contract. Any use of the drawings, data or electronic data without the expressed written permission of Tower Engineering Group is strictly prohibited. The contractor is responsible to verify all dimensions with conditions on the site and report discrepancies to Tower Engineering for adjustment. All rights to be retained.

TOWER PROJECT NO. : 13039

TOWER ENGINEERING GROUP
UNIT 1 - 1140 WAVERLEY ST. WINNIPEG, MB R3T 0P4
TEL: (204) 925-1150 FAX: (204) 925-1155
EMAIL: towereng@towereng.ca WEB: www.towereng.ca
• WINNIPEG • CALGARY • CAMBRIDGE

APEGN
Certificate of Authorization
Tower Engineering Group
No. 4156 Expiry: April 30, 2014

DO NOT SCALE DRAWINGS

Revision/	Issued for Tenders/Construction	Date/Date
Revision/	Description/Description	Date/Date
Client/Client		

**PUBLIC WORKS
GOVERNMENT SERVICES
CANADA**

100-167 LOMBARD AVENUE
PO BOX 1408
WINNIPEG, MANITOBA R3C 2Z1


Project Site/Titre du projet

**STANLEY KNOWLES FIT-UP
391 YORK AVENUE**

Approved by/Approuvé par
TT
Designed by/Concept par
DA
Drawn by/Dessiné par
LS
PWGSC Project Manager/Administrateur de Projets TPWSC
OH
PWGSC Architectural and Engineering Resources Manager/
Ressources Architecturales et de Directeur d'ingénierie, TPWSC
SO
Client/Client
PWGSC
Drawing title/Titre du dessin

**ELECTRICAL
SECOND FLOOR
POWER & SYSTEMS
DEMOLITION**

Project No./No. du projet	Sheet / Feuille	Revision no. / La Révision no.
R.056754.002	E2-03 OF 21	0



SECOND FLOOR PLAN

SCALE: 1:100

