



visions	description	date
	<p>A detail no. no. du detail</p> <p>B location drawing no. sur dessin no.</p> <p>C drawing no. dessin no.</p>	

project	projet
---------	--------

BUILDING AUTOMATION SYSTEM CONSOLIDATION

580 BOOTH, OTTAWA, ON

drawing	dessin
---------	--------

AHU-21
SUPPLY AIR
CONTROL SCHEMATIC

Designed By	CHRISTIAN WORKMAN	Conçu par
Date	AUGUST 2012	(yyyy/mm/dd)
Drawn By	HANI KARAM	Dessiné par
Date	AUGUST 2012	(yyyy/mm/dd)
Reviewed By	GREG SANTYR	Examiné par
Date	SEPTEMBER 2012	(yyyy/mm/dd)
Approved By	DANIEL ROY	Approuvé par
Date	SEPTEMBER 2012	(yyyy/mm/dd)
Sender	CORY CAMPBELL	Soumission
Project Manager	Administrateur de projets	
Project no.	R.041796.002	No. du projet
Drawing no.		No. du dessin

1. ANY EXISTING HARDWIRED INTERLOCKS BETWEEN ANY EQUIPMENT AND COMPONENTS OF MECHANICAL SYSTEMS AS WELL AS BETWEEN SAFETY AND MECHANICAL SYSTEMS ARE TO REMAIN IN OPERATING CONDITION.
2. PROVIDE 15A/1/120V ELECTRICAL CONNECTIONS FOR CONTROL EQUIPMENT AS REQUIRED.
3. PROVIDE CO-ORDINATION AS REQUIRED FOR CONTROL CONNECTIONS AT THE MOTOR CONTROL EQUIPMENT SUCH AS STARTERS, MCC, VFD.
4. ALL RELAYS AND RELAY WIRING ON SITE TO BE CHECKED ON SITE.
5. FREEZE STAT HARD WIRED TO SUPPLY FAN.
6. CONTRACTOR RESPONSIBLE FOR DETERMINING LOCATION OF EXISTING SENSORS.

N.T.S.