


Drawing name: K:\A\A000234-580 Booth Controls\400\440\A000234-M02 Bsmt.dwg Oct 01, 2013 - 10:58am



DRAWING NOTES:

- EXISTING HEATING COIL
- EXISTING UNIT HEATER
- EXISTING RE-HEAT COIL
- EXISTING GENERATOR ROOM EXHAUST FAN
- EXISTING STORAGE EXHAUST FAN
- EXISTING TRANSFORMER ROOM EXHAUST FAN
- EXISTING AHU SERVING GROUND FLOOR
- EXISTING GENERAL EXHAUST FAN
- EXISTING CHILLER
- EXISTING CHILLED WATER PUMPS
- EXISTING CONDENSER WATER PUMPS
- EXISTING STAIRWELL PRESSURIZATION FAN
- EXISTING MUA SERVING DEOC
- EXISTING AHU SERVING DEOC
- EXISTING BY-PASS BOX
- EXISTING CABINET UNIT HEATER SERVING MAIN ENTRANCE VESTIBULE
- EXISTING AC UNIT SERVING DEOC
- EXISTING WASHROOM EXHAUST FAN
- EXISTING SANITARY SUMP PUMPS SET
- EXISTING STORM WATER SUMP PUMPS SET
- EXISTING ELEVATOR PIT SUMP PUMP
- EXISTING 120/208V 3Ø 4W ELECTRICAL PANEL, PROVIDE ONE 15A-1P BREAKER AND CONNECT THE BAS CONTROL CIRCUIT
- PROVIDE 15A/1/120V HARD WIRED ELECTRICAL OUTLET FOR BAS
- EXISTING CONTROL SYSTEM OWS TO BE REPLACED WITH OPERATOR WORK STATION #1
- EXISTING CONTROL SYSTEM OWS TO BE REPLACED WITH OPERATOR WORK STATION #3

EXISTING GROUND FLOOR PERIMETER HEATING CONTROL VALVE
C/W ELECTRONIC ACTUATOR TO REMAIN EXISTING TEMPERATURE
SENSOR OR THERMOSTAT ON GROUND FLOOR. SEE M03
(TYPICAL)

Contractor to verify all dimensions & conditions on site and immediately notify the engineer of all discrepancies.

revisions	description	date
E	Issued for 100% review	2013-10-04
D	Issued for 99% review	2013-05-03
C	Issued for 66% review	2013-02-08
B	Issued for 33% review	2013-01-04
A	Issued for design development review	2012-11-02

A	A detail no. no. du detail	A
C	B location drawing no. sur dessin no.	B C
	C drawing no. dessin no.	

project

**BUILDING AUTOMATION
SYSTEM
CONSOLIDATION**

580 BOOTH, OTTAWA, ON

drawing

**BASEMENT FLOOR PLAN
CONTROLS**

Designed By	CHRISTIAN WORKMAN	Conçu par
Date	AUGUST 2012	(yyyy/mm/dd)
Drawn By	HANI KARAM	Dessiné par
Date	AUGUST 2012	(yyyy/mm/dd)
Reviewed By	GREG SANTYR	Examiné par
Date	SEPTEMBER 2012	(yyyy/mm/dd)
Approved By	DANIEL ROY	Approuvé par
Date	SEPTEMBER 2012	(yyyy/mm/dd)
Tender	CORY CAMPBELL	Soumission
Project Manager		Administrateur de projets
Project no.	R.041796.002	No. du projet
Drawing no.		No. du dessin