

Remarks:	Power: 120/208 V 3 ø 4 W										PANEL EP1				SYM. IC: 14000 A				Remarks:
	# OF CKTS: 42										LOCATION ELECTRICAL ROOM 006				MAINS: 225 A				
	INCOMING:														MAIN BKR: N/A A				
Designation		CKT #	Watts	BKR	PHASE	a	b	c	CKT #	Designation									
CHILLED FOOD HOLDING 142 CONDENSING UNIT		1	500	20	X	20	1612	2											
		3	500	3P	X	2P	1612	4		CHILLED FOOD HOLDING 142 EVAPORATOR #1									
		5	500		X	20	1612	6											
CHILLED FOOD HOLDING 142 HEAT TAPE/CTRLS		7	1200	15	X	2P	1612	8		CHILLED FOOD HOLDING 142 EVAPORATOR #2									
LTS: CHILLED FOOD HOLDING 142		9	200	20	X	15		10		SPARE									
SPARE		11		15	X	15		12		SPARE									
SPARE		13		15	X			14											
		15		15	X			16											
		17			X			18											
		19			X			20											
		21			X			22											
		23			X			24											
		25		X				26											
		27		X				28											
		29		X				30											
		31		X				32											
		33		X				34											
		35		X				36											
		37		X				38											
		39		X				40											
		41			X			42											
FEEDER:					SOURCE:														
Remarks:										Phase A Total		4924W				41.0A			
										Phase B Total		2312W				19.3A			
										Phase C Total		2112W				17.6A			
										TOTAL		9348W				26.0A			

Power: 120/208 V 3 ø 4 W				PANEL P3				SYM. I.C.: 1400V A			
# OF CKTS.: 66				LOCATION CORRIDOR 118				MAINS: 22T A			
MOUNTING RECESSED								MAIN BKR: N/A			
1-Remarks	2-Designation	3-CKT #	4-Watts	5-BKR	6-Phase	7-CKT#	8-Designation	9-Remarks			
1	EXT SIGNS	20	15	X	20	832	2	LTG: ROOM 108, 111, 112			
	LTG: ROOM 119, 121, 122	3	1216	X	20	1344	4	LTG: ROOM 108, 111, 112, 115, 116, 104, 105, 106, 107			
	LTG: ROOM 108, 109, 111, 112, 117, 118	5	980	20	X	900	6	LTG: LOADING DOCK 138			
	LTG: ROOM 139, 141, 142	7	1088	20	X	400	8	CLAY 05 006			
	EXTERIOR RECEPTACLES	9	450	20	X	750	10	RECEPT: ROOM: 99, 101, 103, 113, 114			
	SGMP FUSEZ 108 CONTROLS/HEAT TAPE	11	800	20	X	600	12	RECEPT: ROOM 107			
	RECEPT: MAIN AREA 102	13	450	20	X	1400	14	HAND DRYER DRY GOODS STORAGE 121			
	RECEPT: BREAKDOWN AREA 104	15	450	20	X	1400	16	HAND DRYER STAFF CHANGE ROOM 114			
2	TRAP PRIMER	17	100	15	X	1400	18	HAND DRYER STAFF WC & CHANGE RM 109			
2	HAND DRYER BREAKDOWN AREA 104	19	1400	20	X	800	20	RECEIVING COOLER 138 CONTROLLER/HEAT TAP			
2	DOOR OPERATOR DOOR 122AB	21	1400	20	X	1500	22	DOOR OPERATOR DOOR 104AB			
2	FLUSH CONTROL 109 104	23	200	15	X	2000	24	DOOR OPERATOR DOOR 108			
2	DOOR OPERATOR DOOR 101A	25	1000	20	X	1500	26	RECEPT OFFICE 112			
2	DOOR OPERATOR 100X	27	1000	20	X	1500	28	RECEPT OFFICE 111			
	GFI RECEPT: ROOM 109, 116	29	300	15	X	1500	30	RECEPT: SGMP PICKUP 101			
	RECEPT: OFFICE 103	31	600	15	X	800	32	RECEIVING FREEZER 108 CONTROLS/HEAT TAPE			
	SGMP FREEZER 108 CONTROLS/HEAT TAPE	33	800	15	X	1400	34	RECEPT: WORK TABLE DRY GOODS STORAGE 121			
	RECEPT: WORK TABLE BREAKDOWN AREA 122	35	1400	15	X	1400	36	RECEPT: WORK TABLE DRY GOODS STORAGE 121			
	RECEPT: WORK TABLE INGREDIENT ROOM 119	37	1400	15	X	1400	38	RECEPT: WORK TABLE BREAKDOWN AREA 104			
	RECEPT: WORK TABLE INGREDIENT ROOM 119	39	1400	15	X	1400	40	RECEPT: WORK TABLE BREAKDOWN AREA 104			
	RECEPT: WORK TABLE INGREDIENT ROOM 119	41	1400	15	X	1400	42	RECEPT: WORK TABLE BREAKDOWN AREA 104			
	HAND DRYER CORR 108	43	1400	20	X	1500	44	RECEPT: WORK TABLE INGREDIENT ROOM 119			
	RECEIVING COOLER EVAP	45	1000	20	X	1500	46	RECEPT: WORK TABLE INGREDIENT ROOM 119			
	SPARE	47	15	X	20	1000	48	SGMP FREEZER 108 EVAP			
	SPARE	49	15	X	20	50	50	SPARE			
	RECEIVING FREEZER EVAP	51	1500	20	X	52	52	SPARE			
	SPARE	53	1500	20	X	1000	54	RECEIVING COOLER 138 EVAP			
	SPARE	55	1500	20	X	56	56	SPARE			
	SPARE	57	15	X	20	58	58	SPARE			
	SPARE	59	15	X	15	60	60	SPARE			
	SPARE	61	15	X	15	62	62	SPARE			
	SPARE	63	15	X	15	64	64	SPARE			
	SPARE	65	15	X	15	66	66	SPARE			
FEEDER:					SOURCE:						
Remarks:	1 PROVIDE BREAKER LOCK				Phase A Total	16490 W		137.4 A			
	2 CONFIRM EXACT BREAKER AND WIRE CONFIGURATION				Phase B Total	19010 W		158.4 A			
					Phase C Total	15660 W		130.5 A			
					TOTAL	51160 W		142.2 A			