

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
401-1230 Government St.
Victoria
BC
V8W 3X4
Bid Fax: (250) 363-3344

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, 12th floor
800, rue Burrard, 12e étage
Vancouver
British C
V6Z 0B9

Title - Sujet Boiler Upgrade	
Solicitation No. - N° de l'invitation 23145-140271/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2013-12-23
GETS Reference No. - N° de référence de SEAG PW-\$PWY-011-7159	
File No. - N° de dossier PWY-3-36176 (011)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-01-06	Time Zone Fuseau horaire Pacific Standard Time PST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Anderson, Elaine PWY	Buyer Id - Id de l'acheteur pwy011
Telephone No. - N° de téléphone (250) 363-3298 ()	FAX No. - N° de FAX (250) 363-0395
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: NRCan - Pacific Forestry Centre - Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Amendment 001 (Addendum #1) is raised to answer questions raised from the site visit.

The following changes in the tender documents are effective immediately. This addendum will form part of the Contract documents.

Questions from Bidders:

Q.1 Section 3.6-3 Chemical treatment and water balance . Question is this only for new piping or entire system ?

A1. Water treatment and balancing shall be for the new piping only.

Q.2 Section 23-21-13-2.2 & 2.3 Victaulic roll groove is acceptable ?

A.2 Victaulic roll groove to conform CSA B242 is acceptable.

Q.3 Access to breaching on 2nd floor , Do we carry contractor cost for cutting and patching?

A.3 Re-use existing boiler B-1 vent opening. Modify/patch opening to suit with the new boiler vent size.

Q.4 Alternate Boiler: Model 2000 MBH or Model 2500 MBH

A.4 Alternate boiler shall have a capacity equal or better than the specified capacity, in this case use 2500 MBH. Due to limited height and space in the plantroom, please ensure that the proposed alternate boiler can fit to the available space and its maintenance clearance requirements are met.

All other terms and conditions remain unchanged.

END