

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Réception des soumissions - TPSGC / Bid Receiving
- PWGSC
1550, Avenue d'Estimauville
1550, D'Estimauville Avenue
Québec
Québec
G1J 0C7

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
TPSGC-PWGSC
601-1550, Avenue d'Estimauville
Québec
Québec
G1J 0C7

Title - Sujet Pieux-Palplanches quai 97&98	
Solicitation No. - N° de l'invitation EE517-141638/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client EE517-14-1638	Date 2013-12-24
GETS Reference No. - N° de référence de SEAG PW-\$QCM-008-15743	
File No. - N° de dossier QCM-3-36211 (008)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-01-14	Time Zone Fuseau horaire Heure Normale du l'Est HNE
F.O.B. - F.A.B. Specified Herein - Précisé dans les présentes Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input checked="" type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Rochette, Jean	Buyer Id - Id de l'acheteur qcm008
Telephone No. - N° de téléphone (418) 649-2834 ()	FAX No. - N° de FAX (418) 648-2209
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Title : STEEL PIPE PILES AND SHEET PILING FOR RECONSTRUCTION OF WHARVES 97 AND 98, QUÉBEC CITY, QC

Included in the present amendment :

1. Questions and answers 1 to 9
 2. Clarification
-

QUESTIONS AND ANSWERS :

Question 1 : Annexe A) Art. 1.1.. p18 : Please confirm whether the amounts payable will be as shown in the approved shop drawings?

Answer 1 : The amounts payable are those that are approved in shop drawings.

Question 2 : Annexe A) Art. 1.1: What cut off should be provided for the length of the connectors attached to the piles, 300 mm cut off being fixed elements or 2000 mm is cut off items to rock?

Answer 2 : The connectors are not required on the piles on a length of 300 mm only.

Question 3 : Annexe A) Art. 1.1: The sheet piles should be provided in pairs. As some half pairs are shown in Drawings can we supply some single sheet piles?

Answer 3 : The sheet piles will be provided in pairs unless otherwise specified in the plans.

Question 4 : Annexe A) Art. 1.1: Due to slight variations permitted center to center width of pipe piles system, Please confirm if the number of piles is fixed?

Answer 4 : The number of piles is fixed.

Question 5 : Annexe A) Art. 1.1: Confirm whether two 90 ° corners at the bottom end of mooring basin must be provided?

Answer 5 : Yes all 90 ° corners are part of the materials to be delivered.

Question 6 : Annexe A) Art. 7.5.1. p.25 We suggest adding that" the Piles provided should be numbered from 1 to 71, outside and legibly 100 mm high"

Answer 6 : Piles should be numbered and legible.

Question 7 : Annexe A) Art. 1.1 et Annexe E) Drawings : Is a cut-off 1000 mm would be acceptable over the last 6 pairs of piles and connecting the docks 97 and 96?

Answer 7 : Yes a cut-off 1000 mm is acceptable.

Question 8 : Specifications (section: 7.5.3.1.4) says that we are not allowed mid welds in the sheet piles. However, based on preliminary takeoffs + 2.3m that is required, there are some sheets (12 pairs) that exceed 85Feet in length. We cannot produce the sheet piles in longer than 85Feet, so for these 12 sheets we would be required to weld shorter pieces (one weld per sheet) to achieve the required lengths. We have welded sheet piles numerous times for other projects, and have never had any problems. All inspection (UT & Visual) would be to our cost - we would hire an approved 3rd party inspection company to do all inspections. Should we not have permission to mid weld a few pairs, then we would have to regret on this quotation, and unfortunately, PWGCS would be left with only one supplier.

Answer 8 : Only twelve pairs a single weld is acceptable provided it is done in the workshop and controlled by ultrasound on 100% of its length and will be inspected by an independent laboratory at the expense of the supplier.

Question 9 : For the Ultrasonic testing of the pipe welds, is there a standard (API or CWB) that you would like us to adhere to?

Answer 9 : The standard is the one with the most stringent requirements.

CLARIFICATION

1. The supplier must take into account that some sheet piles will be reversed and for some piles, connectors must be welded reversed.
 2. For cut-off 2000mm, there is no need to add 300 mm.
-

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.