

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, 2nd floor  
800, rue Burrard, 2e étage  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, 12th floor  
800, rue Burrard, 12e étage  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Kent Institution - Modify Gun Ports	
<b>Solicitation No. - N° de l'invitation</b> EZ899-141867/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2014-01-08
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-004-7153	
<b>File No. - N° de dossier</b> PWY-3-36231 (004)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2014-01-13</b>	<b>Time Zone</b> Fuseau horaire Pacific Standard Time PST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Mestry, Ruth (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy004
<b>Telephone No. - N° de téléphone</b> (604) 775-9385 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> CSC - Kent Institution - Agassiz, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EZ899-141867/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

004

File No. - N° du dossier

PWY-3-36231

Buyer ID - Id de l'acheteur

pw004

CCC No./N° CCC - FMS No/ N° VME

---

Attached is Addendum No. 2

**MODIFY GUN PORTS**

**POD1 Control Post & Principal Entrance Control Post**

**ADDENDUM #2**

2014-01-07

Page 1

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

---

**SPECIFICATIONS**

.1 Section 08 80 50 - Glazing

(1) **Add:** new Para 2.3.4 and sub-paragraph 2.3.4.1:

.4 Gaskets:

- .1 Closed cell high density Neoprene sponge minimum 3 mm thickness x 50 mm wide with one side with self adhesive strip. Gaskets used to separate glass from polycarbonate security glazing and gun port metal clamp components.

.2 Section 11 19 60 - Detention Fabrication:

(2) **Add:** new Para 3.1.1.5:

- .5 Install new and reused gunports using new sex-bolt fasteners. For reused gunports at Principal Entrance the existing sex-bolt fasteners may be reused provided they are of sufficient length and are undamaged.

**END OF ADDENDUM No 2**

---