

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
PWGSC/TPSGC Acquisitions  
1045 Main Street  
1st Floor, Lobby C  
Unit 108  
Moncton, NB E1C 1H1  
Bid Fax: (506) 851-6759

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
NB / PEI Division - Moncton Acquisitions Office  
1045 Main Street  
1st Floor, Lobby C  
Unit 108  
Moncton, NB E1C 1H1

<b>Title - Sujet</b> Electrical Supplies	
<b>Solicitation No. - N° de l'invitation</b> 5P131-130412/B	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> 5P131-130412	<b>Date</b> 2014-01-14
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$MCT-018-4741	
<b>File No. - N° de dossier</b> MCT-3-36048 (018)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-01-17</b>	<b>Time Zone</b> Fuseau horaire Atlantic Standard Time AST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Martin, Lisa M.	<b>Buyer Id - Id de l'acheteur</b> mct018
<b>Telephone No. - N° de téléphone</b> (506) 851-7811 ( )	<b>FAX No. - N° de FAX</b> (506) 851-6759
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Solicitation Amendment No. 004**

This solicitation is hereby amended to provide the following questions and answers.

**Question 1.** For item 26 is it acceptable for us to supply "Southwire 28kV primary UD cable jacketed / HDPLUS" cable?

This proposed cable is predominantly used for primary underground distribution; suitable for use in wet of dry locations, direct burial, underground ducts, and exposure to direct sunlight. To be used at conductor temperatures not to exceed 90°C normal operation.

**Specifications**

Southwire Primary UD Cable is manufactured to CAN/CSA-C68.3-97.

**Construction**

Conductor: Moisture Blocked, Compact ¾ Hard (H16/H26) Aluminum per ASTM B 400

Strand Shield: Super-Smooth, Semi-conducting Crosslinked Material

Insulation: Tree Retardant Crosslinked Polyethylene

Insulation Shield: Strippable Semi-conducting Crosslinked Material

Concentric Neutral: Copper Neutral / Size: AWG 14, Quantity: 16

Jacket: Longitudinally Water Blocked, Non-conducting Linear Low Density Polyethylene Material

The Southwire cable is stock in Canada, the specified cable is made to order and the minimum order qty's are high.

If we quote on the Southwire cable we will quote the load break elbows (item 27) to match this cable.

**Answer 1:** Yes, Southwire cable is OK.

**Question 2.**

11) OPEN POWER DISTRIBUTION BLOCKS WIRE RANGE 2/0-#14, QTY: 17 EA. SINGLE PRIMARY TWO POLES SECONDARY. 185 AMP CSA RATED  
DIMENSIONS: HEIGHT=75MM, WIDTH=45MM, DEPT=50MM

**Q2.** WHAT'S THE GAUGE FOR THE WIRES FOR THE SECONDARY POLES?

**Answer 2:** Secondary poles are the same size- 2/0-#14

**Question 3.**

12) JUNCTION BOXES, CSA TYPE 3RPAINTED STEEL GALVINIZED. QTY: 42 EA.DIMENSIONS: WIDTH=8", HEIGHT=12",DEPT=4" FORMED AND SPOT WELDED FROM 16 OR 14 GAUGE GALVINIZED STEEL. DRIP-SHIELD TOP AND SEAM-FREE SIDES, FRONT AND BACK. SLIP-ON REMOVABLE COVER  
FASTENED WITH PLATED STEEL SCREWS. DOOR HANDLES ON BODY TYPE C ENCLOSURE. EMBOSSED MOUNTING HOLES ON BACK OF ENCLOSURE. EASILY REMOVED KNOCKOUTS ON BOTTOM OF ENCLOSURE.

**Q3.** PAINTED WHAT COLOUR?

**Answer 3:** Gray

---

**Question 4.**

18) 2" PVC CONDUIT QTY: 200 MR

**Q4:** IN LENGTHS OF 10' OR 20'?

**Answer 4:** 10 ft lengths

**Question 5.**

23) 4" PVC RIGID CONDUIT QTY: 500 MR

**Q5:** IN LENGTHS OF 10' OR 20'?

**Answer 5:** 10 ft lengths

**Question 6.**

28) 2" PVC LB'S WITH LOCKNUTS QTY: 42 EA.

**Q6:** WIRES COMING IN OR OUT OF LB "BOXES" ARE SECURED WITH COUPLINGS, NOT LOCKNUTS... WANT US TO QUOTE THE COUPLINGS? IF SO, WE'LL NEED THE WIRE GAUGE.

**Answer 6:** Disregard locknuts

**Question 7.**

29) HIGH VOLTAGE CAUTION TAPE QTY: 2000 MR

**Q7:** DIMENSIONS REQUIRED? COLOUR REQUIRED? ONLY WRITTEN HIGH VOLTAGE OR MORE INFORMATION NEEDS TO APPEAR? IS IT JUST FOR AN INDOOR USAGE TO BLOCK OFF AN AREA OR TO BE BURIED UNDERGROUND?

**Answer 7:** Buried underground red "DANGER BURIED ELECTRICAL CABLE" or something to that effect.

**Question 8**

30) ROLLS, GREEN ELECTRICAL TAPE QTY: 20 EA.

**Q8:** IS YOUR TAPE JUST FOR IDENTIFYING YOUR WIRES OR YOU NEED TRUE CABLE INSULATION CAPABILITIES?

**Answer 8:** IDENTIFYING

**Question 9.**

31) ROLLS, WHITE ELECTRICAL TAPE QTY: 20 EA.

**Q9:** IS YOUR TAPE JUST FOR IDENTIFYING YOUR WIRES OR YOU NEED TRUE CABLE INSULATION CAPABILITIES?

Solicitation No. - N° de l'invitation

5P131-130412/B

Client Ref. No. - N° de réf. du client

5P131-130412

Amd. No. - N° de la modif.

004

File No. - N° du dossier

MCT-3-36048

Buyer ID - Id de l'acheteur

mct018

CCC No./N° CCC - FMS No/ N° VME

---

**Answer 9: IDENTIFYING**

**Question 10.**

32) ROLLS, BLACK ELECTRICAL TAPE QTY: 40 EA.

**Q10:** IS YOUR TAPE JUST FOR IDENTIFYING YOUR WIRES OR YOU NEED TRUE CABLE INSULATION CAPABILITIES?

**Answer 10: IDENTIFYING**

And

This solicitation is hereby amended to:

(1) Reference: Page 6 of - de 9 **Delivery Date**

DELETE: While delivery is requested by 28 February 2014, the best delivery that could be offered is \_\_\_\_\_ and;

INSERT: All the deliverables must be received on or before March 14, 2014.

If your bid has already been forwarded and you wish to revise same, this revision should be sent either in a sealed envelope and mailed to the above address or by facsimile (506) 851-6759 and reach the undersigned before the appropriate closing date. The solicitation number and the closing date are to be shown on the outside of the sealed envelope or on the facsimile transmission.

All other terms and conditions of the solicitation document remain unchanged.

All enquiries concerning this amendment are to be forwarded to:

Name Lisa Martin

Telephone No.: (506) 851-7811

Facsimile No: (506) 851-6759