

7 M502 BUILDING SECTION MECHANICAL

1:100

DRAWING KEYNOTES:

1. DEMOLISH EXISTING MOTORIZED 1500x900 R.A. DAMPER AND PATCH BOTTOM OF MIXED AIR PLENUM.
2. EXISTING MOTORIZED 1500x900 O.A. DAMPER TO REMAIN.
3. NEW 1500x900 R.A. DAMPER ON TOP OF EXISTING MIXED AIR PLENUM.
4. NEW 2540x1702 O.A. DUCT CONNECTION FROM NEW AIR HANDLING TO EXISTING O.A. INTAKE PLENUM. TYPICAL OF 2.
5. ANGLE IRON STAND ON HOUSEKEEPING PAD. HEIGHT TO SUIT CONDENSATE PIPING.

Publics Works and Government Services Canada / Travaux publics et services gouvernementaux Canada

Canada

Contractor to verify all dimensions & conditions on site and immediately notify the engineer of all discrepancies.

revisions	description	date
1	ISSUED FOR ADDENDUM No.01	2013/12/20

A detail no. / no. du detail
B location drawing no. / sur dessin no.
C drawing no. / dessin no.

project / projet

SIR FREDERICK BANTING RESEARCH CENTRE

ANIMAL TO WET LAB CONVERSION

251 SIR FREDERICK BANTING WAY, ON

drawing / dessin

MECHANICAL EQUIPMENT

Designed By / Conçu par	W. CURRIE	
Date		(yyyy/mm/dd)
Drawn By / Dessiné par	W. CURRIE	
Date		(yyyy/mm/dd)
Reviewed By / Examiné par	S. DIACHUN	
Date		(yyyy/mm/dd)
Approved By / Approuvé par	S. DIACHUN	
Date		(yyyy/mm/dd)
Tender / Soumission		
Project Manager / Administrateur de projets		
Project no. / No. du projet	R.044033.002	
Drawing no. / No. du dessin	M502-R2	

PWGSC 11X17 (431x279)